

Site Radon Inspection Report

Date : 02/10/2016

Blaine Cunningham
Webster Central Schools
119 South Ave
Webster, NY 14580-

Client: Dewitt Rd Elementary

Test Location: 722 Dewitt Road
Webster, NY 14580-

Individual Canister Results

Canister ID# : 2396619 Test Start : 01/26/2016 @ 12:50
Canister Type : Charcoal Canister 3 inch Test Stop : 01/29/2016 @ 14:07
Location : Main Off Received: 02/10/2016 @ 14:11
Radon Level : **0.2 pCi/L** Analyzed: 02/11/2016 @ 16:47
Error for Measurement is: ± 0.8 pCi/L

Canister ID# : 2396748 Test Start : 01/26/2016 @ 13:24
Canister Type : Charcoal Canister 3 inch Test Stop : 01/29/2016 @ 14:31
Location : Second Floor-218 Received: 02/10/2016 @ 14:11
Radon Level : **0.1 pCi/L** Analyzed: 02/11/2016 @ 17:02
Error for Measurement is: ± 0.2 pCi/L

Canister ID# : 2396755 Test Start : 01/26/2016 @ 13:08
Canister Type : Charcoal Canister 3 inch Test Stop : 01/29/2016 @ 14:17
Location : 106 Received: 02/10/2016 @ 14:11
Radon Level : **0.1 pCi/L** Analyzed: 02/11/2016 @ 16:13
Error for Measurement is: ± 0.1 pCi/L

Canister ID# : 2396751 Test Start : 01/26/2016 @ 13:16
Canister Type : Charcoal Canister 3 inch Test Stop : 01/29/2016 @ 14:24
Location : Stage Received: 02/10/2016 @ 14:11
Radon Level : **0.2 pCi/L** Analyzed: 02/11/2016 @ 17:02
Error for Measurement is: ± 1.0 pCi/L

Canister ID# : 2396792 Test Start : 01/26/2016 @ 13:13
Canister Type : Charcoal Canister 3 inch Test Stop : 01/29/2016 @ 14:20
Location : 117 Received: 02/10/2016 @ 14:11
Radon Level : **0.1 pCi/L** Analyzed: 02/11/2016 @ 16:13
Error for Measurement is: ± 0.1 pCi/L



Andreas C. George
Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan
Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 02/10/2016

Canister ID# : 2396801 Test Start : 01/26/2016 @ 13:14
Canister Type : Charcoal Canister 3 inch Test Stop : 01/29/2016 @ 14:21
Location : 118 Received: 02/10/2016 @ 14:11
Radon Level : **0.5 pCi/L** Analyzed: 02/11/2016 @ 16:47
Error for Measurement is: \pm 1.2 pCi/L

Canister ID# : 2396795 Test Start : 01/26/2016 @ 12:53
Canister Type : Charcoal Canister 3 inch Test Stop : 01/29/2016 @ 14:10
Location : 111 Received: 02/10/2016 @ 14:11
Radon Level : **0.1 pCi/L** Analyzed: 02/11/2016 @ 16:47
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2396750 Test Start : 01/26/2016 @ 12:54
Canister Type : Charcoal Canister 3 inch Test Stop : 01/29/2016 @ 14:11
Location : 114 Received: 02/10/2016 @ 14:11
Radon Level : **0.1 pCi/L** Analyzed: 02/11/2016 @ 16:28
Error for Measurement is: \pm 0.2 pCi/L

Canister ID# : 2396757 Test Start : 01/26/2016 @ 13:22
Canister Type : Charcoal Canister 3 inch Test Stop : 01/29/2016 @ 14:26
Location : Kitchen Received: 02/10/2016 @ 14:11
Radon Level : **0.5 pCi/L** Analyzed: 02/11/2016 @ 16:13
Error for Measurement is: \pm 1.2 pCi/L

Canister ID# : 2396836 Test Start : 01/26/2016 @ 13:30
Canister Type : Charcoal Canister 3 inch Test Stop : 01/29/2016 @ 14:33
Location : Second Floor-201 Received: 02/10/2016 @ 14:11
Radon Level : **0.2 pCi/L** Analyzed: 02/11/2016 @ 16:47
Error for Measurement is: \pm 1.0 pCi/L

Canister ID# : 2396848 Test Start : 01/26/2016 @ 12:50
Canister Type : Charcoal Canister 3 inch Test Stop : 01/29/2016 @ 14:07
Location : Principal Off Received: 02/10/2016 @ 14:11
Radon Level : **1.5 pCi/L** Analyzed: 02/11/2016 @ 16:47
Error for Measurement is: \pm 1.4 pCi/L

Canister ID# : 2396860 Test Start : 01/26/2016 @ 13:11
Canister Type : Charcoal Canister 3 inch Test Stop : 01/29/2016 @ 14:19
Location : 103 Received: 02/10/2016 @ 14:11
Radon Level : **0.1 pCi/L** Analyzed: 02/11/2016 @ 16:28
Error for Measurement is: \pm 0.4 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 02/10/2016

Canister ID# : 2396835 Test Start : 01/26/2016 @ 12:56
Canister Type : Charcoal Canister 3 inch Test Stop : 01/29/2016 @ 14:12
Location : 102 Received: 02/10/2016 @ 14:11
Radon Level : **0.9 pCi/L** Analyzed: 02/11/2016 @ 16:28
Error for Measurement is: \pm 1.2 pCi/L

Canister ID# : 2396847 Test Start : 01/26/2016 @ 13:17
Canister Type : Charcoal Canister 3 inch Test Stop : 01/29/2016 @ 14:24
Location : 198 Received: 02/10/2016 @ 14:11
Radon Level : **0.1 pCi/L** Analyzed: 02/11/2016 @ 16:47
Error for Measurement is: \pm 0.1 pCi/L

Canister ID# : 2396766 Test Start : 01/26/2016 @ 13:12
Canister Type : Charcoal Canister 3 inch Test Stop : 01/29/2016 @ 14:20
Location : 116 Received: 02/10/2016 @ 14:11
Radon Level : **0.6 pCi/L** Analyzed: 02/11/2016 @ 16:13
Error for Measurement is: \pm 1.2 pCi/L

Canister ID# : 2396777 Test Start : 01/26/2016 @ 13:15
Canister Type : Charcoal Canister 3 inch Test Stop : 01/29/2016 @ 14:23
Location : 119 Received: 02/10/2016 @ 14:11
Radon Level : **0.1 pCi/L** Analyzed: 02/11/2016 @ 16:47
Error for Measurement is: \pm 0.1 pCi/L

Canister ID# : 2396774 Test Start : 01/26/2016 @ 13:33
Canister Type : Charcoal Canister 3 inch Test Stop : 01/29/2016 @ 14:29
Location : Second Floor-205 Received: 02/10/2016 @ 14:11
Radon Level : **0.1 pCi/L** Analyzed: 02/11/2016 @ 17:02
Error for Measurement is: \pm 0.2 pCi/L

Canister ID# : 2396785 Test Start : 01/26/2016 @ 13:02
Canister Type : Charcoal Canister 3 inch Test Stop : 01/29/2016 @ 14:16
Location : 164 Received: 02/10/2016 @ 14:11
Radon Level : **0.1 pCi/L** Analyzed: 02/11/2016 @ 16:13
Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 2396758 Test Start : 01/26/2016 @ 13:10
Canister Type : Charcoal Canister 3 inch Test Stop : 01/29/2016 @ 14:18
Location : 104 Received: 02/10/2016 @ 14:11
Radon Level : **0.3 pCi/L** Analyzed: 02/11/2016 @ 16:47
Error for Measurement is: \pm 1.3 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 02/10/2016

Canister ID# : 2404273 Test Start : 01/26/2016 @ 13:08
Canister Type : Charcoal Canister 3 inch Test Stop : 01/29/2016 @ 14:16
Location : 135 Received: 02/10/2016 @ 14:11
Radon Level : **0.6 pCi/L** Analyzed: 02/11/2016 @ 17:02
Error for Measurement is: \pm 1.2 pCi/L

Canister ID# : 2404289 Test Start : 01/26/2016 @ 12:57
Canister Type : Charcoal Canister 3 inch Test Stop : 01/29/2016 @ 14:12
Location : 101 Received: 02/10/2016 @ 14:11
Radon Level : **0.9 pCi/L** Analyzed: 02/11/2016 @ 16:28
Error for Measurement is: \pm 1.4 pCi/L

Canister ID# : 2404294 Test Start : 01/26/2016 @ 13:23
Canister Type : Charcoal Canister 3 inch Test Stop : 01/29/2016 @ 14:26
Location : Kitchen Received: 02/10/2016 @ 14:11
Radon Level : **0.1 pCi/L** Analyzed: 02/11/2016 @ 17:02
Error for Measurement is: \pm 0.2 pCi/L

Canister ID# : 2404170 Test Start : 01/26/2016 @ 13:00
Canister Type : Charcoal Canister 3 inch Test Stop : 01/29/2016 @ 14:13
Location : K1-K2 Store Rm Received: 02/10/2016 @ 14:11
Radon Level : **1.6 pCi/L** Analyzed: 02/11/2016 @ 16:47
Error for Measurement is: \pm 1.4 pCi/L

Canister ID# : 2404158 Test Start : 01/26/2016 @ 12:54
Canister Type : Charcoal Canister 3 inch Test Stop : 01/29/2016 @ 14:11
Location : 110 Received: 02/10/2016 @ 14:11
Radon Level : **0.1 pCi/L** Analyzed: 02/11/2016 @ 17:02
Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 2404098 Test Start : 01/26/2016 @ 13:00
Canister Type : Charcoal Canister 3 inch Test Stop : 01/29/2016 @ 14:13
Location : K2 Received: 02/10/2016 @ 14:11
Radon Level : **1.6 pCi/L** Analyzed: 02/11/2016 @ 16:28
Error for Measurement is: \pm 1.3 pCi/L

Canister ID# : 2404132 Test Start : 01/26/2016 @ 13:00
Canister Type : Charcoal Canister 3 inch Test Stop : 01/29/2016 @ 14:14
Location : K1 Received: 02/10/2016 @ 14:11
Radon Level : **0.4 pCi/L** Analyzed: 02/11/2016 @ 17:02
Error for Measurement is: \pm 1.2 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 02/10/2016

Canister ID# : 2404144 Test Start : 01/26/2016 @ 12:52
Canister Type : Charcoal Canister 3 inch Test Stop : 01/29/2016 @ 14:10
Location : 131 Received: 02/10/2016 @ 14:11
Radon Level : **0.2 pCi/L** Analyzed: 02/11/2016 @ 16:47
Error for Measurement is: \pm 0.9 pCi/L

Canister ID# : 2404166 Test Start : 01/26/2016 @ 13:35
Canister Type : Charcoal Canister 3 inch Test Stop : 01/29/2016 @ 14:29
Location : BL Received: 02/10/2016 @ 14:11
Radon Level : **0.8 pCi/L** Analyzed: 02/11/2016 @ 16:47
Error for Measurement is: \pm 1.2 pCi/L

Canister ID# : 2396859 Test Start : 01/26/2016 @ 13:06
Canister Type : Charcoal Canister 3 inch Test Stop : 01/29/2016 @ 14:16
Location : Art Rm Received: 02/10/2016 @ 14:11
Radon Level : **0.1 pCi/L** Analyzed: 02/11/2016 @ 17:02
Error for Measurement is: \pm 1.0 pCi/L

Canister ID# : 2396826 Test Start : 01/26/2016 @ 13:21
Canister Type : Charcoal Canister 3 inch Test Stop : 01/29/2016 @ 14:25
Location : Cafe Received: 02/10/2016 @ 14:11
Radon Level : **0.1 pCi/L** Analyzed: 02/11/2016 @ 16:28
Error for Measurement is: \pm 0.7 pCi/L

Canister ID# : 2396858 Test Start : 01/26/2016 @ 13:25
Canister Type : Charcoal Canister 3 inch Test Stop : 01/29/2016 @ 14:31
Location : Second Floor-213 Received: 02/10/2016 @ 14:11
Radon Level : **0.1 pCi/L** Analyzed: 02/11/2016 @ 16:28
Error for Measurement is: \pm 0.1 pCi/L

Canister ID# : 2396849 Test Start : 01/26/2016 @ 13:12
Canister Type : Charcoal Canister 3 inch Test Stop : 01/29/2016 @ 14:19
Location : 115 Received: 02/10/2016 @ 14:11
Radon Level : **0.5 pCi/L** Analyzed: 02/11/2016 @ 17:02
Error for Measurement is: \pm 1.2 pCi/L

Canister ID# : 2396829 Test Start : 01/26/2016 @ 12:54
Canister Type : Charcoal Canister 3 inch Test Stop : 01/29/2016 @ 14:11
Location : Centr Received: 02/10/2016 @ 14:11
Radon Level : **0.1 pCi/L** Analyzed: 02/11/2016 @ 16:47
Error for Measurement is: \pm 0.2 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 02/10/2016

Canister ID# : 2396833 Test Start : 01/26/2016 @ 12:52
 Canister Type : Charcoal Canister 3 inch Test Stop : 01/29/2016 @ 14:10
 Location : 112 Received: 02/10/2016 @ 14:11
 Radon Level : **0.5 pCi/L** Analyzed: 02/11/2016 @ 16:28
 Error for Measurement is: \pm 1.2 pCi/L

Canister ID# : 2396821 Test Start : 01/26/2016 @ 13:30
 Canister Type : Charcoal Canister 3 inch Test Stop : 01/29/2016 @ 14:33
 Location : Second Floor-201 Received: 02/10/2016 @ 14:11
 Radon Level : **0.1 pCi/L** Analyzed: 02/11/2016 @ 16:47
 Error for Measurement is: \pm 0.2 pCi/L

Canister ID# : 2396817 Test Start : 01/26/2016 @ 13:01
 Canister Type : Charcoal Canister 3 inch Test Stop : 01/29/2016 @ 14:15
 Location : Health Received: 02/10/2016 @ 14:11
 Radon Level : **0.1 pCi/L** Analyzed: 02/11/2016 @ 16:47
 Error for Measurement is: \pm 0.1 pCi/L

Canister ID# : 2396805 Test Start : 01/26/2016 @ 13:16
 Canister Type : Charcoal Canister 3 inch Test Stop : 01/29/2016 @ 14:24
 Location : 199 Received: 02/10/2016 @ 14:11
 Radon Level : **0.1 pCi/L** Analyzed: 02/11/2016 @ 16:13
 Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 2396804 Test Start : 01/26/2016 @ 13:10
 Canister Type : Charcoal Canister 3 inch Test Stop : 01/29/2016 @ 14:18
 Location : 105 Received: 02/10/2016 @ 14:11
 Radon Level : **0.1 pCi/L** Analyzed: 02/11/2016 @ 16:28
 Error for Measurement is: \pm 0.3 pCi/L

Canister ID# : 2396808 Test Start : 01/26/2016 @ 13:21
 Canister Type : Charcoal Canister 3 inch Test Stop : 01/29/2016 @ 14:25
 Location : Cafe Received: 02/10/2016 @ 14:11
 Radon Level : **0.1 pCi/L** Analyzed: 02/11/2016 @ 17:02
 Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 2398830 Test Start : 01/26/2016 @ 12:51
 Canister Type : Charcoal Canister 3 inch Test Stop : 01/29/2016 @ 14:08
 Location : VP Received: 02/10/2016 @ 14:11
 Radon Level : **0.1 pCi/L** Analyzed: 02/11/2016 @ 16:28
 Error for Measurement is: \pm 0.1 pCi/L




Andreas C. George
 Radon Measurement Specialist
 NJ MES 11089



Dante Galan
 Laboratory Director

NRSB ARL0001
 NYS ELAP ID: 10806
 PADEP ID: 0346
 NJDEP ID: NY933
 NJ MEB 90036
 FL DOH RB1609
 IL RNL2000201

Site Radon Inspection Report

Date : 02/10/2016

Canister ID# : 2398827 Test Start : 01/26/2016 @ 13:35
Canister Type : Charcoal Canister 3 inch Test Stop : 01/29/2016 @ 14:29
Location : BL Received: 02/10/2016 @ 14:11
Radon Level : **0.1 pCi/L** Analyzed: 02/11/2016 @ 16:28
Error for Measurement is: \pm 0.2 pCi/L

Canister ID# : 2404117 Test Start : 01/26/2016 @ 13:06
Canister Type : Charcoal Canister 3 inch Test Stop : 01/29/2016 @ 14:16
Location : Art Rm Stor Received: 02/10/2016 @ 14:11
Radon Level : **0.1 pCi/L** Analyzed: 02/11/2016 @ 16:47
Error for Measurement is: \pm 0.3 pCi/L

Canister ID# : 2398834 Test Start : 01/26/2016 @ 13:01
Canister Type : Charcoal Canister 3 inch Test Stop : 01/29/2016 @ 14:15
Location : 109 Received: 02/10/2016 @ 14:11
Radon Level : **0.5 pCi/L** Analyzed: 02/11/2016 @ 16:28
Error for Measurement is: \pm 1.5 pCi/L

Canister ID# : 2402801 Test Start : 01/26/2016 @ 12:56
Canister Type : Charcoal Canister 3 inch Test Stop : 01/29/2016 @ 14:12
Location : 102 Received: 02/10/2016 @ 14:11
Radon Level : **1.8 pCi/L** Analyzed: 02/11/2016 @ 16:47
Error for Measurement is: \pm 1.3 pCi/L

Canister ID# : 2402361 Test Start : 01/26/2016 @ 13:09
Canister Type : Charcoal Canister 3 inch Test Stop : 01/29/2016 @ 14:17
Location : 125 Received: 02/10/2016 @ 14:11
Radon Level : **0.7 pCi/L** Analyzed: 02/11/2016 @ 16:13
Error for Measurement is: \pm 1.2 pCi/L

Canister ID# : 2396966 Test Start : 01/26/2016 @ 13:35
Canister Type : Charcoal Canister 3 inch Test Stop : 01/29/2016 @ 14:29
Location : Second Floor-206 Received: 02/10/2016 @ 14:11
Radon Level : **0.1 pCi/L** Analyzed: 02/11/2016 @ 16:28
Error for Measurement is: \pm 0.7 pCi/L

Canister ID# : 2396922 Test Start : 01/26/2016 @ 13:32
Canister Type : Charcoal Canister 3 inch Test Stop : 01/29/2016 @ 14:34
Location : Second Floor-203 Received: 02/10/2016 @ 14:11
Radon Level : **0.1 pCi/L** Analyzed: 02/11/2016 @ 16:13
Error for Measurement is: \pm 0.2 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 02/10/2016

Canister ID# : 2396881 Test Start : 01/26/2016 @ 13:07
Canister Type : Charcoal Canister 3 inch Test Stop : 01/29/2016 @ 14:16
Location : 135 Received: 02/10/2016 @ 14:11
Radon Level : **0.1 pCi/L** Analyzed: 02/11/2016 @ 17:02
Error for Measurement is: \pm 1.4 pCi/L

Canister ID# : 2396868 Test Start : 01/26/2016 @ 13:15
Canister Type : Charcoal Canister 3 inch Test Stop : 01/29/2016 @ 14:23
Location : 119 Received: 02/10/2016 @ 14:11
Radon Level : **0.8 pCi/L** Analyzed: 02/11/2016 @ 16:28
Error for Measurement is: \pm 1.5 pCi/L

The reported results indicate that radon levels in the building are below the United States Environmental Protection Agency (EPA) action level of 4.0 picoCuries per liter of air (pCi/L). The EPA recommends retesting if your living patterns change and you begin occupying a lower level of the building, such as a basement or if major remodeling is done.

General radon information may be obtained by consulting the EPA booklet: A Citizen's Guide to Radon (www.epa.gov/radon/pubs/citguide.html). To request a copy or for further information, please contact your state health department. The EPA maintains a radon information website, including copies of its publications, at www.epa.gov/iaq/radon.

For New Jersey clients: Please see the attached guidance document entitled Radon Testing and Mitigation: The Basics for further information.

For New York clients: If the radon level of one or more testing devices is equal to or exceeds 20 pCi/L please contact the New York State Department of Health, Bureau of Environmental Radiation Protection, for technical advice and assistance at 518-402-7556 or toll free 1-800-458-1158.

PLEDGE OF ASSURED QUALITY

All procedures used for generating this report are in complete accordance with the current EPA protocols for the analysis of radon in air (EPA 402-R-92-004). The analytical results relate only to the samples tested, in the condition received by the lab, and that calculations were based upon the information supplied by client. RTCA and its personnel do not assume responsibility or liability, collectively and individually, for analysis results when detectors have been improperly handled or placed by the consumer, nor does RTCA and its personnel accept responsibility for any financial or health consequences of subsequent action or lack of action, taken by the customer or its consultants based on RTCA-provided results.



Andreas C. George
Radon Measurement Specialist
NJ MES 11089



Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201