

# Lead in Drinking Water Testing – Basket Road Dugouts November 7, 2025

## Location:

Webster Central School District  
1028 Ridge Road, Suite 12  
Webster, New York 14580



## LaBella Project No.

2251107

December 15, 2025



## Table of Contents

<b>1.0</b>	<b>BACKGROUND</b> .....	<b>1</b>
<b>2.0</b>	<b>SAMPLING PROCEDURES</b> .....	<b>1</b>
<b>3.0</b>	<b>RESULTS</b> .....	<b>2</b>
<b>3.1</b>	<b><i>Total Water Sample Summary</i></b> .....	<b>2</b>
<b>4.0</b>	<b>RESPONSE MEASURES</b> .....	<b>2</b>
<b>4.1</b>	<b><i>Immediate Response</i></b> .....	<b>2</b>
<b>4.2</b>	<b><i>Short-Term Control Measures</i></b> .....	<b>3</b>
<b>4.3</b>	<b><i>Permanent Control Measures</i></b> .....	<b>3</b>
<b>5.0</b>	<b>REPORTING AND RECORD KEEPING</b> .....	<b>3</b>

## Appendices

Appendix A – Detailed Results Spreadsheet

Appendix B – Laboratory Analytical Results

Appendix C – Licenses and Certifications



## 1.0 BACKGROUND

---

LaBella Associates, D.P.C. (LaBella) sampled potable water outlets throughout the Webster Central School District (WCSD) in accordance with Subpart 67-4 of Title 10 of the New York State Codes, Rules, and Regulations (Subpart 67-4). Under Subpart 67-4, “all school districts and boards of cooperative educational services are required to test potable water for lead contamination, and to develop and implement a lead remediation plan, where applicable.”

Lead contamination is a significant public health concern. Lead has been linked to various harmful conditions such as central nervous system and kidney damage. Children, especially those under the age of 6, are particularly susceptible to the toxic effects of lead. There is no known safe level of lead in blood, and the US Environmental Protection Agency (USEPA) has set a Maximum Contaminant Level Goal of zero. As of 2022, Subpart 67-4 establishes an action level of 5 parts per billion (ppb) in school drinking water. If test results exceed this level, the district must undertake remedial action.

The Subpart 67-4 testing requirement was first promulgated under emergency legislation in 2016, and subsequently signed into permanent law. Subsequently, Senate Bill S2122A was signed into law on December 22, 2022, changing various components of Subpart 67-4. Key revisions to the standard include a reduced action level down to 5 parts per billion (ppb), and requires that testing be performed every three years. The next round of sampling reports are due by the end of 2025. This report has been designed to fulfill the initial testing and reporting requirements outlined in Subpart 67-4.

LaBella conducted the initial water sampling on November 7, 2025 at Basket Road Dugouts located at 1645 Boulter Industrial Park in Webster, NY. Outlets that were selected for sampling include drinking fountains, bottle fillers, kitchen sinks, classroom sinks, medical office sinks, and ice machines. Outlets categorically excluded from testing included laboratory sinks, bathroom sinks, art room sinks, single-handle faucets, showers, toilets, janitor’s sinks, and mechanical room outlets. Typically, excluded outlets are capable of being isolated by custodial staff, and will require warning signs to prohibit consumption.

## 2.0 SAMPLING PROCEDURES

---

The target water fixtures were left to stagnate for a period of 8 to 18 hours prior to the start of the sampling. The water conditions were reported to be representative of normal consumptive patterns with building occupancy controlled during stagnation and sampling periods.

In accordance with Subpart 67-4 requirements, sampling was limited to “first-draw” samples. A volume of the first 250 mL of water was taken from each cold-water fixture in the sampling inventory.

The samples were then promptly packaged and shipped to a NYS Department of Health Environmental Laboratory Approval Program (ELAP) accredited laboratory. Samples were analyzed utilizing EPA environmental analysis method 200.8 for lead in potable water. Results from the sampling rounds were then delivered to WCSD.



### 3.0 RESULTS

---

#### 3.1 Total Water Sample Summary

The following table summarizes the results from the November 7, 2025 sampling round:

Basket Road Dugouts – November 7, 2025 Water Sample Summary		
Building	Number of Total Samples	Number of Fixtures above Action Level
Basket Road Dugouts	2	1

Based on laboratory analyses of the samples collected, a total of 1 fixture was determined to exceed the Subpart 67-4 action level of 5 micrograms per liter (µg/L). A summary of this specific fixture is described below:

Basket Road Dugouts School Samples Exceeding 5 µg/L (ppb) Reporting Threshold			
Sample ID	Sample Description	Outlet Type	Result (µg/L)
BRD-01-RM-IN-DGOUTE-B	Bubbler in Eastern Dugout	Bubbler	17.8

For a full list of fixtures sampled, see Appendix A.

### 4.0 RESPONSE MEASURES

---

According to section Subpart 67-4.4 “Response” of the regulation, school districts shall prohibit the use of all fixtures which exceed the 5 ppb (µg/L) action level. These fixtures shall remain out of service until a lead remediation plan is implemented to reduce the level of lead, and resampling indicates lead levels at or below the action level. While the fixture is out of service, the district must supply an appropriate amount of potable water for drinking or cooking to building occupants.

The following measures are meant to be options for the district to consider. If a fixture is found to have exceeded the Action Level, an Immediate Response must be implemented. From there a Short-Term Control Measure may be enough to mitigate the hazard, with additional sampling conducted to confirm the measures’ effectiveness. Permanent Control Measures may be considered if the fixture continues to show elevated levels. Additional samples shall be collected after any control measure is put in place.

#### 4.1 Immediate Response

- A. Shut Off Problem Outlets – If initial sample results exceed the Action Level, the outlet can be shut off or disconnected until the problem is resolved.
- B. Post “Non-Potable Water” at Problem Outlets – If the outlet is routinely used for purposes other than human ingestion (i.e. hand washing), clear signage can be posted to notify building occupants that the outlet is not to be used for drinking or cooking. This shall remain until further sampling proves the contaminant levels are below the Action Level.

*Special Note – this signage shall also be posted on any outlet that was categorically excluded from testing and that cannot be isolated by custodial staff.*



- C. Provide Alternate Drinking Water Sources – If the removal of an outlet drastically affects the drinking or cooking water supply of occupants, the district shall supply water by other means. This shall be in the form of water bottles, water coolers, or other methods to bring in outside water.

#### **4.2 Short-Term Control Measures**

- A. Post “Non-Potable Water” at Problem Outlets – This method may be used as a continual short-term control measure. The sign may be removed only when additional sampling confirms that contaminant levels within the outlet are below the Action Level. Maintenance or custodial staff shall perform periodic inspections to ensure the signage remains in place.
- B. Provide Filters at Problem Outlets – Point-of-use (POU) units are commercially available and can be effective in removing lead contaminants. The district shall oversee the installation and routine maintenance of these outlets, as well as keep records on their location and maintenance history.

#### **4.3 Permanent Control Measures**

- A. Provide Filters at Problem Outlets – POU filters can serve as long-term or permanent control measures. The district shall create maintenance schedules, conduct follow-up water sampling, and replace the filters as needed.
- B. Replacement of Problem Outlets – This can involve the removal of the outlet as well as any upstream plumbing components (e.g. valves, leaded solder). New outlets to be installed shall be certified lead-free.
- C. Pipe Replacement – Lead pipes within school buildings and portions of lead service lines can be replaced. Contact the local Public Water System regarding jurisdiction to determine if the replacement of lead piping or service lines are under the jurisdiction of the District or other entity.

### **5.0 REPORTING AND RECORD KEEPING**

---

In accordance with Subpart 67-4 the district shall:

1. Report the test results to the local health department as soon as practicable, but no more than 1 business day after the school received the laboratory report.
2. Notify all staff and all persons in parental relation to children or students of the test results, in writing, as soon as practicable, but no more than 10 business days after the school received the laboratory report.
3. The school shall make available, on the school’s website, the results of all lead testing performed and lead remediation plans implemented pursuant to Subpart 67-4, as soon as practicable, but no more than 6 weeks after the school received the laboratory reports.
4. As soon as practicable, but no more than 10 business days after the school received the laboratory reports, the school shall report data relating to test results to the NYS Health Department, local health department, and NYS Education Department, through the NYS Health Department’s designated statewide electronic reporting system.



5. The school shall retain all records of test results, lead remediation plans, and waiver requests, for ten years following the creation of such documentation. Copies of such documentation shall be immediately provided to the NYS Health Department, local health department, or NYS Education Department, upon request.



**APPENDIX A:**  
**DETAILED RESULTS SPREADSHEET**

## Basket Road Dugouts

Identification Code	Description	Date Sampled	Time Sampled	Result ( $\mu\text{g/L}$ )
BRD-01-RM-IN-DGOUTE-B	Eastern Dugout Bubbler	11/7/2025	0656	17.8
BRD-01-RM-IN-DGOUTW-B	Western Dugout Bubbler	11/7/2025	0657	4.4



**APPENDIX B:**  
**LABORATORY ANALYTICAL**  
**REPORTS**



December 09, 2025

Service Request No:R2515007

Victoria Kaptein  
Lozier Environmental Consulting, Incorporated  
2011 East Main Street  
Rochester, NY 14609

Laboratory Results for: Webster CSD - Basket Rd Dugouts

Dear Victoria,

Enclosed are the results of the sample(s) submitted to our laboratory November 07, 2025  
For your reference, these analyses have been assigned our service request number R2515007.

All testing was performed according to our laboratory's quality assurance program and met the requirements of the TNI standards except as noted in the case narrative report. Any testing not included in the lab's accreditation is identified on a Non-Certified Analytes report. All results are intended to be considered in their entirety. ALS Environmental is not responsible for use of less than the complete report. Results apply only to the individual samples submitted to the lab for analysis, as listed in the report. The measurement uncertainty of the results included in this report is within that expected when using the prescribed method(s), and represented by Laboratory Control Sample control limits. Any events, such as QC failures or Holding Time exceedances, which may add to the uncertainty are explained in the report narrative or are flagged with qualifiers. The flags are explained in the Report Qualifiers and Definitions page of this report.

Please contact me if you have any questions. My extension is 7475. You may also contact me via email at [Meghan.Pedro@alsglobal.com](mailto:Meghan.Pedro@alsglobal.com).

Respectfully submitted,

ALS Group USA, Corp. dba ALS Environmental

Meghan Pedro  
Project Manager

ADDRESS 1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623  
PHONE +1 585 288 5380 | FAX +1 585 288 8475  
ALS Group USA, Corp.  
dba ALS Environmental



# Narrative Documents

**ALS Environmental—Rochester Laboratory**  
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623  
Phone (585) 288-5380 Fax (585) 288-8475  
[www.alsglobal.com](http://www.alsglobal.com)



**Client:** Labella Associates, PC  
**Project:** Webster CSD - Basket Rd Dugouts  
**Sample Matrix:** Drinking Water

**Service Request:** R2515007  
**Date Received:** 11/07/2025

**CASE NARRATIVE**

All analyses were performed consistent with the quality assurance program of ALS Environmental. This report contains analytical results for samples for the Tier II level requested by the client.

**Sample Receipt:**

Two drinking water samples were received for analysis at ALS Environmental on 11/07/2025. Any discrepancies upon initial sample inspection are annotated on the sample receipt and preservation form included within this report. The samples were stored at minimum in accordance with the analytical method requirements.

**Metals:**

No significant anomalies were noted with this analysis.

A handwritten signature in black ink that reads "Meghan Pedro".

Approved by \_\_\_\_\_

Date 12/08/2025



### SAMPLE DETECTION SUMMARY

This form includes only detections above the reporting levels. For a full listing of sample results, continue to the Sample Results section of this Report.

CLIENT ID: BRD-01-RM-IN-DGOUTE-B			Lab ID: R2515007-001			
----------------------------------	--	--	----------------------	--	--	--

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	17.8			1.0	ug/L	200.8

CLIENT ID: BRD-01-RM-IN-DGOUTW-B			Lab ID: R2515007-002			
----------------------------------	--	--	----------------------	--	--	--

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	4.4			1.0	ug/L	200.8



## Sample Receipt Information

**ALS Environmental—Rochester Laboratory**  
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623  
Phone (585) 288-5380 Fax (585) 288-8475  
[www.alsglobal.com](http://www.alsglobal.com)

Client: Labella Associates, PC  
Project: Webster CSD - Basket Rd Dugouts/2251107

Service Request:R2515007

SAMPLE CROSS-REFERENCE

<u>SAMPLE #</u>	<u>CLIENT SAMPLE ID</u>	<u>DATE</u>	<u>TIME</u>
R2515007-001	BRD-01-RM-IN-DGOUTE-B	11/7/2025	0656
R2515007-002	BRD-01-RM-IN-DGOUTW-B	11/7/2025	0657



ALS Environmental

Laboratory location:  
Rochester NY

# Chain of Custody Form

Page 1 of 1

Customer Information				Project Information				Parameter/Method Request for Analysis											
Purchase Order		Project Name	Webster CSD - Basket Rd Dugouts	A	EPA 200.8 Lead in Drinking Water														
Work Order		Project Number	2251107	B															
Company Name	LaBella Associates	Bill To Company	LaBella Associates	C															
Send Report To	Cory Stamp	Invoice Attn:	Cory Stamp	D															
Address	300 State Street, Suite 200	Address	300 State Street, Suite 200	E															
				F															
City/State/Zip	Rochester, NY 14614	City/State/Zip	Rochester, NY 14614	G															
Phone	(607) 591-7516	Phone	(607) 591-7516	H															
Fax		Fax		I															
e-Mail Address	cstamp@labellapc.com	e-Mail Address	cstamp@labellapc.com	J															
No.	Sample Description	Date	Time	Matrix	Pres.	# Bottles	A	B	C	D	E	F	G	H	I	J	Hold		
1	BRD-01-RM-IN-DGOUTE-B	11/07/25	6:56 AM		N/A		X												
2	BRD-01-RM-IN-DGOUTW-B	11/07/25	6:57 AM		N/A		X												
3																			
4																			
5																			
6																			
7																			
8																			
9																			
10																			
Sampler(s): Please Print & Sign <i>Cory Stamp</i>		Shipment Method: Delivered		Required Turnaround Time: <input checked="" type="checkbox"/> STD 10 Wk Days <input type="checkbox"/> 5 Wk Days <input type="checkbox"/> 2 Wk Days <input type="checkbox"/> 24 Hour				Results Due Date:											
Relinquished by: <i>Cory Stamp</i>		Date: 11/7/25	Time: 1535	Received by: <i>[Signature]</i>		Notes:													
Relinquished by:		Date:	Time:	Received by (Laboratory):		Cooler Temp.:	QC Package: (Check Box Below)												
Logged by (Laboratory):		Date:	Time:	Checked by (Laboratory):			Level II: Standard QC		TRRP-Checklist										
							Level III: Std QC + Raw Data		TRRP Level IV										
							Level IV: SW846 CLP-Like												
Preservative Key: 1-HCL 2-HNO3 3-H2SO4 4-NaOH 5-Na2S2O3 6-NaHSO4 7-Other 8-4 degrees C 9-5035						Other:													

Note: Any changes must be made in writing once samples and COC Form have been submitted to ALS Laboratory Group.  
Signature denotes acceptance of ALS Group USA, Corp. Terms and Conditions - Please click the link below for detailed Terms & Conditions:

<https://www.alsglobal.com/ALSGroupUSACorpTC>

ALS copyright © 2024. All rights reserved.

**R2515007**

**5**

Lozier Environmental Consulting, Incorporated  
Webster CSD - Basket Rd Dugouts





# Cooler Receipt and Preservation Check Form

**R2515007** 5  
 Lozier Environmental Consulting, Incorporated  
 Webster CSD - Basket Rd Dugouts

Project/Client \_\_\_\_\_ Folder Number \_\_\_\_\_

Cooler received on 11/7/25 by: \_\_\_\_\_

COURIER: ALS UPS FEDEX VELOCITY CLIENT

1	Were Custody seals on outside of cooler?	Y <u>N</u>
2	Custody papers properly completed (ink, signed)?	<u>Y</u> N
3	Did all bottles arrive in good condition (unbroken)?	<u>Y</u> N
4	Circle: Wet Ice Dry Ice Gel packs present?	Y <u>N</u>

5a	Did VOA vials have sig* bubbles?	Y N <u>NA</u>
5b	Sig* bubbles: Alk? Y N <u>NA</u> Sulfide? Y N <u>NA</u>	
6	Where did the bottles originate?	<u>ALS/ROC</u> CLIENT
7	Soil VOA received as: Bulk Encore 5035set	<u>NA</u>

8. Temperature Readings Date: 11/10/25 Time: 11:10 ID: IR#12 IR#11 From: Temp Blank Sample Bottle

Temp (°C)	<u>17.2</u>						
Within 0-6°C?	Y <u>N</u>	Y N	Y N	Y N	Y N	Y N	Y N
If <0°C, were samples frozen?	Y N	Y N	Y N	Y N	Y N	Y N	Y N

If out of Temperature, note packing/ice condition: No ice Ice melted Poorly Packed (described below) Same Day Rule  
 & Client Approval to Run Samples: \_\_\_\_\_ Standing Approval Client aware at drop-off Client notified by: \_\_\_\_\_

All samples held in storage location: SMO by RM on 11/10 at 11:12  
 5035 samples placed in storage location: \_\_\_\_\_ by \_\_\_\_\_ on \_\_\_\_\_ at \_\_\_\_\_ within 48 hours of sampling? Y N

Cooler Breakdown/Preservation Check\*\*: Date: 11/14/25 Time: 11:17 by: MM

- 9. Were all bottle labels complete (i.e. analysis, preservation, etc.)? YES NO
- 10. Did all bottle labels and tags agree with custody papers? YES NO
- 11. Were correct containers used for the tests indicated? YES NO
- 12. Were 5035 vials acceptable (no extra labels; not leaking)? YES NO N/A
- 13. Were dissolved metals filtered in the field? YES NO N/A
- 14. Air Samples: Cassettes / Tubes Intact Y/N with MS Y/N Canisters Pressurized Tedlar® Bags Inflated N/A

pH	Lot of test paper	Reagent	Preserved?		Lot Received	Exp	Sample ID Adjusted	Vol. Added	Lot Added	Final pH
			Yes	No						
≥12		NaOH								
≤2		HNO <sub>3</sub>		<input checked="" type="checkbox"/>			<u>All</u>	<u>4.0ml</u>	<u>245078</u>	<u>2.0</u>
≤2		H <sub>2</sub> SO <sub>4</sub>								
<4		NaHSO <sub>4</sub>								
5-9		For 608pest			No=Notify for 3day					
Residual Chlorine (-)		For CN, Phenol, 625, 608pest, 522			If +, contact PM to add Na <sub>2</sub> S <sub>2</sub> O <sub>3</sub> (625, 608, CN), ascorbic (phenol).					
		Na <sub>2</sub> S <sub>2</sub> O <sub>3</sub>								
		ZnAcetate	-	-						
		HCl	**	**						

\*\*VOAs and 1664 Not to be tested before analysis. Otherwise, all bottles of all samples with chemical preservatives are checked (not just representatives).

Bottle lot numbers: \_\_\_\_\_  
 Explain all Discrepancies/ Other Comments: \_\_\_\_\_

HPROD	BULK
HTR	FLDT
SUB	HGFB
ALS	LL3541

Labels secondary reviewed by: TJP \*significant air bubbles: VOA > 5-6 mm : WC > 1 in. diameter



## Miscellaneous Forms

**ALS Environmental—Rochester Laboratory**  
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623  
Phone (585) 288-5380 Fax (585) 288-8475  
[www.alsglobal.com](http://www.alsglobal.com)



## REPORT QUALIFIERS AND DEFINITIONS

- U Analyte was analyzed for but not detected. The sample quantitation limit has been corrected for dilution and for percent moisture, unless otherwise noted in the case narrative.
- J Estimated value due to either being a Tentatively Identified Compound (TIC) or that the concentration is between the MRL and the MDL. Concentrations are not verified within the linear range of the calibration. For DoD: concentration >40% difference between two GC columns (pesticides/Aroclors).
- B Analyte was also detected in the associated method blank at a concentration that may have contributed to the sample result.
- E Inorganics- Concentration is estimated due to the serial dilution was outside control limits.
- E Organics- Concentration has exceeded the calibration range for that specific analysis.
- D Concentration is a result of a dilution, typically a secondary analysis of the sample due to exceeding the calibration range or that a surrogate has been diluted out of the sample and cannot be assessed.
- \* Indicates that a quality control parameter has exceeded laboratory limits. Under the "Notes" column of the Form I, this qualifier denotes analysis was performed out of Holding Time.
- H Analysis was performed out of hold time for tests that have an "immediate" hold time criteria.
- # Spike was diluted out.
- + Correlation coefficient for MSA is <0.995.
- N Inorganics- Matrix spike recovery was outside laboratory limits.
- N Organics- Presumptive evidence of a compound (reported as a TIC) based on the MS library search.
- S Concentration has been determined using Method of Standard Additions (MSA).
- W Post-Digestion Spike recovery is outside control limits and the sample absorbance is <50% of the spike absorbance.
- P Concentration >40% difference between the two GC columns.
- C Confirmed by GC/MS
- Q DoD reports: indicates a pesticide/Aroclor is not confirmed ( $\geq 100\%$  Difference between two GC columns).
- X See Case Narrative for discussion.
- MRL Method Reporting Limit. Also known as:
- LOQ Limit of Quantitation (LOQ)  
The lowest concentration at which the method analyte may be reliably quantified under the method conditions.
- MDL Method Detection Limit. A statistical value derived from a study designed to provide the lowest concentration that will be detected 99% of the time. Values between the MDL and MRL are estimated (see J qualifier).
- LOD Limit of Detection. A value at or above the MDL which has been verified to be detectable.
- ND Non-Detect. Analyte was not detected at the concentration listed. Same as U qualifier.

### Rochester Lab ID # for State Accreditations<sup>1</sup>



NELAP States
Florida ID # E87674
New Hampshire ID # 2941
New York ID # 10145
Pennsylvania ID# 68-786
Texas ID#T104704581
Virginia #460167

Non-NELAP States
Connecticut ID #PH0556
Delaware Approved
Maine ID #NY01587
North Carolina #36701
North Carolina #676
Rhode Island LAO00333

<sup>1</sup> Analyses were performed according to our laboratory's NELAP-approved quality assurance program and any applicable state or agency requirements. The test results meet requirements of the current NELAP/TNI standards or state or agency requirements, where applicable, except as noted in the case narrative. Since not all analyte/method/matrix combinations are offered for state/NELAC accreditation, this report may contain results which are not accredited. For a specific list of accredited analytes, contact the laboratory. To verify NH accredited analytes, go to <https://www4.des.state.nh.us/CertifiedLabs/Certified-Method.aspx>.

# ALS Laboratory Group

---

## Acronyms

ASTM	American Society for Testing and Materials
A2LA	American Association for Laboratory Accreditation
CARB	California Air Resources Board
CAS Number	Chemical Abstract Service registry Number
CFC	Chlorofluorocarbon
CFU	Colony-Forming Unit
DEC	Department of Environmental Conservation
DEQ	Department of Environmental Quality
DHS	Department of Health Services
DOE	Department of Ecology
DOH	Department of Health
EPA	U. S. Environmental Protection Agency
ELAP	Environmental Laboratory Accreditation Program
GC	Gas Chromatography
GC/MS	Gas Chromatography/Mass Spectrometry
LUFT	Leaking Underground Fuel Tank
M	Modified
MCL	Maximum Contaminant Level is the highest permissible concentration of a substance allowed in drinking water as established by the USEPA.
MDL	Method Detection Limit
MPN	Most Probable Number
MRL	Method Reporting Limit
NA	Not Applicable
NC	Not Calculated
NCASI	National Council of the Paper Industry for Air and Stream Improvement
ND	Not Detected
NIOSH	National Institute for Occupational Safety and Health
PQL	Practical Quantitation Limit
RCRA	Resource Conservation and Recovery Act
SIM	Selected Ion Monitoring
TPH	Total Petroleum Hydrocarbons
tr	Trace level is the concentration of an analyte that is less than the PQL but greater than or equal to the MDL.

ALS Group USA, Corp.  
dba ALS Environmental  
Analyst Summary report

Client: Labella Associates, PC  
Project: Webster CSD - Basket Rd Dugouts/2251107

Service Request: R2515007

Sample Name: BRD-01-RM-IN-DGOUTE-B  
Lab Code: R2515007-001  
Sample Matrix: Drinking Water

Date Collected: 11/7/25  
Date Received: 11/7/25

Analysis Method  
200.8

Extracted/Digested By

Analyzed By  
MKASTAN

Sample Name: BRD-01-RM-IN-DGOUTW-B  
Lab Code: R2515007-002  
Sample Matrix: Drinking Water

Date Collected: 11/7/25  
Date Received: 11/7/25

Analysis Method  
200.8

Extracted/Digested By

Analyzed By  
MKASTAN



## PREPARATION METHODS

The preparation methods associated with this report are found in these tables unless discussed in the case narrative.

### INORGANIC

#### Water/Liquid Matrix

Analytical Method	Preparation Method
200.7 / 200.8	200.2
6010D	3005A/3010A
6020B	ILM05.3
9034 Sulfide Acid Soluble	9030B
SM 4500-CN-N-2016 Amenable and Residual Cyanide	SM 4500-CN-G and SM 4500-CN-B,C-2016
SM 4500-CN-E WAD Cyanide	SM 4500-CN-I

#### Solid/Soil/Non-Aqueous Matrix

Analytical Method	Preparation Method
6010D	3050B
6010D TCLP (1311) extract	3005A/3010A
6010D SPLP (1312) extract	3005A/3010A
7199	3060A
300.0 Anions/ 350.1/ 353.2/ SM 2320B/ SM 5210B/ 9056A Anions	DI extraction
For analytical methods not listed, the preparation method is the same as the analytical method reference.	

### ORGANIC

**Preparation Methods for Organic methods are listed in the header of the Results pages.**

#### Regarding "Bulk/5035A":

For soil/solid samples submitted in soil jars for Volatiles analysis, the prep method is listed as "Bulk/5035A". The lab follows the closed-system EPA 5035A protocols once the sample is transferred to a sealed vial, but collection in bulk in soil jars does not follow the collection protocols listed in EPA 5035A. In accordance with the NYSDOH technical notice of October 2012, all results or reporting limits <200 ug/kg are to be considered estimated due to potential low bias.



# Sample Results

**ALS Environmental—Rochester Laboratory**  
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623  
Phone (585) 288-5380 Fax (585) 288-8475  
[www.alsglobal.com](http://www.alsglobal.com)



# Metals

**ALS Environmental—Rochester Laboratory**  
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623  
Phone (585) 288-5380 Fax (585) 288-8475  
[www.alsglobal.com](http://www.alsglobal.com)

Analytical Report

Client: Labella Associates, PC  
Project: Webster CSD - Basket Rd Dugouts/2251107  
Sample Matrix: Drinking Water  
Sample Name: BRD-01-RM-IN-DGOUTE-B  
Lab Code: R2515007-001

Service Request: R2515007  
Date Collected: 11/07/25 06:56  
Date Received: 11/07/25 15:30  
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	17.8	ug/L	1.0	1	12/05/25 12:42	

Analytical Report

Client: Labella Associates, PC  
Project: Webster CSD - Basket Rd Dugouts/2251107  
Sample Matrix: Drinking Water  
Sample Name: BRD-01-RM-IN-DGOUTW-B  
Lab Code: R2515007-002

Service Request: R2515007  
Date Collected: 11/07/25 06:57  
Date Received: 11/07/25 15:30  
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	4.4	ug/L	1.0	1	12/05/25 12:44	



## QC Summary Forms

**ALS Environmental—Rochester Laboratory**  
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623  
Phone (585) 288-5380 Fax (585) 288-8475  
[www.alsglobal.com](http://www.alsglobal.com)



# Metals

**ALS Environmental—Rochester Laboratory**  
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623  
Phone (585) 288-5380 Fax (585) 288-8475  
[www.alsglobal.com](http://www.alsglobal.com)

Analytical Report

Client: Labella Associates, PC  
Project: Webster CSD - Basket Rd Dugouts/2251107  
Sample Matrix: Drinking Water  
Sample Name: Method Blank  
Lab Code: R2515007-MB

Service Request: R2515007  
Date Collected: NA  
Date Received: NA  
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	12/05/25 12:34	

Client: Labella Associates, PC  
Project: Webster CSD - Basket Rd Dugouts/2251107  
Sample Matrix: Drinking Water

Service Request: R2515007  
Date Analyzed: 12/05/25

Lab Control Sample Summary  
Inorganic Parameters

Units: ug/L  
Basis: NA

Lab Control Sample  
R2515007-LCS

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	20.3	20.0	101	85-115



**APPENDIX C:**  
**LICENSES AND CERTIFICATIONS**

# United States Environmental Protection Agency

This is to certify that

LaBella Associates, D.P.C.

has fulfilled the requirements of the Toxic Substances Control Act (TSCA) Section 402, and has received certification to conduct lead-based paint activities pursuant to 40 CFR Part 745.226

In the Jurisdiction of:

All EPA Administered Lead-based Paint Activities Program States, Tribes and Territories

This certification is valid from the date of issuance and expires September 26, 2027

LBP-2226-3

Certification #

August 01, 2024

Issued On



A handwritten signature in black ink, appearing to read "Marc Edmonds".

Marc Edmonds, Chief

Risk Assessment Management Branch 2.

# United States Environmental Protection Agency

This is to certify that



Cory J Stamp

has fulfilled the requirements of the Toxic Substances Control Act (TSCA) Section 402, and has received certification to conduct lead-based paint activities pursuant to 40 CFR Part 745.226 as:

Risk Assessor

In the Jurisdiction of:

All EPA Administered Lead-based Paint Activities Program States, Tribes and Territories

This certification is valid from the date of issuance and expires October 24, 2028

LBP-R-I206349-3

Certification #

October 15, 2025

Issued On



A handwritten signature in black ink that reads "Ben Conetta".

Ben Conetta, Manager

Chemicals and Multimedia Programs Branch

NEW YORK STATE DEPARTMENT OF HEALTH  
WADSWORTH CENTER



Expires 12:01 AM April 01, 2026  
Issued April 01, 2025

**CERTIFICATE OF APPROVAL FOR LABORATORY SERVICE**

*Issued in accordance with and pursuant to section 502 Public Health Law of New York State*

**MS. CHRISTINE KUTZER**  
**ALS ENVIRONMENTAL - ROCHESTER**  
**1565 JEFFERSON ROAD BUILDING 300, SUITE 360**  
**ROCHESTER, NY 14623**

**NY Lab Id No: 10145**

*is hereby APPROVED as an Environmental Laboratory in conformance with the  
National Environmental Laboratory Accreditation Conference Standards (2016) for the category  
ENVIRONMENTAL ANALYSES POTABLE WATER  
All approved analytes are listed below:*

**Bacteriology**

Coliform, Total / E. coli (Qualitative) SM 20, 21-23 9223B (-04) (Colilert)

**Dissolved Gases**

Acetylene RSK-175  
Ethane RSK-175  
Ethene (Ethylene) RSK-175  
Methane RSK-175  
Propane RSK-175

**Fuel Additives**

Methyl tert-butyl ether EPA 524.2  
Naphthalene EPA 524.2

**Metals I**

Arsenic, Total EPA 200.8 Rev. 5.4  
Barium, Total EPA 200.8 Rev. 5.4  
Cadmium, Total EPA 200.8 Rev. 5.4  
Chromium, Total EPA 200.7 Rev. 4.4  
Copper, Total EPA 200.8 Rev. 5.4  
Iron, Total EPA 200.7 Rev. 4.4  
Lead, Total EPA 200.8 Rev. 5.4  
Manganese, Total EPA 200.7 Rev. 4.4  
Mercury, Total EPA 245.1 Rev. 3.0  
Selenium, Total EPA 200.8 Rev. 5.4  
Silver, Total EPA 200.7 Rev. 4.4  
Zinc, Total EPA 200.7 Rev. 4.4



**Serial No.: 70111**

Property of the New York State Department of Health. Certificates are valid only at the address shown and must be conspicuously posted by the laboratory. Continued accreditation depends on the laboratory's successful ongoing participation in the Program. Consumers may verify a laboratory's accreditation status online at <https://apps.health.ny.gov/pubdoh/applinks/wc/elappublicweb/>, by phone (518) 485-5570 or by email to [elap@health.ny.gov](mailto:elap@health.ny.gov).

