

**Lead in Drinking Water Testing –
Klem Road North Elementary School
November 20, 2025**

Location:

Webster Central School District
1028 Ridge Road, Suite 12
Webster, New York 14580



LaBella Project No.

2251107

January 7, 2026



Table of Contents

1.0	BACKGROUND.....	1
2.0	SAMPLING PROCEDURES	1
3.0	RESULTS.....	2
3.1	<i>Total Water Sample Summary</i>	2
4.0	RESPONSE MEASURES	2
4.1	<i>Immediate Response</i>	2
4.2	<i>Short-Term Control Measures</i>	3
4.3	<i>Permanent Control Measures</i>	3
5.0	REPORTING AND RECORD KEEPING	3

Appendices

Appendix A – Detailed Results Spreadsheet

Appendix B – Laboratory Analytical Results

Appendix C – Licenses and Certifications



1.0 BACKGROUND

LaBella Associates, D.P.C. (LaBella) sampled potable water outlets throughout the Webster Central School District (WCSD) in accordance with Subpart 67-4 of Title 10 of the New York State Codes, Rules, and Regulations (Subpart 67-4). Under Subpart 67-4, “all school districts and boards of cooperative educational services are required to test potable water for lead contamination, and to develop and implement a lead remediation plan, where applicable.”

Lead contamination is a significant public health concern. Lead has been linked to various harmful conditions such as central nervous system and kidney damage. Children, especially those under the age of 6, are particularly susceptible to the toxic effects of lead. There is no known safe level of lead in blood, and the US Environmental Protection Agency (USEPA) has set a Maximum Contaminant Level Goal of zero. As of 2022, Subpart 67-4 establishes an action level of 5 parts per billion (ppb) in school drinking water. If test results exceed this level, the district must undertake remedial action.

The Subpart 67-4 testing requirement was first promulgated under emergency legislation in 2016, and subsequently signed into permanent law. Subsequently, Senate Bill S2122A was signed into law on December 22, 2022, changing various components of Subpart 67-4. Key revisions to the standard include a reduced action level down to 5 parts per billion (ppb), and requires that testing be performed every three years. The next round of sampling reports are due by the end of 2025. This report has been designed to fulfill the initial testing and reporting requirements outlined in Subpart 67-4.

LaBella conducted the initial water sampling on November 20, 2025 at the Klem Road North Elementary School located at 1015 Klem Road in Webster, NY. Outlets that were selected for sampling include drinking fountains, bottle fillers, kitchen sinks, classroom sinks, medical office sinks, and ice machines. Outlets categorically excluded from testing included laboratory sinks, bathroom sinks, art room sinks, single-handle faucets, showers, toilets, janitor’s sinks, and mechanical room outlets. Typically, excluded outlets are capable of being isolated by custodial staff, and will require warning signs to prohibit consumption.

2.0 SAMPLING PROCEDURES

The target water fixtures were left to stagnate for a period of 8 to 18 hours prior to the start of the sampling. The water conditions were reported to be representative of normal consumptive patterns with building occupancy controlled during stagnation and sampling periods.

In accordance with Subpart 67-4 requirements, sampling was limited to “first-draw” samples. A volume of the first 250 mL of water was taken from each cold-water fixture in the sampling inventory.

The samples were then promptly packaged and shipped to a NYS Department of Health Environmental Laboratory Approval Program (ELAP) accredited laboratory. Samples were analyzed utilizing EPA environmental analysis method 200.8 for lead in potable water. Results from the sampling rounds were then delivered to WCSD.



3.0 RESULTS

3.1 Total Water Sample Summary

The following table summarizes the results from the November 20, 2025 sampling round:

Klem Road North Elementary School – November 20, 2025 Water Sample Summary		
Building	Number of Total Samples	Number of Fixtures above Action Level
Klem Road North Elementary School	30	2

Based on laboratory analyses of the samples collected, a total of 2 fixtures were determined to exceed the Subpart 67-4 action level of 5 micrograms per liter ($\mu\text{g/L}$). A summary of these specific fixtures is described below:

Klem Road North Elementary School Samples Exceeding 5 $\mu\text{g/L}$ (ppb) Reporting Threshold			
Sample ID	Sample Description	Outlet Type	Result ($\mu\text{g/L}$)
KN-01-RM-IN-LIB-T	Library	Tap	5.6
KN-01-OFF-IN-MO-T	Main Office Kitchenette	Tap	5.3

For a full list of fixtures sampled, see Appendix A.

4.0 RESPONSE MEASURES

According to section Subpart 67-4.4 “Response” of the regulation, school districts shall prohibit the use of all fixtures which exceed the 5 ppb ($\mu\text{g/L}$) action level. These fixtures shall remain out of service until a lead remediation plan is implemented to reduce the level of lead, and resampling indicates lead levels at or below the action level. While the fixture is out of service, the district must supply an appropriate amount of potable water for drinking or cooking to building occupants.

The following measures are meant to be options for the district to consider. If a fixture is found to have exceeded the Action Level, an Immediate Response must be implemented. From there a Short-Term Control Measure may be enough to mitigate the hazard, with additional sampling conducted to confirm the measures’ effectiveness. Permanent Control Measures may be considered if the fixture continues to show elevated levels. Additional samples shall be collected after any control measure is put in place.

4.1 Immediate Response

- A. Shut Off Problem Outlets – If initial sample results exceed the Action Level, the outlet can be shut off or disconnected until the problem is resolved.
- B. Post “Non-Potable Water” at Problem Outlets – If the outlet is routinely used for purposes other than human ingestion (i.e. hand washing), clear signage can be posted to notify building occupants that the outlet is not to be used for drinking or cooking. This shall remain until further sampling proves the contaminant levels are below the Action Level.



Special Note – this signage shall also be posted on any outlet that was categorically excluded from testing and that cannot be isolated by custodial staff.

- C. Provide Alternate Drinking Water Sources – If the removal of an outlet drastically affects the drinking or cooking water supply of occupants, the district shall supply water by other means. This shall be in the form of water bottles, water coolers, or other methods to bring in outside water.

4.2 Short-Term Control Measures

- A. Post “Non-Potable Water” at Problem Outlets – This method may be used as a continual short-term control measure. The sign may be removed only when additional sampling confirms that contaminant levels within the outlet are below the Action Level. Maintenance or custodial staff shall perform periodic inspections to ensure the signage remains in place.
- B. Provide Filters at Problem Outlets – Point-of-use (POU) units are commercially available and can be effective in removing lead contaminants. The district shall oversee the installation and routine maintenance of these outlets, as well as keep records on their location and maintenance history.

4.3 Permanent Control Measures

- A. Provide Filters at Problem Outlets – POU filters can serve as long-term or permanent control measures. The district shall create maintenance schedules, conduct follow-up water sampling, and replace the filters as needed.
- B. Replacement of Problem Outlets – This can involve the removal of the outlet as well as any upstream plumbing components (e.g. valves, leaded solder). New outlets to be installed shall be certified lead-free.
- C. Pipe Replacement – Lead pipes within school buildings and portions of lead service lines can be replaced. Contact the local Public Water System regarding jurisdiction to determine if the replacement of lead piping or service lines are under the jurisdiction of the District or other entity.

5.0 REPORTING AND RECORD KEEPING

In accordance with Subpart 67-4 the district shall:

1. Report the test results to the local health department as soon as practicable, but no more than 1 business day after the school received the laboratory report.
2. Notify all staff and all persons in parental relation to children or students of the test results, in writing, as soon as practicable, but no more than 10 business days after the school received the laboratory report.
3. The school shall make available, on the school’s website, the results of all lead testing performed and lead remediation plans implemented pursuant to Subpart 67-4, as soon as practicable, but no more than 6 weeks after the school received the laboratory reports.
4. As soon as practicable, but no more than 10 business days after the school received the



laboratory reports, the school shall report data relating to test results to the NYS Health Department, local health department, and NYS Education Department, through the NYS Health Department's designated statewide electronic reporting system.

5. The school shall retain all records of test results, lead remediation plans, and waiver requests, for ten years following the creation of such documentation. Copies of such documentation shall be immediately provided to the NYS Health Department, local health department, or NYS Education Department, upon request.



APPENDIX A:
DETAILED RESULTS SPREADSHEET

Klem Road North Elementary School				
New Identification Code	Description	Date Sampled	Time Sampled	Result (µg/L)
KN-00-RM-IN-KI-T1	Kitchen Sink 1 (East Wall, Left)	11/20/2025	0603	3.2
KN-00-RM-IN-KI-T2	Kitchen Sink 2 (East Wall, Right)	11/20/2025	0604	<1.00
KN-00-RM-IN-KI-T3S	Kitchen Overhead Sprayer (On Tap 3)	11/20/2025	0605	1.9
KN-00-RM-IN-KI-PF	Kitchen Pot Filler	11/20/2025	0606	2.2
KN-00-RM-IN-CAFÉ-DF	Cafeteria Drinking Fountain	11/20/2025	0609	<1.00
KN-00-RM-IN-CAFÉ-BF	Cafeteria Bottle Filler	11/20/2025	0610	<1.00
KN-00-RM-IN-11-T	Old Art Room/Multipurpose Room Sink	11/20/2025	0611	1.4
KN-01-RM-IN-LIB-T	Library Tap	11/20/2025	0613	5.6
KN-01-RM-IN-BLR-DF	Boy's Locker Room Drinking Fountain	11/20/2025	0618	3.8
KN-01-OFF-IN-127-T	Vice Principal's Office 127 Tap	11/20/2025	0619	2.8
KN-01-RM-IN-GLR-DF	Girl's Locker Room Drinking Fountain	11/20/2025	0620	<1.00
KN-01-HA-BY-MO-DF	Hallway by Main Office Drinking Fountain	11/20/2025	0621	<1.00
KN-01-HA-BY-MO-BF	Hallway by Main Office Bottle Filler	11/20/2025	0622	<1.00
KN-01-OFF-IN-MO-T	Main Office Tap	11/20/2025	0625	5.3
KN-01-RM-IN-NO-T	Nurse's Office Tap	11/20/2025	0627	4.3
KN-01-HA-BY-108-DF	Hallway by Room 108 Drinking Fountain	11/20/2025	0630	<1.00
KN-01-HA-BY-108-BF	Hallway by Room 108 Bottle Filler	11/20/2025	0631	<1.00
KN-01-CR-IN-101-T	Classroom 101 Tap	11/20/2025	0633	1.4
KN-01-CR-IN-101-BF	Classroom 101 Bottle Filler	11/20/2025	0634	2.8
KN-01-CR-IN-102-T	Classroom 102 Tap	11/20/2025	0637	2.9
KN-01-CR-IN-102-BF	Classroom 102 Bottle Filler	11/20/2025	0638	2
KN-01-HA-BY-116-DF	Hallway by Room 116 Drinking Fountain	11/20/2025	0640	<1.00
KN-01-HA-BY-116-BF	Hallway by Room 116 Bottle Filler	11/20/2025	0641	<1.00
KN-02-RM-IN-TL-T	Teacher's Lounge Tap	11/20/2025	0645	1.7
KN-02-CR-IN-201-T	Classroom 201 Tap	11/20/2025	0646	<1.00
KN-02-CR-IN-201-B	Classroom 201 Bubbler	11/20/2025	0647	<1.00
KN-02-HA-BY-202-DF	Hallway by Room 202 Drinking Fountain	11/20/2025	0649	<1.00
KN-02-HA-BY-202-BF	Hallway by Room 202 Bottle Filler	11/20/2025	0650	<1.00
KN-02-HA-BY-212-DF	Hallway by Room 212 Drinking Fountain	11/20/2025	0651	1.3
KN-02-HA-BY-212-BF	Hallway by Room 212 Bottle Filler	11/20/2025	0652	<1.00



APPENDIX B:
LABORATORY ANALYTICAL
REPORTS



December 15, 2025

Service Request No:R2515834

Cory Stamp
Labella Associates, PC
300 State Street, 2nd Floor
Suite 201
Rochester, NY 14614

Laboratory Results for: Webster CSD - Klem North

Dear Cory,

Enclosed are the results of the sample(s) submitted to our laboratory November 21, 2025
For your reference, these analyses have been assigned our service request number R2515834.

All testing was performed according to our laboratory's quality assurance program and met the requirements of the TNI standards except as noted in the case narrative report. Any testing not included in the lab's accreditation is identified on a Non-Certified Analytes report. All results are intended to be considered in their entirety. ALS Environmental is not responsible for use of less than the complete report. Results apply only to the individual samples submitted to the lab for analysis, as listed in the report. The measurement uncertainty of the results included in this report is within that expected when using the prescribed method(s), and represented by Laboratory Control Sample control limits. Any events, such as QC failures or Holding Time exceedances, which may add to the uncertainty are explained in the report narrative or are flagged with qualifiers. The flags are explained in the Report Qualifiers and Definitions page of this report.

Please contact me if you have any questions. My extension is 7475. You may also contact me via email at Meghan.Pedro@alsglobal.com.

Respectfully submitted,

ALS Group USA, Corp. dba ALS Environmental

Meghan Pedro
Project Manager

ADDRESS 1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
PHONE +1 585 288 5380 | FAX +1 585 288 8475
ALS Group USA, Corp.
dba ALS Environmental



Narrative Documents

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



Client: Labella Associates, PC
Project: Webster CSD - Klem North
Sample Matrix: Drinking Water

Service Request: R2515834
Date Received: 11/21/2025

CASE NARRATIVE

All analyses were performed consistent with the quality assurance program of ALS Environmental. This report contains analytical results for samples for the Tier II level requested by the client.

Sample Receipt:

Thirty drinking water samples were received for analysis at ALS Environmental on 11/21/2025. Any discrepancies upon initial sample inspection are annotated on the sample receipt and preservation form included within this report. The samples were stored at minimum in accordance with the analytical method requirements.

Metals:

No significant anomalies were noted with this analysis.

A handwritten signature in black ink that reads "Meghan Pedro".

Approved by _____

Date 12/15/2025



SAMPLE DETECTION SUMMARY

This form includes only detections above the reporting levels. For a full listing of sample results, continue to the Sample Results section of this Report.

CLIENT ID: KN-00-RM-IN-KIT-T1		Lab ID: R2515834-001					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	3.2			1.0	ug/L	200.8	
CLIENT ID: KN-00-RM-IN-KIT-T3		Lab ID: R2515834-003					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	1.9			1.0	ug/L	200.8	
CLIENT ID: KN-00-RM-IN-KIT-PF		Lab ID: R2515834-004					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	2.2			1.0	ug/L	200.8	
CLIENT ID: KN-00-RM-IN-11-T		Lab ID: R2515834-007					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	1.4			1.0	ug/L	200.8	
CLIENT ID: KN-01-RM-IN-LIB-T		Lab ID: R2515834-008					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	5.6			1.0	ug/L	200.8	
CLIENT ID: KN-01-RM-IN-BLR-DF		Lab ID: R2515834-009					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	3.8			1.0	ug/L	200.8	
CLIENT ID: KN-01-OFF-IN-127-T		Lab ID: R2515834-010					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	2.8			1.0	ug/L	200.8	
CLIENT ID: KN-01-OFF-IN-MO-T		Lab ID: R2515834-014					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	5.3			1.0	ug/L	200.8	
CLIENT ID: KN-01-RM-IN-NO-T		Lab ID: R2515834-015					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	4.3			1.0	ug/L	200.8	
CLIENT ID: KN-01-CR-IN-101-T		Lab ID: R2515834-018					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	1.4			1.0	ug/L	200.8	
CLIENT ID: KN-01-CR-IN-101-BF		Lab ID: R2515834-019					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	2.8			1.0	ug/L	200.8	
CLIENT ID: KN-01-CR-IN-102-T		Lab ID: R2515834-020					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	2.9			1.0	ug/L	200.8	



SAMPLE DETECTION SUMMARY

This form includes only detections above the reporting levels. For a full listing of sample results, continue to the Sample Results section of this Report.

CLIENT ID: KN-01-CR-IN-102-BF			Lab ID: R2515834-021			
-------------------------------	--	--	----------------------	--	--	--

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	2.0			1.0	ug/L	200.8

CLIENT ID: KN-02-RM-IN-TL-T			Lab ID: R2515834-024			
-----------------------------	--	--	----------------------	--	--	--

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.7			1.0	ug/L	200.8

CLIENT ID: KN-02-HA-BY-212-DF			Lab ID: R2515834-029			
-------------------------------	--	--	----------------------	--	--	--

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.3			1.0	ug/L	200.8



Sample Receipt Information

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

Client: Labella Associates, PC
Project: Webster CSD - Klem North/2251107

Service Request:R2515834

SAMPLE CROSS-REFERENCE

<u>SAMPLE #</u>	<u>CLIENT SAMPLE ID</u>	<u>DATE</u>	<u>TIME</u>
R2515834-001	KN-00-RM-IN-KIT-T1	11/20/2025	0603
R2515834-002	KN-00-RM-IN-KIT-T2	11/20/2025	0604
R2515834-003	KN-00-RM-IN-KIT-T3	11/20/2025	0605
R2515834-004	KN-00-RM-IN-KIT-PF	11/20/2025	0606
R2515834-005	KN-00-RM-IN-CAFE-DF	11/20/2025	0609
R2515834-006	KN-00-RM-IN-CAFE-BF	11/20/2025	0610
R2515834-007	KN-00-RM-IN-11-T	11/20/2025	0611
R2515834-008	KN-01-RM-IN-LIB-T	11/20/2025	0613
R2515834-009	KN-01-RM-IN-BLR-DF	11/20/2025	0618
R2515834-010	KN-01-OFF-IN-127-T	11/20/2025	0619
R2515834-011	KN-01-RM-IN-GLR-DF	11/20/2025	0620
R2515834-012	KN-01-HA-BY-MO-DF	11/20/2025	0621
R2515834-013	KN-01-HA-BY-MO-BF	11/20/2025	0622
R2515834-014	KN-01-OFF-IN-MO-T	11/20/2025	0625
R2515834-015	KN-01-RM-IN-NO-T	11/20/2025	0627
R2515834-016	KN-01-HA-BY-108-DF	11/20/2025	0630
R2515834-017	KN-01-HA-BY-108-BF	11/20/2025	0631
R2515834-018	KN-01-CR-IN-101-T	11/20/2025	0633
R2515834-019	KN-01-CR-IN-101-BF	11/20/2025	0634
R2515834-020	KN-01-CR-IN-102-T	11/20/2025	0637
R2515834-021	KN-01-CR-IN-102-BF	11/20/2025	0638
R2515834-022	KN-01-HA-BY-116-DF	11/20/2025	0640
R2515834-023	KN-01-HA-BY-116-BF	11/20/2025	0641
R2515834-024	KN-02-RM-IN-TL-T	11/20/2025	0645
R2515834-025	KN-02-CR-IN-201-T	11/20/2025	0646
R2515834-026	KN-02-CR-IN-201-B	11/20/2025	0647
R2515834-027	KN-02-HA-BY-202-DF	11/20/2025	0649
R2515834-028	KN-02-HA-BY-202-BF	11/20/2025	0650
R2515834-029	KN-02-HA-BY-212-DF	11/20/2025	0651
R2515834-030	KN-02-HA-BY-212-BF	11/20/2025	0652



1565 Jefferson Road, Building 300, Suite 360 • Rochester, NY 14623 • +1 585 288 5380 • alsglobal.com

Chain of Custody / Analytical Request Form

084635

Cr6 7196/SM3500; BOD; CT; Cr6 7199/218.6
 353.2 NO2; OPO4; 300/9056A NO2/NO3; Sulfide
 RES Cl; DO; Ferrous Iron; Sulfite; UV 254; CHL A
 Color; Turbidity; Set Solids

Report To:		ALL SHADED AREAS MUST BE COMPLETED BY THE CLIENT / SAMPLER			Preservative		0-None, 1-HCl, 2-HNO3, 3-H2SO4, 4-NaOH, 5-ZnAc, 6-MeOH, 7-NaHSO4, 8-Other																									
Company: <i>LaBella</i>		Project Name: <i>Webster CSP - Klem North</i>			GW WW SW DW S I NA	Matrix	Number of Containers	MS/MSD?	↓ Tests / Analytes Requested ↓																							
Contact: <i>Cory Stamp</i>		Project Number: <i>2251107</i>							GC/MS VOA - 8260 • 624 • 524 • TCLP	GC/MS SVOA - 8270 • 625 • TCLP	Pesticides - 8081 • 608 • TCLP	PCBs - 8082 • 608	Herbicides - 8151 • TCLP	Metals, Total - Select Below	Metals, Dissolved - Field / In-Lab Filter																	
Email: <i>cstamp@labella.com</i>		ALS Quote #:		DOD? Y / N																												
Phone:		Sampler's Signature: <i>[Signature]</i>																														
Address:		Email CC:																														
		Email CC:																														
		State Samples Collected (Circle or Write): <i>(NY)</i> MA, PA, CT, Other:																														
Lab ID (ALS)	Sample Collection Information:			Matrix	Number of Containers	MS/MSD?	GC/MS VOA - 8260 • 624 • 524 • TCLP	GC/MS SVOA - 8270 • 625 • TCLP	Pesticides - 8081 • 608 • TCLP	PCBs - 8082 • 608	Herbicides - 8151 • TCLP	Metals, Total - Select Below	Metals, Dissolved - Field / In-Lab Filter																			
	Sample ID / Name of Collection Point:	Date	Time																													
	<i>See attached</i>																															
	<i>spreadsheet - emailed to Meghan Pedro</i>																															
Metals: RCRA 8 • PP 13 • TAL 23 • TCLP • Part 375 • Other (List)				Turnaround Requirements			Report Requirements			Invoice To: (☐ Same as Report To)																						
VOA/SVOA Report List: TCL • BTEX • TCLP • CP-51/Stars • THM • Part 375 • Other (List)				*Rush (Surcharges Apply)			Tier II/Cat A - Results/QC			PO #:																						
Special Instructions / Comments:				*Subject to Availability*			Tier IV/Cat B - Data Validation Report w/. Data			Company:																						
				Please Check with your PM			EDD: Yes No			Contact:																						
				Standard (10 Business Days)			EDD Type:			Email:																						
				TAT / Date Required:						Phone:																						
Relinquished By / Company Name		Date	Time	Received By / Company Name								Address:																				
<i>[Signature] LaBella</i>		<i>11/21/25</i>	<i>1005</i>	<i>[Signature] ALS 11/21/25 10:05</i>																												
3				4																												
5				6																												
7				8																												

R2515834 5
 Labella Associates, PC
 Webster CSP - Klem North

Sample Number	Location	Outlet Type	Detail	Date	Time
KN-00- ^{RM} IN-KIT-T1	Kitchen	Tap	East Wall (R)	11/20	0603
KN-00- ^{RM} IN-KIT-T2		Tap	" " (R)		0604
KN-00-RM-IN-KIT 35		Overhead Sprayer	O ₂ Tap 3 (S)		0605
-PF		Pot Filler			0606
-CAFE-DF	Cafeteria	DF			0609
-CAFE-BF	" "	BF			0610
-11-T	Old Art Room / Multipurpose Room 11	T			0611
-01-RM-IN-LEB-T	Library	T			0613
-BLR-DF	Boy's Locker Room (122A)	DF			0618
-01-OFF-IN-122-T	Vice Principal's Office 122	T			0619
-RM-IN-GR-DF	Girl's Locker Room	DF			0620
-HA-BY-MO-DF	Hallway by Main Office	DF			0621
-BF	" "	BF			0622
-OFF-IN-MO-T	Main Office	T			0625
-RM-IN-NO-T	Nurse's Office	T			0627
-HA-BY-108-DF	Hallway by 108	DF			0630
-BF	" "	BF			0631
-CR-IN-101-T	Classroom 101	T			0633
-BF	" "	BF			0634
-102-T	Classroom 102	T			0637
-BF	" "	BF			0638
-HA-BY-116-DF	Hallway by 116	DF			0640
-BF	" "	BF			0641
-02-RM-IN-TL-OT	Teacher's Lounge	T			0645
-CH-IN-201-T	Classroom 202	T			0646
-B		B			0647



Miscellaneous Forms

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



REPORT QUALIFIERS AND DEFINITIONS

- U Analyte was analyzed for but not detected. The sample quantitation limit has been corrected for dilution and for percent moisture, unless otherwise noted in the case narrative.
- J Estimated value due to either being a Tentatively Identified Compound (TIC) or that the concentration is between the MRL and the MDL. Concentrations are not verified within the linear range of the calibration. For DoD: concentration >40% difference between two GC columns (pesticides/Aroclors).
- B Analyte was also detected in the associated method blank at a concentration that may have contributed to the sample result.
- E Inorganics- Concentration is estimated due to the serial dilution was outside control limits.
- E Organics- Concentration has exceeded the calibration range for that specific analysis.
- D Concentration is a result of a dilution, typically a secondary analysis of the sample due to exceeding the calibration range or that a surrogate has been diluted out of the sample and cannot be assessed.
- * Indicates that a quality control parameter has exceeded laboratory limits. Under the "Notes" column of the Form I, this qualifier denotes analysis was performed out of Holding Time.
- H Analysis was performed out of hold time for tests that have an "immediate" hold time criteria.
- # Spike was diluted out.
- + Correlation coefficient for MSA is <0.995.
- N Inorganics- Matrix spike recovery was outside laboratory limits.
- N Organics- Presumptive evidence of a compound (reported as a TIC) based on the MS library search.
- S Concentration has been determined using Method of Standard Additions (MSA).
- W Post-Digestion Spike recovery is outside control limits and the sample absorbance is <50% of the spike absorbance.
- P Concentration >40% difference between the two GC columns.
- C Confirmed by GC/MS
- Q DoD reports: indicates a pesticide/Aroclor is not confirmed ($\geq 100\%$ Difference between two GC columns).
- X See Case Narrative for discussion.
- MRL Method Reporting Limit. Also known as:
- LOQ Limit of Quantitation (LOQ)
The lowest concentration at which the method analyte may be reliably quantified under the method conditions.
- MDL Method Detection Limit. A statistical value derived from a study designed to provide the lowest concentration that will be detected 99% of the time. Values between the MDL and MRL are estimated (see J qualifier).
- LOD Limit of Detection. A value at or above the MDL which has been verified to be detectable.
- ND Non-Detect. Analyte was not detected at the concentration listed. Same as U qualifier.

Rochester Lab ID # for State Accreditations¹



NELAP States
Florida ID # E87674
New Hampshire ID # 2941
New York ID # 10145
Pennsylvania ID# 68-786
Texas ID#T104704581
Virginia #460167

Non-NELAP States
Connecticut ID #PH0556
Delaware Approved
Maine ID #NY01587
North Carolina #36701
North Carolina #676
Rhode Island LAO00333

¹ Analyses were performed according to our laboratory's NELAP-approved quality assurance program and any applicable state or agency requirements. The test results meet requirements of the current NELAP/TNI standards or state or agency requirements, where applicable, except as noted in the case narrative. Since not all analyte/method/matrix combinations are offered for state/NELAC accreditation, this report may contain results which are not accredited. For a specific list of accredited analytes, contact the laboratory. To verify NH accredited analytes, go to <https://www4.des.state.nh.us/CertifiedLabs/Certified-Method.aspx>.

ALS Laboratory Group

Acronyms

ASTM	American Society for Testing and Materials
A2LA	American Association for Laboratory Accreditation
CARB	California Air Resources Board
CAS Number	Chemical Abstract Service registry Number
CFC	Chlorofluorocarbon
CFU	Colony-Forming Unit
DEC	Department of Environmental Conservation
DEQ	Department of Environmental Quality
DHS	Department of Health Services
DOE	Department of Ecology
DOH	Department of Health
EPA	U. S. Environmental Protection Agency
ELAP	Environmental Laboratory Accreditation Program
GC	Gas Chromatography
GC/MS	Gas Chromatography/Mass Spectrometry
LUFT	Leaking Underground Fuel Tank
M	Modified
MCL	Maximum Contaminant Level is the highest permissible concentration of a substance allowed in drinking water as established by the USEPA.
MDL	Method Detection Limit
MPN	Most Probable Number
MRL	Method Reporting Limit
NA	Not Applicable
NC	Not Calculated
NCASI	National Council of the Paper Industry for Air and Stream Improvement
ND	Not Detected
NIOSH	National Institute for Occupational Safety and Health
PQL	Practical Quantitation Limit
RCRA	Resource Conservation and Recovery Act
SIM	Selected Ion Monitoring
TPH	Total Petroleum Hydrocarbons
tr	Trace level is the concentration of an analyte that is less than the PQL but greater than or equal to the MDL.

ALS Group USA, Corp.
dba ALS Environmental
Analyst Summary report

Client: Labella Associates, PC
Project: Webster CSD - Klem North/2251107

Service Request: R2515834

Sample Name: KN-00-RM-IN-KIT-T1
Lab Code: R2515834-001
Sample Matrix: Drinking Water

Date Collected: 11/20/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: KN-00-RM-IN-KIT-T2
Lab Code: R2515834-002
Sample Matrix: Drinking Water

Date Collected: 11/20/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: KN-00-RM-IN-KIT-T3
Lab Code: R2515834-003
Sample Matrix: Drinking Water

Date Collected: 11/20/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: KN-00-RM-IN-KIT-PF
Lab Code: R2515834-004
Sample Matrix: Drinking Water

Date Collected: 11/20/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: KN-00-RM-IN-CAFE-DF
Lab Code: R2515834-005
Sample Matrix: Drinking Water

Date Collected: 11/20/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

ALS Group USA, Corp.
dba ALS Environmental
Analyst Summary report

Client: Labella Associates, PC
Project: Webster CSD - Klem North/2251107

Service Request: R2515834

Sample Name: KN-00-RM-IN-CAFE-BF
Lab Code: R2515834-006
Sample Matrix: Drinking Water

Date Collected: 11/20/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: KN-00-RM-IN-11-T
Lab Code: R2515834-007
Sample Matrix: Drinking Water

Date Collected: 11/20/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: KN-01-RM-IN-LIB-T
Lab Code: R2515834-008
Sample Matrix: Drinking Water

Date Collected: 11/20/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: KN-01-RM-IN-BLR-DF
Lab Code: R2515834-009
Sample Matrix: Drinking Water

Date Collected: 11/20/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: KN-01-OFF-IN-127-T
Lab Code: R2515834-010
Sample Matrix: Drinking Water

Date Collected: 11/20/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

ALS Group USA, Corp.
dba ALS Environmental
Analyst Summary report

Client: Labella Associates, PC
Project: Webster CSD - Klem North/2251107

Service Request: R2515834

Sample Name: KN-01-RM-IN-GLR-DF
Lab Code: R2515834-011
Sample Matrix: Drinking Water

Date Collected: 11/20/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: KN-01-HA-BY-MO-DF
Lab Code: R2515834-012
Sample Matrix: Drinking Water

Date Collected: 11/20/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: KN-01-HA-BY-MO-BF
Lab Code: R2515834-013
Sample Matrix: Drinking Water

Date Collected: 11/20/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: KN-01-OFF-IN-MO-T
Lab Code: R2515834-014
Sample Matrix: Drinking Water

Date Collected: 11/20/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: KN-01-RM-IN-NO-T
Lab Code: R2515834-015
Sample Matrix: Drinking Water

Date Collected: 11/20/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

ALS Group USA, Corp.
dba ALS Environmental
Analyst Summary report

Client: Labella Associates, PC
Project: Webster CSD - Klem North/2251107

Service Request: R2515834

Sample Name: KN-01-HA-BY-108-DF
Lab Code: R2515834-016
Sample Matrix: Drinking Water

Date Collected: 11/20/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: KN-01-HA-BY-108-BF
Lab Code: R2515834-017
Sample Matrix: Drinking Water

Date Collected: 11/20/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: KN-01-CR-IN-101-T
Lab Code: R2515834-018
Sample Matrix: Drinking Water

Date Collected: 11/20/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: KN-01-CR-IN-101-BF
Lab Code: R2515834-019
Sample Matrix: Drinking Water

Date Collected: 11/20/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: KN-01-CR-IN-102-T
Lab Code: R2515834-020
Sample Matrix: Drinking Water

Date Collected: 11/20/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

ALS Group USA, Corp.
dba ALS Environmental
Analyst Summary report

Client: Labella Associates, PC
Project: Webster CSD - Klem North/2251107

Service Request: R2515834

Sample Name: KN-01-CR-IN-102-BF
Lab Code: R2515834-021
Sample Matrix: Drinking Water

Date Collected: 11/20/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: KN-01-HA-BY-116-DF
Lab Code: R2515834-022
Sample Matrix: Drinking Water

Date Collected: 11/20/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: KN-01-HA-BY-116-BF
Lab Code: R2515834-023
Sample Matrix: Drinking Water

Date Collected: 11/20/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: KN-02-RM-IN-TL-T
Lab Code: R2515834-024
Sample Matrix: Drinking Water

Date Collected: 11/20/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: KN-02-CR-IN-201-T
Lab Code: R2515834-025
Sample Matrix: Drinking Water

Date Collected: 11/20/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

ALS Group USA, Corp.
dba ALS Environmental
Analyst Summary report

Client: Labella Associates, PC
Project: Webster CSD - Klem North/2251107

Service Request: R2515834

Sample Name: KN-02-CR-IN-201-B
Lab Code: R2515834-026
Sample Matrix: Drinking Water

Date Collected: 11/20/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: KN-02-HA-BY-202-DF
Lab Code: R2515834-027
Sample Matrix: Drinking Water

Date Collected: 11/20/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: KN-02-HA-BY-202-BF
Lab Code: R2515834-028
Sample Matrix: Drinking Water

Date Collected: 11/20/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: KN-02-HA-BY-212-DF
Lab Code: R2515834-029
Sample Matrix: Drinking Water

Date Collected: 11/20/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: KN-02-HA-BY-212-BF
Lab Code: R2515834-030
Sample Matrix: Drinking Water

Date Collected: 11/20/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER



PREPARATION METHODS

The preparation methods associated with this report are found in these tables unless discussed in the case narrative.

INORGANIC

Water/Liquid Matrix

Analytical Method	Preparation Method
200.7 / 200.8	200.2
6010D	3005A/3010A
6020B	ILM05.3
9034 Sulfide Acid Soluble	9030B
SM 4500-CN-N-2016 Amenable and Residual Cyanide	SM 4500-CN-G and SM 4500-CN-B,C-2016
SM 4500-CN-E WAD Cyanide	SM 4500-CN-I

Solid/Soil/Non-Aqueous Matrix

Analytical Method	Preparation Method
6010D	3050B
6010D TCLP (1311) extract	3005A/3010A
6010D SPLP (1312) extract	3005A/3010A
7199	3060A
300.0 Anions/ 350.1/ 353.2/ SM 2320B/ SM 5210B/ 9056A Anions	DI extraction
For analytical methods not listed, the preparation method is the same as the analytical method reference.	

ORGANIC

Preparation Methods for Organic methods are listed in the header of the Results pages.

Regarding "Bulk/5035A":

For soil/solid samples submitted in soil jars for Volatiles analysis, the prep method is listed as "Bulk/5035A". The lab follows the closed-system EPA 5035A protocols once the sample is transferred to a sealed vial, but collection in bulk in soil jars does not follow the collection protocols listed in EPA 5035A. In accordance with the NYSDOH technical notice of October 2012, all results or reporting limits <200 ug/kg are to be considered estimated due to potential low bias.



Sample Results

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



Metals

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Klem North/2251107
Sample Matrix: Drinking Water
Sample Name: KN-00-RM-IN-KIT-T1
Lab Code: R2515834-001

Service Request: R2515834
Date Collected: 11/20/25 06:03
Date Received: 11/21/25 10:05
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	3.2	ug/L	1.0	1	12/11/25 18:00	

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Klem North/2251107
Sample Matrix: Drinking Water
Sample Name: KN-00-RM-IN-KIT-T2
Lab Code: R2515834-002

Service Request: R2515834
Date Collected: 11/20/25 06:04
Date Received: 11/21/25 10:05
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	12/11/25 18:01	

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Klem North/2251107
Sample Matrix: Drinking Water
Sample Name: KN-00-RM-IN-KIT-T3
Lab Code: R2515834-003

Service Request: R2515834
Date Collected: 11/20/25 06:05
Date Received: 11/21/25 10:05
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.9	ug/L	1.0	1	12/11/25 18:02	

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Klem North/2251107
Sample Matrix: Drinking Water
Sample Name: KN-00-RM-IN-KIT-PF
Lab Code: R2515834-004

Service Request: R2515834
Date Collected: 11/20/25 06:06
Date Received: 11/21/25 10:05
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	2.2	ug/L	1.0	1	12/11/25 18:12	

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Klem North/2251107
Sample Matrix: Drinking Water
Sample Name: KN-00-RM-IN-CAFE-DF
Lab Code: R2515834-005

Service Request: R2515834
Date Collected: 11/20/25 06:09
Date Received: 11/21/25 10:05
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	12/11/25 18:16	

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Klem North/2251107
Sample Matrix: Drinking Water
Sample Name: KN-00-RM-IN-CAFE-BF
Lab Code: R2515834-006

Service Request: R2515834
Date Collected: 11/20/25 06:10
Date Received: 11/21/25 10:05
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	12/11/25 18:18	

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Klem North/2251107
Sample Matrix: Drinking Water
Sample Name: KN-00-RM-IN-11-T
Lab Code: R2515834-007

Service Request: R2515834
Date Collected: 11/20/25 06:11
Date Received: 11/21/25 10:05
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.4	ug/L	1.0	1	12/11/25 18:19	

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Klem North/2251107
Sample Matrix: Drinking Water
Sample Name: KN-01-RM-IN-LIB-T
Lab Code: R2515834-008

Service Request: R2515834
Date Collected: 11/20/25 06:13
Date Received: 11/21/25 10:05
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	5.6	ug/L	1.0	1	12/11/25 18:20	

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Klem North/2251107
Sample Matrix: Drinking Water
Sample Name: KN-01-RM-IN-BLR-DF
Lab Code: R2515834-009

Service Request: R2515834
Date Collected: 11/20/25 06:18
Date Received: 11/21/25 10:05
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	3.8	ug/L	1.0	1	12/11/25 18:22	

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Klem North/2251107
Sample Matrix: Drinking Water
Sample Name: KN-01-OFF-IN-127-T
Lab Code: R2515834-010

Service Request: R2515834
Date Collected: 11/20/25 06:19
Date Received: 11/21/25 10:05
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	2.8	ug/L	1.0	1	12/11/25 18:26	

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Klem North/2251107
Sample Matrix: Drinking Water
Sample Name: KN-01-RM-IN-GLR-DF
Lab Code: R2515834-011

Service Request: R2515834
Date Collected: 11/20/25 06:20
Date Received: 11/21/25 10:05
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	12/11/25 18:27	

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Klem North/2251107
Sample Matrix: Drinking Water
Sample Name: KN-01-HA-BY -MO-DF
Lab Code: R2515834-012

Service Request: R2515834
Date Collected: 11/20/25 06:21
Date Received: 11/21/25 10:05
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	12/11/25 18:29	

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Klem North/2251107
Sample Matrix: Drinking Water
Sample Name: KN-01-HA-BY -MO-BF
Lab Code: R2515834-013

Service Request: R2515834
Date Collected: 11/20/25 06:22
Date Received: 11/21/25 10:05
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	12/11/25 18:30	

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Klem North/2251107
Sample Matrix: Drinking Water
Sample Name: KN-01-OFF-IN-MO-T
Lab Code: R2515834-014

Service Request: R2515834
Date Collected: 11/20/25 06:25
Date Received: 11/21/25 10:05
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	5.3	ug/L	1.0	1	12/11/25 18:31	

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Klem North/2251107
Sample Matrix: Drinking Water
Sample Name: KN-01-RM-IN-NO-T
Lab Code: R2515834-015

Service Request: R2515834
Date Collected: 11/20/25 06:27
Date Received: 11/21/25 10:05
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	4.3	ug/L	1.0	1	12/11/25 18:33	

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Klem North/2251107
Sample Matrix: Drinking Water
Sample Name: KN-01-HA-BY -108-DF
Lab Code: R2515834-016

Service Request: R2515834
Date Collected: 11/20/25 06:30
Date Received: 11/21/25 10:05
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	12/11/25 18:34	

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Klem North/2251107
Sample Matrix: Drinking Water
Sample Name: KN-01-HA-BY -108-BF
Lab Code: R2515834-017

Service Request: R2515834
Date Collected: 11/20/25 06:31
Date Received: 11/21/25 10:05
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	12/11/25 18:36	

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Klem North/2251107
Sample Matrix: Drinking Water
Sample Name: KN-01-CR-IN-101-T
Lab Code: R2515834-018

Service Request: R2515834
Date Collected: 11/20/25 06:33
Date Received: 11/21/25 10:05
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.4	ug/L	1.0	1	12/11/25 18:37	

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Klem North/2251107
Sample Matrix: Drinking Water
Sample Name: KN-01-CR-IN-101-BF
Lab Code: R2515834-019

Service Request: R2515834
Date Collected: 11/20/25 06:34
Date Received: 11/21/25 10:05
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	2.8	ug/L	1.0	1	12/11/25 18:38	

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Klem North/2251107
Sample Matrix: Drinking Water
Sample Name: KN-01-CR-IN-102-T
Lab Code: R2515834-020

Service Request: R2515834
Date Collected: 11/20/25 06:37
Date Received: 11/21/25 10:05
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	2.9	ug/L	1.0	1	12/11/25 18:42	

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Klem North/2251107
Sample Matrix: Drinking Water
Sample Name: KN-01-CR-IN-102-BF
Lab Code: R2515834-021

Service Request: R2515834
Date Collected: 11/20/25 06:38
Date Received: 11/21/25 10:05
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	2.0	ug/L	1.0	1	12/11/25 18:44	

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Klem North/2251107
Sample Matrix: Drinking Water
Sample Name: KN-01-HA-BY -116-DF
Lab Code: R2515834-022

Service Request: R2515834
Date Collected: 11/20/25 06:40
Date Received: 11/21/25 10:05
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	12/11/25 18:45	

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Klem North/2251107
Sample Matrix: Drinking Water
Sample Name: KN-01-HA-BY -116-BF
Lab Code: R2515834-023

Service Request: R2515834
Date Collected: 11/20/25 06:41
Date Received: 11/21/25 10:05
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	12/11/25 18:47	

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Klem North/2251107
Sample Matrix: Drinking Water
Sample Name: KN-02-RM-IN-TL-T
Lab Code: R2515834-024

Service Request: R2515834
Date Collected: 11/20/25 06:45
Date Received: 11/21/25 10:05
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.7	ug/L	1.0	1	12/11/25 18:56	

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Klem North/2251107
Sample Matrix: Drinking Water
Sample Name: KN-02-CR-IN-201-T
Lab Code: R2515834-025

Service Request: R2515834
Date Collected: 11/20/25 06:46
Date Received: 11/21/25 10:05
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	12/11/25 19:00	

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Klem North/2251107
Sample Matrix: Drinking Water
Sample Name: KN-02-CR-IN-201-B
Lab Code: R2515834-026

Service Request: R2515834
Date Collected: 11/20/25 06:47
Date Received: 11/21/25 10:05
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	12/11/25 19:02	

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Klem North/2251107
Sample Matrix: Drinking Water
Sample Name: KN-02-HA-BY -202-DF
Lab Code: R2515834-027

Service Request: R2515834
Date Collected: 11/20/25 06:49
Date Received: 11/21/25 10:05
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	12/11/25 19:03	

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Klem North/2251107
Sample Matrix: Drinking Water
Sample Name: KN-02-HA-BY -202-BF
Lab Code: R2515834-028

Service Request: R2515834
Date Collected: 11/20/25 06:50
Date Received: 11/21/25 10:05
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	12/11/25 19:04	

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Klem North/2251107
Sample Matrix: Drinking Water
Sample Name: KN-02-HA-BY -212-DF
Lab Code: R2515834-029

Service Request: R2515834
Date Collected: 11/20/25 06:51
Date Received: 11/21/25 10:05
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.3	ug/L	1.0	1	12/11/25 19:06	

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Klem North/2251107
Sample Matrix: Drinking Water
Sample Name: KN-02-HA-BY -212-BF
Lab Code: R2515834-030

Service Request: R2515834
Date Collected: 11/20/25 06:52
Date Received: 11/21/25 10:05
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	12/11/25 19:10	



QC Summary Forms

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



Metals

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Klem North/2251107
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2515834-MB1

Service Request: R2515834
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	12/11/25 17:25	

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Klem North/2251107
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2515834-MB2

Service Request: R2515834
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	12/11/25 18:09	

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Klem North/2251107
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2515834-MB3

Service Request: R2515834
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	12/11/25 18:53	

QA/QC Report

Client: Labella Associates, PC
Project: Webster CSD - Klem North/2251107
Sample Matrix: Drinking Water

Service Request: R2515834
Date Collected: 11/20/25
Date Received: 11/21/25
Date Analyzed: 12/11/25

Duplicate Matrix Spike Summary
Inorganic Parameters

Sample Name: KN-00-RM-IN-KIT-T3
Lab Code: R2515834-003
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike R2515834-003MS		Result	Duplicate Matrix Spike R2515834-003DMS		% Rec Limits	RPD	RPD Limit
			Spike Amount	% Rec		Spike Amount	% Rec			
Lead, Total	1.9	22.2	20.0	101	22.4	20.0	102	70-130	<1	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

QA/QC Report

Client: Labella Associates, PC
Project: Webster CSD - Klem North/2251107
Sample Matrix: Drinking Water

Service Request: R2515834
Date Collected: 11/20/25
Date Received: 11/21/25
Date Analyzed: 12/11/25

Duplicate Matrix Spike Summary
Inorganic Parameters

Sample Name: KN-00-RM-IN-KIT-PF
Lab Code: R2515834-004
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike R2515834-004MS		Result	Duplicate Matrix Spike R2515834-004DMS		% Rec Limits	RPD	RPD Limit
			Spike Amount	% Rec		Spike Amount	% Rec			
Lead, Total	2.2	21.8	20.0	98	21.9	20.0	99	70-130	<1	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

QA/QC Report

Client: Labella Associates, PC
Project: Webster CSD - Klem North/2251107
Sample Matrix: Drinking Water

Service Request: R2515834
Date Collected: 11/20/25
Date Received: 11/21/25
Date Analyzed: 12/11/25

Duplicate Matrix Spike Summary
Inorganic Parameters

Sample Name: KN-01-HA-BY-116-BF
Lab Code: R2515834-023
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike R2515834-023MS		Result	Duplicate Matrix Spike R2515834-023DMS		% Rec Limits	RPD	RPD Limit
			Spike Amount	% Rec		Spike Amount	% Rec			
Lead, Total	1.0 U	20.3	20.0	101	20.3	20.0	101	70-130	<1	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

QA/QC Report

Client: Labella Associates, PC
Project: Webster CSD - Klem North/2251107
Sample Matrix: Drinking Water

Service Request: R2515834
Date Collected: 11/20/25
Date Received: 11/21/25
Date Analyzed: 12/11/25

Duplicate Matrix Spike Summary
Inorganic Parameters

Sample Name: KN-02-RM-IN-TL-T
Lab Code: R2515834-024
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike R2515834-024MS		Result	Duplicate Matrix Spike R2515834-024DMS		% Rec Limits	RPD	RPD Limit
			Spike Amount	% Rec		Spike Amount	% Rec			
Lead, Total	1.7	22.7	20.0	105	22.1	20.0	102	70-130	3	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

Client: Labella Associates, PC
Project: Webster CSD - Klem North/2251107
Sample Matrix: Drinking Water

Service Request: R2515834

Date Analyzed: 12/11/25

Lab Control Sample Summary
Inorganic Parameters

Units: ug/L

Basis: NA

Lab Control Sample
R2515834-LCS1

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	21.4	20.0	107	85-115

Client: Labella Associates, PC
Project: Webster CSD - Klem North/2251107
Sample Matrix: Drinking Water

Service Request: R2515834
Date Analyzed: 12/11/25

Lab Control Sample Summary
Inorganic Parameters

Units: ug/L
Basis: NA

Lab Control Sample
R2515834-LCS2

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	20.6	20.0	103	85-115

Client: Labella Associates, PC
Project: Webster CSD - Klem North/2251107
Sample Matrix: Drinking Water

Service Request: R2515834
Date Analyzed: 12/11/25

Lab Control Sample Summary
Inorganic Parameters

Units: ug/L
Basis: NA

Lab Control Sample
R2515834-LCS3

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	20.7	20.0	104	85-115



APPENDIX C:
LICENSES AND CERTIFICATIONS

United States Environmental Protection Agency

This is to certify that

LaBella Associates, D.P.C.

has fulfilled the requirements of the Toxic Substances Control Act (TSCA) Section 402, and has received certification to conduct lead-based paint activities pursuant to 40 CFR Part 745.226

In the Jurisdiction of:

All EPA Administered Lead-based Paint Activities Program States, Tribes and Territories

This certification is valid from the date of issuance and expires September 26, 2027

LBP-2226-3

Certification #

August 01, 2024

Issued On



A handwritten signature in black ink, appearing to read "Marc Edmonds".

Marc Edmonds, Chief

Risk Assessment Management Branch 2.

United States Environmental Protection Agency

This is to certify that



Cory J Stamp

has fulfilled the requirements of the Toxic Substances Control Act (TSCA) Section 402, and has received certification to conduct lead-based paint activities pursuant to 40 CFR Part 745.226 as:

Risk Assessor

In the Jurisdiction of:

All EPA Administered Lead-based Paint Activities Program States, Tribes and Territories

This certification is valid from the date of issuance and expires October 24, 2028

LBP-R-I206349-3

Certification #

October 15, 2025

Issued On



A handwritten signature in black ink that reads "Ben Conetta".

Ben Conetta, Manager

Chemicals and Multimedia Programs Branch

NEW YORK STATE DEPARTMENT OF HEALTH
WADSWORTH CENTER



Expires 12:01 AM April 01, 2026
Issued April 01, 2025

CERTIFICATE OF APPROVAL FOR LABORATORY SERVICE

Issued in accordance with and pursuant to section 502 Public Health Law of New York State

MS. CHRISTINE KUTZER
ALS ENVIRONMENTAL - ROCHESTER
1565 JEFFERSON ROAD BUILDING 300, SUITE 360
ROCHESTER, NY 14623

NY Lab Id No: 10145

*is hereby APPROVED as an Environmental Laboratory in conformance with the
National Environmental Laboratory Accreditation Conference Standards (2016) for the category
ENVIRONMENTAL ANALYSES POTABLE WATER
All approved analytes are listed below:*

Bacteriology

Coliform, Total / E. coli (Qualitative) SM 20, 21-23 9223B (-04) (Colilert)

Dissolved Gases

Acetylene RSK-175
Ethane RSK-175
Ethene (Ethylene) RSK-175
Methane RSK-175
Propane RSK-175

Fuel Additives

Methyl tert-butyl ether EPA 524.2
Naphthalene EPA 524.2

Metals I

Arsenic, Total EPA 200.8 Rev. 5.4
Barium, Total EPA 200.8 Rev. 5.4
Cadmium, Total EPA 200.8 Rev. 5.4
Chromium, Total EPA 200.7 Rev. 4.4
Copper, Total EPA 200.8 Rev. 5.4
Iron, Total EPA 200.7 Rev. 4.4
Lead, Total EPA 200.8 Rev. 5.4
Manganese, Total EPA 200.7 Rev. 4.4
Mercury, Total EPA 245.1 Rev. 3.0
Selenium, Total EPA 200.8 Rev. 5.4
Silver, Total EPA 200.7 Rev. 4.4
Zinc, Total EPA 200.7 Rev. 4.4



Serial No.: 70111

Property of the New York State Department of Health. Certificates are valid only at the address shown and must be conspicuously posted by the laboratory. Continued accreditation depends on the laboratory's successful ongoing participation in the Program. Consumers may verify a laboratory's accreditation status online at <https://apps.health.ny.gov/pubdoh/applinks/wc/elappublicweb/>, by phone (518) 485-5570 or by email to elap@health.ny.gov.

