

Lead in Drinking Water Testing – Webster Schroeder High School

Location:

Webster Central School District
1028 Ridge Road, Suite 12
Webster, New York 14580



LaBella Project No.

2251107

January 13, 2026



Table of Contents

1.0	BACKGROUND	1
2.0	SAMPLING PROCEDURES	1
3.0	RESULTS	2
3.1	<i>Total Water Sample Summary</i>	2
4.0	RESPONSE MEASURES	2
4.1	<i>Immediate Response</i>	2
4.2	<i>Short-Term Control Measures</i>	3
4.3	<i>Permanent Control Measures</i>	3
5.0	REPORTING AND RECORD KEEPING	3

Appendices

Appendix A – Detailed Results Spreadsheet

Appendix B – Laboratory Analytical Results

Appendix C – Licenses and Certifications



1.0 BACKGROUND

LaBella Associates, D.P.C. (LaBella) sampled potable water outlets throughout the Webster Central School District (WCSD) in accordance with Subpart 67-4 of Title 10 of the New York State Codes, Rules, and Regulations (Subpart 67-4). Under Subpart 67-4, “all school districts and boards of cooperative educational services are required to test potable water for lead contamination, and to develop and implement a lead remediation plan, where applicable.”

Lead contamination is a significant public health concern. Lead has been linked to various harmful conditions such as central nervous system and kidney damage. Children, especially those under the age of 6, are particularly susceptible to the toxic effects of lead. There is no known safe level of lead in blood, and the US Environmental Protection Agency (USEPA) has set a Maximum Contaminant Level Goal of zero. As of 2022, Subpart 67-4 establishes an action level of 5 parts per billion (ppb) in school drinking water. If test results exceed this level, the district must undertake remedial action.

The Subpart 67-4 testing requirement was first promulgated under emergency legislation in 2016, and subsequently signed into permanent law. Subsequently, Senate Bill S2122A was signed into law on December 22, 2022, changing various components of Subpart 67-4. Key revisions to the standard include a reduced action level down to 5 parts per billion (ppb), and requires that testing be performed every three years. The next round of sampling reports are due by the end of 2025. This report has been designed to fulfill the initial testing and reporting requirements outlined in Subpart 67-4.

LaBella conducted the initial water sampling at the Webster Schroeder High School located at 875 Ridge Road in Webster, NY in three separate sampling events. The first sampling round was conducted on November 7, 2025, in order to sample exterior outlets prior to them being shut down for the winter. The second round of sampling on December 11, 2025, consisted of the sampling of applicable outlets within the school. Additional outlets were sampled during the third and final initial sampling round on December 18, 2025.

Outlets that were selected for sampling include drinking fountains, bottle fillers, kitchen sinks, classroom sinks, medical office sinks, and ice machines. Outlets categorically excluded from testing included laboratory sinks, bathroom sinks, art room sinks, single-handle faucets, showers, toilets, janitor’s sinks, and mechanical room outlets. Typically, excluded outlets are capable of being isolated by custodial staff, and will require warning signs to prohibit consumption.

2.0 SAMPLING PROCEDURES

The target water fixtures were left to stagnate for a period of 8 to 18 hours prior to the start of the sampling. The water conditions were reported to be representative of normal consumptive patterns with building occupancy controlled during stagnation and sampling periods.

In accordance with Subpart 67-4 requirements, sampling was limited to “first-draw” samples. A volume of the first 250 mL of water was taken from each cold-water fixture in the sampling inventory.

The samples were then promptly packaged and shipped to a NYS Department of Health Environmental Laboratory Approval Program (ELAP) accredited laboratory. Samples were analyzed utilizing EPA environmental analysis method 200.8 for lead in potable water. Results from the sampling rounds were then delivered to WCSD.



3.0 RESULTS

3.1 Total Water Sample Summary

The following table summarizes the results from the sampling rounds:

Webster Schroeder High School – Water Sample Summary		
Building	Number of Total Samples	Number of Fixtures above Action Level
Webster Schroeder High School	76	2

Based on laboratory analyses of the samples collected, a total of 2 fixtures were determined to exceed the Subpart 67-4 action level of 5 micrograms per liter ($\mu\text{g/L}$). A summary of these specific fixtures is described below:

Webster Schroeder High School Samples Exceeding 5 $\mu\text{g/L}$ (ppb) Reporting Threshold			
Sample ID	Sample Description	Outlet Type	Result ($\mu\text{g/L}$)
SHS-01-KIT-IN-58-T1	Western Kitchen 58	Tap 1	22.7
SHS-02-RM-IN-W228-T*	Room W228	Tap	7.2

*This sample was mislabeled as SHS-02-RM-IN-W28-T on the laboratory analytical results.

For a full list of fixtures sampled, see Appendix A.

4.0 RESPONSE MEASURES

According to section Subpart 67-4.4 “Response” of the regulation, school districts shall prohibit the use of all fixtures which exceed the 5 ppb ($\mu\text{g/L}$) action level. These fixtures shall remain out of service until a lead remediation plan is implemented to reduce the level of lead, and resampling indicates lead levels at or below the action level. While the fixture is out of service, the district must supply an appropriate amount of potable water for drinking or cooking to building occupants.

The following measures are meant to be options for the district to consider. If a fixture is found to have exceeded the Action Level, an Immediate Response must be implemented. From there a Short-Term Control Measure may be enough to mitigate the hazard, with additional sampling conducted to confirm the measures’ effectiveness. Permanent Control Measures may be considered if the fixture continues to show elevated levels. Additional samples shall be collected after any control measure is put in place.

4.1 Immediate Response

- A. Shut Off Problem Outlets – If initial sample results exceed the Action Level, the outlet can be shut off or disconnected until the problem is resolved.
- B. Post “Non-Potable Water” at Problem Outlets – If the outlet is routinely used for purposes other than human ingestion (i.e. hand washing), clear signage can be posted to notify building occupants that the outlet is not to be used for drinking or cooking. This shall remain until further sampling proves the contaminant levels are below the Action Level.



Special Note – this signage shall also be posted on any outlet that was categorically excluded from testing and that cannot be isolated by custodial staff.

- C. Provide Alternate Drinking Water Sources – If the removal of an outlet drastically affects the drinking or cooking water supply of occupants, the district shall supply water by other means. This shall be in the form of water bottles, water coolers, or other methods to bring in outside water.

4.2 Short-Term Control Measures

- A. Post “Non-Potable Water” at Problem Outlets – This method may be used as a continual short-term control measure. The sign may be removed only when additional sampling confirms that contaminant levels within the outlet are below the Action Level. Maintenance or custodial staff shall perform periodic inspections to ensure the signage remains in place.
- B. Provide Filters at Problem Outlets – Point-of-use (POU) units are commercially available and can be effective in removing lead contaminants. The district shall oversee the installation and routine maintenance of these outlets, as well as keep records on their location and maintenance history.

4.3 Permanent Control Measures

- A. Provide Filters at Problem Outlets – POU filters can serve as long-term or permanent control measures. The district shall create maintenance schedules, conduct follow-up water sampling, and replace the filters as needed.
- B. Replacement of Problem Outlets – This can involve the removal of the outlet as well as any upstream plumbing components (e.g. valves, leaded solder). New outlets to be installed shall be certified lead-free.
- C. Pipe Replacement – Lead pipes within school buildings and portions of lead service lines can be replaced. Contact the local Public Water System regarding jurisdiction to determine if the replacement of lead piping or service lines are under the jurisdiction of the District or other entity.

5.0 REPORTING AND RECORD KEEPING

In accordance with Subpart 67-4 the district shall:

1. Report the test results to the local health department as soon as practicable, but no more than 1 business day after the school received the laboratory report.
2. Notify all staff and all persons in parental relation to children or students of the test results, in writing, as soon as practicable, but no more than 10 business days after the school received the laboratory report.
3. The school shall make available, on the school’s website, the results of all lead testing performed and lead remediation plans implemented pursuant to Subpart 67-4, as soon as practicable, but no more than 6 weeks after the school received the laboratory reports.
4. As soon as practicable, but no more than 10 business days after the school received the laboratory reports, the school shall report data relating to test results to the NYS Health



Department, local health department, and NYS Education Department, through the NYS Health Department's designated statewide electronic reporting system.

5. The school shall retain all records of test results, lead remediation plans, and waiver requests, for ten years following the creation of such documentation. Copies of such documentation shall be immediately provided to the NYS Health Department, local health department, or NYS Education Department, upon request.



APPENDIX A:
DETAILED RESULTS SPREADSHEET

Webster Schroeder High School				
Identification Code	Description	Date Sampled	Time Sampled	Result (µg/L)
STF-01-OD-IN-FNCE-B2	Right Hand Bubbler Near Turf Field	11/7/2025	0820	<1.00
STF-01-OD-IN-FNCE-B1	Left Hand Bubbler Near Turf Field	11/7/2025	0821	<1.00
STF-01-RM-IN-CONC-T	Turf Field Concessions Stand Tap	11/7/2025	0825	5.0
STF-01-RM-IN-CONC-HCT	Turf Field Concessions Stand Hot Chocolate Tap	11/7/2025	0827	3.6
STF-01-RM-IN-CONC-CT	Turf Field Concessions Stand Coffee Tap	11/7/2025	0826	2.0
STF-01-OD-IN-FNCE-T1	Water Tree by Turf Field Spout 1	11/7/2025	0831	<1.00
STF-01-OD-IN-FNCE-T2	Water Tree by Turf Field Spout 1	11/7/2025	0832	<1.00
STF-01-OD-IN-FNCE-T3	Water Tree by Turf Field Spout 1	11/7/2025	0833	<1.00
STF-01-OD-IN-FNCE-T4	Water Tree by Turf Field Spout 1	11/7/2025	0834	<1.00
SPF-01-OD-BY-PFF-T1	Water Tree by Practice Field Spout 1	11/7/2025	0840	<1.00
SPF-01-OD-BY-PFF-T2	Right Hand Bubbler Near Turf Field	11/7/2025	0841	1.4
SPF-01-OD-BY-PFF-T3	Right Hand Bubbler Near Turf Field	11/7/2025	0842	<1.00
SPF-01-OD-BY-PFF-T4	Right Hand Bubbler Near Turf Field	11/7/2025	0843	<1.00
SHS-01-KIT-IN-58-T1	Western Kitchen 58 Tap 1	12/11/2025	0600	22.7
SHS-01-KIT-IN-58-T2	Western Kitchen 58 Tap 2	12/11/2025	0602	<1.00
SHS-01-KIT-IN-58-CT	Western Kitchen Coffee Line	12/11/2025	0604	<1.00
SHS-01-KIT-IN-58-HCT	Western Kitchen Hot Chocolate Line	12/11/2025	0608	<1.00
SHS-01-KIT-IN-58-T3	Western Kitchen 58 Tap 3	12/11/2025	0610	1.3
SHS-01-KIT-IN-58-T3S	Western Kitchen 58 Overhead Sprayer on Tap 3	12/11/2025	0611	<1.00
SHS-01-KIT-IN-58-T4	Western Kitchen 58 Tap 4	12/11/2025	0614	<1.00
SHS-01-KIT-IN-58-T5	Western Kitchen 58 Tap 5	12/11/2025	0615	<1.00
SHS-01-KIT-IN-58-PF1	Western Kitchen 58 Pot Filler 1	12/11/2025	0618	<1.00
SHS-01-KIT-IN-58-PF2	Western Kitchen 58 Pot Filler 2	12/11/2025	0619	<1.00
SHS-01-KIT-IN-58-PF3	Western Kitchen 58 Pot Filler 3	12/11/2025	0622	2.7
SHS-01-KIT-IN-58-T6	Western Kitchen 58 Tap 6	12/11/2025	0623	<1.00
SHS-01-KIT-IN-58-T8	Western Kitchen 58 Tap 8	12/11/2025	0626	1.5
SHS-01-KIT-IN-58-T9	Western Kitchen 58 Tap 9	12/11/2025	0627	<1.00
SHS-01-NO-IN-PO-T	Nurse's Office Personal Office Tap	12/11/2025	0634	<1.00
SHS-01-NO-IN-BR-T	Nurse's Office Bandage Room Tap	12/11/2025	0636	<1.00
SHS-01-HA-BY-NOE-DFL	Hallway by Nurse's Office (East) Left Drinking Fountain	12/11/2025	0637	<1.00
SHS-01-HA-BY-NOE-BF	Hallway by Nurse's Office (East) Bottle Filler	12/11/2025	0638	<1.00
SHS-01-HA-BY-NOE-DFR	Hallway by Nurse's Office (East) Right Drinking Fountain	12/11/2025	0639	2.1

Webster Schroeder High School				
Identification Code	Description	Date Sampled	Time Sampled	Result (µg/L)
SHS-01-HA-BY-TR-DFL	Hallway by Trainer's Room Left Drinking Fountain	12/11/2025	0640	<1.00
SHS-01-HA-BY-TR-BF	Hallway by Trainer's Room Bottle Filler	12/11/2025	0641	<1.00
SHS-01-HA-BY-TR-DFR	Hallway by Trainer's Room Right Bottle Filler	12/11/2025	0642	<1.00
SHS-01-TR-IN-S7-IM	Trainer's Room S7 Ice Machine	12/11/2025	0644	<1.00
SHS-01-MS-IN-N18-T	Makerspace N18 Tap	12/11/2025	0651	2.7
SHS-01-LIB-IN-N12-T	Library N12 Tap	12/11/2025	0652	<1.00
SHS-01-OFF-IN-W29-T	Office W29 Tap	12/11/2025	0653	<1.00
SHS-01-CONC-IN-SESA-T	Concesseions SESA Tap	12/11/2025	0655	1.3
SHS-01-HA-BY-W28-DF	Hallway by W28 Drinking Fountain	12/11/2025	0659	<1.00
SHS-01-HA-BY-W28-BF	Hallway by W28 Bottle Filler	12/11/2025	0700	<1.00
SHS-01-FR-IN-W22-T	Faculty Room W22 Tap	12/11/2025	0702	<1.00
SHS-01-HA-BY-W13-DF	Hallway by W13 Drinking Fountain	12/11/2025	0705	<1.00
SHS-01-HA-BY-W13-BF	Hallway by W13 Bottle Filler	12/11/2025	0706	<1.00
SHS-01-GOAL-IN-W11-T	Goal Room W11 Tap	12/11/2025	0709	2.2
SHS-01-KIT-IN-WSA-T	Kitchen in WSA Classroom Tap	12/11/2025	0712	<1.00
SHS-01-HA-BY-W2B-DF	Hallway by W2B Drinking Fountain	12/11/2025	0715	<1.00
SHS-01-HA-BY-W2B-BF	Hallway by W2B Bottle Filler	12/11/2025	0716	<1.00
SHS-01-KIT-IN-MO-T	Main Office Kitchenette Tap	12/11/2025	0722	<1.00
SHS-01-HA-BY-E4-DF	Hallway by E4 Drinking Fountain	12/11/2025	0723	<1.00
SHS-01-HA-BY-E4-BF	Hallway by E4 Bottle Filler	12/11/2025	0724	<1.00
SHS-01-HA-BY-E18-DF	Hallway by E18 Drinking Fountain	12/11/2025	0729	<1.00
SHS-01-HA-BY-E18-BF	Hallway by E18 Bottle Filler	12/11/2025	0730	<1.00
SHS-01-UPK-IN-E26-T	UPK Classroom E26 Tap	12/11/2025	0732	<1.00
SHS-01-HA-BY-E33-DF	Hallway by E33 Drinking Fountain	12/11/2025	0736	<1.00
SHS-01-HA-BY-E33-BF	Hallway by E33 Bottle Filler	12/11/2025	0737	<1.00
SHS-01-SEC-IN-E34-T	Security Room E34 Tap	12/11/2025	0739	3.1
SHS-02-RM-IN-W228-T	Room W228 Tap	12/11/2025	0740	7.2
SHS-02-HA-BY-W227-DF	Hallway by W227 Drinking Fountain	12/11/2025	0741	<1.00
SHS-02-HA-BY-W227-BF	Hallway by W227 Bottle Filler	12/11/2025	0742	<1.00
SHS-02-FR-IN-W221-T	Faculty Room W221 Tap	12/11/2025	0744	2.8
SHS-02-HA-BY-W211-DF	Hallway by W211 Drinking Fountain	12/11/2025	0746	<1.00
SHS-02-HA-BY-W211-BF	Hallway by W211 Bottle Filler	12/11/2025	0747	<1.00

Webster Schroeder High School				
Identification Code	Description	Date Sampled	Time Sampled	Result (µg/L)
SHS-02-HA-BY-W200-DF	Hallway by W200 Drinking Fountain	12/11/2025	0749	<1.00
SHS-02-HA-BY-W200-BF	Hallway by W200 Bottle Filler	12/11/2025	0750	<1.00
SHS-02-OFF-IN-E202-T	Office E202 Tap	12/11/2025	0757	3.3
SHS-02-HA-BY-E203-DF	Hallway by E203 Drinking Fountain	12/11/2025	0757	<1.00
SHS-02-HA-BY-E203-BF	Hallway by E203 Bottle Filler	12/11/2025	0758	<1.00
SHS-02-HA-BY-E219-DF	Hallway by E219 Drinking Fountain	12/11/2025	0759	<1.00
SHS-02-HA-BY-E219-BF	Hallway by E219 Bottle Filler	12/11/2025	0800	<1.00
SHS-02-HA-BY-E234-DF	Hallway by E234 Drinking Fountain	12/11/2025	0805	<1.00
SHS-02-HA-BY-E234-BF	Hallway by E234 Bottle Filler	12/11/2025	0806	<1.00
SHS-01-RM-IN-GRNH-IM	Greenhouse Ice Machine	12/18/2025	0720	<1.00
SHS-01-RM-IN-WR-B	Bubbler in Weight Room	12/18/2025	0727	2.61
SHS-02-RM-IN-LAC-T	Lactation Room Tap	12/18/2025	0729	0.63



APPENDIX B:
LABORATORY ANALYTICAL
REPORTS



December 05, 2025

Service Request No:R2515000

Cory Stamp
Labella Associates, PC
300 State Street, 2nd Floor
Suite 201
Rochester, NY 14614

Laboratory Results for: Webster CSD - Schroeder

Dear Cory,

Enclosed are the results of the sample(s) submitted to our laboratory November 07, 2025
For your reference, these analyses have been assigned our service request number R2515000.

All testing was performed according to our laboratory's quality assurance program and met the requirements of the TNI standards except as noted in the case narrative report. Any testing not included in the lab's accreditation is identified on a Non-Certified Analytes report. All results are intended to be considered in their entirety. ALS Environmental is not responsible for use of less than the complete report. Results apply only to the individual samples submitted to the lab for analysis, as listed in the report. The measurement uncertainty of the results included in this report is within that expected when using the prescribed method(s), and represented by Laboratory Control Sample control limits. Any events, such as QC failures or Holding Time exceedances, which may add to the uncertainty are explained in the report narrative or are flagged with qualifiers. The flags are explained in the Report Qualifiers and Definitions page of this report.

Please contact me if you have any questions. My extension is 7475. You may also contact me via email at Meghan.Pedro@alsglobal.com.

Respectfully submitted,

ALS Group USA, Corp. dba ALS Environmental

Meghan Pedro
Project Manager

ADDRESS 1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
PHONE +1 585 288 5380 | FAX +1 585 288 8475
ALS Group USA, Corp.
dba ALS Environmental



Narrative Documents

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



Client: Labella Associates, PC
Project: Webster CSD - Schroeder
Sample Matrix: Drinking Water

Service Request: R2515000
Date Received: 11/07/2025

CASE NARRATIVE

All analyses were performed consistent with the quality assurance program of ALS Environmental. This report contains analytical results for samples for the Tier II level requested by the client.

Sample Receipt:

Thirteen drinking water samples were received for analysis at ALS Environmental on 11/07/2025. Any discrepancies upon initial sample inspection are annotated on the sample receipt and preservation form included within this report. The samples were stored at minimum in accordance with the analytical method requirements.

Metals:

No significant anomalies were noted with this analysis.

A handwritten signature in black ink that reads 'Meghan Pedro'.

Approved by _____

Date 12/05/2025



SAMPLE DETECTION SUMMARY

This form includes only detections above the reporting levels. For a full listing of sample results, continue to the Sample Results section of this Report.

CLIENT ID: STF-01-RM-IN-CONC-T		Lab ID: R2515000-003				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	5.0			1.0	ug/L	200.8

CLIENT ID: STF-01-RM-IN-CONC-HCT		Lab ID: R2515000-004				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	3.6			1.0	ug/L	200.8

CLIENT ID: STF-01-RM-IN-CONC-CT		Lab ID: R2515000-005				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	2.0			1.0	ug/L	200.8

CLIENT ID: STF-01-OD-BY-PFF-T2		Lab ID: R2515000-011				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.4			1.0	ug/L	200.8



Sample Receipt Information

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

Client: Labella Associates, PC
Project: Webster CSD - Schroeder/2251107

Service Request:R2515000

SAMPLE CROSS-REFERENCE

<u>SAMPLE #</u>	<u>CLIENT SAMPLE ID</u>	<u>DATE</u>	<u>TIME</u>
R2515000-001	STF-01-OD-IN-FNCE-B2	11/7/2025	0820
R2515000-002	STF-01-OD-IN-FNCE-B1	11/7/2025	0821
R2515000-003	STF-01-RM-IN-CONC-T	11/7/2025	0825
R2515000-004	STF-01-RM-IN-CONC-HCT	11/7/2025	0827
R2515000-005	STF-01-RM-IN-CONC-CT	11/7/2025	0826
R2515000-006	STF-01-OD-IN-FNCE-T1	11/7/2025	0831
R2515000-007	STF-01-OD-IN-FNCE-T2	11/7/2025	0832
R2515000-008	STF-01-OD-IN-FNCE-T3	11/7/2025	0833
R2515000-009	STF-01-OD-IN-FNCE-T4	11/7/2025	0834
R2515000-010	STF-01-OD-BY-PFF-T1	11/7/2025	0840
R2515000-011	STF-01-OD-BY-PFF-T2	11/7/2025	0841
R2515000-012	STF-01-OD-BY-PFF-T3	11/7/2025	0842
R2515000-013	STF-01-OD-BY-PFF-T4	11/7/2025	0843



ALS Environmental

Laboratory location:
Rochester NY

Chain of Custody Form

Page 1 of 2

R2515000

LaBella Associates, PC
Webster CSD - Schroeder

5



Customer Information			Project Information				Parameter/Method Request for Analysis										
Purchase Order		Project Name	Webster CSD - <i>Schroeder</i>		A	EPA 200.8 Lead in Drinking Water											
Work Order		Project Number	2251107		B												
Company Name	LaBella Associates	Bill To Company	LaBella Associates		C												
Send Report To	<i>Cory Stamp</i>	Invoice Attn:	<i>Cory Stamp</i>		D												
Address	300 State Street, Suite 200	Address	300 State Street, Suite 200		E												
					F												
City/State/Zip	Rochester, NY 14614	City/State/Zip	Rochester, NY 14614		G												
Phone	(607) 591-7516	Phone	(607) 591-7516		H												
Fax		Fax			I												
e-Mail Address	<i>cstamp@labellapc.com</i>	e-Mail Address	<i>cstamp@labellapc.com</i>		J												
No.	Sample Description	Date	Time	Matrix	Pres.	# Bottles	A	B	C	D	E	F	G	H	I	J	Hold
1	See attached spreadsheets for sample				N/A		X										
2	descriptions. All samples are 250 mL																
3	plastic bottles, drinking water, with																
4	no preservative																
5																	
6																	
7																	
8																	
9																	
10																	
Sampler(s): Please Print & Sign <i>Cory Stamp</i>			Shipment Method: Delivered		Required Turnaround Time: <input checked="" type="checkbox"/> STD 10 Wk Days <input type="checkbox"/> 5 Wk Days <input type="checkbox"/> 2 Wk Days <input type="checkbox"/> 24 Hour				Results Due Date:								
Relinquished by: <i>[Signature]</i>		Date: 11/7/25	Time: 1530	Received by: <i>[Signature]</i>		Notes:											
Relinquished by:		Date:	Time:	Received by (Laboratory):		Cooler Temp.:	QC Package: (Check Box Below)										
Logged by (Laboratory):		Date:	Time:	Checked by (Laboratory):			<input type="checkbox"/> Level II: Standard QC				TRRP-Checklist						
							<input type="checkbox"/> Level III: Std QC + Raw Data				TRRP Level IV						
							<input type="checkbox"/> Level IV: SW846 CLP-Like										
Preservative Key: 1-HCL 2-HNO3 3-H2SO4 4-NaOH 5-Na2S2O3 6-NaHSO4 7-Other 8-4 degrees C 9-8035						Other:											

Note: Any changes must be made in writing once samples and COC Form have been submitted to ALS Laboratory Group. Signature denotes acceptance of ALS Group USA, Corp. Terms and Conditions - Please click the link below for detailed Terms & Conditions:

<https://www.alsglobal.com/ALSGroupUSACorpTC>

ALS copyright © 2024. All rights reserved.

Identification Code	Description	Date Sampled	Time Sampled
STF-01-OD-IN-FNCE-B2	Right Hand Bubbler Near Turf Field	11/7/2025	0820
STF-01-OD-IN-FNCE-B1	Left Hand Bubbler Near Turf Field	11/7/2025	0821
STF-01-RM-IN-CONC-T	Turf Field Concessions Stand Tap	11/7/2025	0825
STF-01-RM-IN-CONC-HCT	Turf Field Concessions Stand Hot Chocolate Tap	11/7/2025	0827
STF-01-RM-IN-CONC-CT	Turf Field Concessions Stand Coffee Tap	11/7/2025	0826
STF-01-OD-IN-FNCE-T1	Water Tree by Turf Field Spout 1	11/7/2025	0831
STF-01-OD-IN-FNCE-T2	Water Tree by Turf Field Spout 1	11/7/2025	0832
STF-01-OD-IN-FNCE-T3	Water Tree by Turf Field Spout 1	11/7/2025	0833
STF-01-OD-IN-FNCE-T4	Water Tree by Turf Field Spout 1	11/7/2025	0834
SPF-01-OD-BY-PFF-T1	Water Tree by Practice Field Spout 1	11/7/2025	0840
SPF-01-OD-BY-PFF-T2	Right Hand Bubbler Near Turf Field	11/7/2025	0841
SPF-01-OD-BY-PFF-T3	Right Hand Bubbler Near Turf Field	11/7/2025	0842
SPF-01-OD-BY-PFF-T4	Right Hand Bubbler Near Turf Field	11/7/2025	0843



R2515000

Labette Associates, PC
Webster CSD - Schroeder

5



Cooler Receipt and Preservation Check Form

Project/Client _____ Folder Number _____

Cooler received on 11/7/25 by: _____

COURIER: ALS UPS FEDEX VELOCITY CLIENT

1	Were Custody seals on outside of cooler?	Y <u>N</u>
2	Custody papers properly completed (ink, signed)?	<u>Y</u> N
3	Did all bottles arrive in good condition (unbroken)?	<u>Y</u> N
4	Circle: Wet Ice Dry Ice Gel packs present?	Y <u>N</u>

5a	Did VOA vials have sig* bubbles?	Y N <u>NA</u>
5b	Sig* bubbles: Alk? Y N <u>NA</u>	Sulfide? Y N <u>NA</u>
6	Where did the bottles originate?	<u>ALS/ROC</u> CLIENT
7	Soil VOA received as: Bulk Encore 5035set	<u>NA</u>

8. Temperature Readings Date: 11/10/25 Time: 11:10 ID: IR#12 IR#11 From: Temp Blank Sample Bottle

Temp (°C)	<u>17.2</u>						
Within 0-6°C?	Y <u>N</u>	Y N	Y N	Y N	Y N	Y N	Y N
If <0°C, were samples frozen?	Y N	Y N	Y N	Y N	Y N	Y N	Y N

If out of Temperature, note packing/ice condition: No ice Ice melted Poorly Packed (described below) Same Day Rule
& Client Approval to Run Samples: _____ Standing Approval Client aware at drop-off Client notified by: _____

All samples held in storage location: SMO by Rm on 11/10 at 11:12
5035 samples placed in storage location: _____ by _____ on _____ at _____ within 48 hours of sampling? Y N

Cooler Breakdown/Preservation Check**: Date: 11/14/25 Time: 11:00 by: NM

- 9. Were all bottle labels complete (i.e. analysis, preservation, etc.)? YES NO
- 10. Did all bottle labels and tags agree with custody papers? YES NO
- 11. Were correct containers used for the tests indicated? YES NO
- 12. Were 5035 vials acceptable (no extra labels, not leaking)? YES NO N/A
- 13. Were dissolved metals filtered in the field? YES NO N/A
- 14. Air Samples: Cassettes / Tubes Intact Y / N with MS Y / N Canisters Pressurized Tedlar® Bags Inflated N/A

pH	Lot of test paper	Reagent	Preserved?		Lot Received	Exp	Sample ID Adjusted	Vol. Added	Lot Added	Final pH
			Yes	No						
≥12		NaOH								
≤2		HNO ₃		✓			All	4.0 ml	745078	2.0
≤2		H ₂ SO ₄								
<4		NaHSO ₄								
5-9		For 608pest			No=Notify for 3day					
Residual Chlorine (-)		For CN, Phenol, 625, 608pest, 522			If +, contact PM to add Na ₂ S ₂ O ₃ (625, 608, CN), ascorbic (phenol).					
		Na ₂ S ₂ O ₃								
		ZnAcetate	-	-						
		HCl	**	**						

**VOAs and 1664 Not to be tested before analysis. Otherwise, all bottles of all samples with chemical preservatives are checked (not just representatives).

Bottle lot numbers: _____
Explain all Discrepancies/ Other Comments: _____

HPROD	BULK
HTR	FLDT
SUB	HGFB
ALS	LL3541

Labels secondary reviewed by: TJP *significant air bubbles: VOA > 5-6 mm : WC > 1 in. diameter



Miscellaneous Forms

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



REPORT QUALIFIERS AND DEFINITIONS

- U Analyte was analyzed for but not detected. The sample quantitation limit has been corrected for dilution and for percent moisture, unless otherwise noted in the case narrative.
- J Estimated value due to either being a Tentatively Identified Compound (TIC) or that the concentration is between the MRL and the MDL. Concentrations are not verified within the linear range of the calibration. For DoD: concentration >40% difference between two GC columns (pesticides/Aroclors).
- B Analyte was also detected in the associated method blank at a concentration that may have contributed to the sample result.
- E Inorganics- Concentration is estimated due to the serial dilution was outside control limits.
- E Organics- Concentration has exceeded the calibration range for that specific analysis.
- D Concentration is a result of a dilution, typically a secondary analysis of the sample due to exceeding the calibration range or that a surrogate has been diluted out of the sample and cannot be assessed.
- * Indicates that a quality control parameter has exceeded laboratory limits. Under the "Notes" column of the Form I, this qualifier denotes analysis was performed out of Holding Time.
- H Analysis was performed out of hold time for tests that have an "immediate" hold time criteria.
- # Spike was diluted out.
- + Correlation coefficient for MSA is <0.995.
- N Inorganics- Matrix spike recovery was outside laboratory limits.
- N Organics- Presumptive evidence of a compound (reported as a TIC) based on the MS library search.
- S Concentration has been determined using Method of Standard Additions (MSA).
- W Post-Digestion Spike recovery is outside control limits and the sample absorbance is <50% of the spike absorbance.
- P Concentration >40% difference between the two GC columns.
- C Confirmed by GC/MS
- Q DoD reports: indicates a pesticide/Aroclor is not confirmed ($\geq 100\%$ Difference between two GC columns).
- X See Case Narrative for discussion.
- MRL Method Reporting Limit. Also known as:
- LOQ Limit of Quantitation (LOQ)
The lowest concentration at which the method analyte may be reliably quantified under the method conditions.
- MDL Method Detection Limit. A statistical value derived from a study designed to provide the lowest concentration that will be detected 99% of the time. Values between the MDL and MRL are estimated (see J qualifier).
- LOD Limit of Detection. A value at or above the MDL which has been verified to be detectable.
- ND Non-Detect. Analyte was not detected at the concentration listed. Same as U qualifier.

Rochester Lab ID # for State Accreditations¹



NELAP States
Florida ID # E87674
New Hampshire ID # 2941
New York ID # 10145
Pennsylvania ID# 68-786
Texas ID#T104704581
Virginia #460167

Non-NELAP States
Connecticut ID #PH0556
Delaware Approved
Maine ID #NY01587
North Carolina #36701
North Carolina #676
Rhode Island LAO00333

¹ Analyses were performed according to our laboratory's NELAP-approved quality assurance program and any applicable state or agency requirements. The test results meet requirements of the current NELAP/TNI standards or state or agency requirements, where applicable, except as noted in the case narrative. Since not all analyte/method/matrix combinations are offered for state/NELAC accreditation, this report may contain results which are not accredited. For a specific list of accredited analytes, contact the laboratory. To verify NH accredited analytes, go to <https://www4.des.state.nh.us/CertifiedLabs/Certified-Method.aspx>.

ALS Laboratory Group

Acronyms

ASTM	American Society for Testing and Materials
A2LA	American Association for Laboratory Accreditation
CARB	California Air Resources Board
CAS Number	Chemical Abstract Service registry Number
CFC	Chlorofluorocarbon
CFU	Colony-Forming Unit
DEC	Department of Environmental Conservation
DEQ	Department of Environmental Quality
DHS	Department of Health Services
DOE	Department of Ecology
DOH	Department of Health
EPA	U. S. Environmental Protection Agency
ELAP	Environmental Laboratory Accreditation Program
GC	Gas Chromatography
GC/MS	Gas Chromatography/Mass Spectrometry
LUFT	Leaking Underground Fuel Tank
M	Modified
MCL	Maximum Contaminant Level is the highest permissible concentration of a substance allowed in drinking water as established by the USEPA.
MDL	Method Detection Limit
MPN	Most Probable Number
MRL	Method Reporting Limit
NA	Not Applicable
NC	Not Calculated
NCASI	National Council of the Paper Industry for Air and Stream Improvement
ND	Not Detected
NIOSH	National Institute for Occupational Safety and Health
PQL	Practical Quantitation Limit
RCRA	Resource Conservation and Recovery Act
SIM	Selected Ion Monitoring
TPH	Total Petroleum Hydrocarbons
tr	Trace level is the concentration of an analyte that is less than the PQL but greater than or equal to the MDL.

ALS Group USA, Corp.
dba ALS Environmental
Analyst Summary report

Client: Labella Associates, PC
Project: Webster CSD - Schroeder/2251107

Service Request: R2515000

Sample Name: STF-01-OD-IN-FNCE-B2
Lab Code: R2515000-001
Sample Matrix: Drinking Water

Date Collected: 11/7/25
Date Received: 11/7/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: STF-01-OD-IN-FNCE-B1
Lab Code: R2515000-002
Sample Matrix: Drinking Water

Date Collected: 11/7/25
Date Received: 11/7/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: STF-01-RM-IN-CONC-T
Lab Code: R2515000-003
Sample Matrix: Drinking Water

Date Collected: 11/7/25
Date Received: 11/7/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: STF-01-RM-IN-CONC-HCT
Lab Code: R2515000-004
Sample Matrix: Drinking Water

Date Collected: 11/7/25
Date Received: 11/7/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: STF-01-RM-IN-CONC-CT
Lab Code: R2515000-005
Sample Matrix: Drinking Water

Date Collected: 11/7/25
Date Received: 11/7/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

ALS Group USA, Corp.
dba ALS Environmental
Analyst Summary report

Client: Labella Associates, PC
Project: Webster CSD - Schroeder/2251107

Service Request: R2515000

Sample Name: STF-01-OD-IN-FNCE-T1
Lab Code: R2515000-006
Sample Matrix: Drinking Water

Date Collected: 11/7/25
Date Received: 11/7/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: STF-01-OD-IN-FNCE-T2
Lab Code: R2515000-007
Sample Matrix: Drinking Water

Date Collected: 11/7/25
Date Received: 11/7/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: STF-01-OD-IN-FNCE-T3
Lab Code: R2515000-008
Sample Matrix: Drinking Water

Date Collected: 11/7/25
Date Received: 11/7/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: STF-01-OD-IN-FNCE-T4
Lab Code: R2515000-009
Sample Matrix: Drinking Water

Date Collected: 11/7/25
Date Received: 11/7/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: STF-01-OD-BY -PFF-T1
Lab Code: R2515000-010
Sample Matrix: Drinking Water

Date Collected: 11/7/25
Date Received: 11/7/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

ALS Group USA, Corp.
dba ALS Environmental
Analyst Summary report

Client: Labella Associates, PC
Project: Webster CSD - Schroeder/2251107

Service Request: R2515000

Sample Name: STF-01-OD-BY -PFF-T2
Lab Code: R2515000-011
Sample Matrix: Drinking Water

Date Collected: 11/7/25
Date Received: 11/7/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: STF-01-OD-BY -PFF-T3
Lab Code: R2515000-012
Sample Matrix: Drinking Water

Date Collected: 11/7/25
Date Received: 11/7/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: STF-01-OD-BY -PFF-T4
Lab Code: R2515000-013
Sample Matrix: Drinking Water

Date Collected: 11/7/25
Date Received: 11/7/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN



PREPARATION METHODS

The preparation methods associated with this report are found in these tables unless discussed in the case narrative.

INORGANIC

Water/Liquid Matrix

Analytical Method	Preparation Method
200.7 / 200.8	200.2
6010D	3005A/3010A
6020B	ILM05.3
9034 Sulfide Acid Soluble	9030B
SM 4500-CN-N-2016 Amenable and Residual Cyanide	SM 4500-CN-G and SM 4500-CN-B,C-2016
SM 4500-CN-E WAD Cyanide	SM 4500-CN-I

Solid/Soil/Non-Aqueous Matrix

Analytical Method	Preparation Method
6010D	3050B
6010D TCLP (1311) extract	3005A/3010A
6010D SPLP (1312) extract	3005A/3010A
7199	3060A
300.0 Anions/ 350.1/ 353.2/ SM 2320B/ SM 5210B/ 9056A Anions	DI extraction
For analytical methods not listed, the preparation method is the same as the analytical method reference.	

ORGANIC

Preparation Methods for Organic methods are listed in the header of the Results pages.

Regarding "Bulk/5035A":

For soil/solid samples submitted in soil jars for Volatiles analysis, the prep method is listed as "Bulk/5035A". The lab follows the closed-system EPA 5035A protocols once the sample is transferred to a sealed vial, but collection in bulk in soil jars does not follow the collection protocols listed in EPA 5035A. In accordance with the NYSDOH technical notice of October 2012, all results or reporting limits <200 ug/kg are to be considered estimated due to potential low bias.



Sample Results

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



Metals

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Schroeder/2251107
Sample Matrix: Drinking Water
Sample Name: STF-01-OD-IN-FNCE-B2
Lab Code: R2515000-001

Service Request: R2515000
Date Collected: 11/07/25 08:20
Date Received: 11/07/25 15:30
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	12/02/25 18:24	

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Schroeder/2251107
Sample Matrix: Drinking Water
Sample Name: STF-01-OD-IN-FNCE-B1
Lab Code: R2515000-002

Service Request: R2515000
Date Collected: 11/07/25 08:21
Date Received: 11/07/25 15:30
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	12/02/25 18:25	

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Schroeder/2251107
Sample Matrix: Drinking Water
Sample Name: STF-01-RM-IN-CONC-T
Lab Code: R2515000-003

Service Request: R2515000
Date Collected: 11/07/25 08:25
Date Received: 11/07/25 15:30
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	5.0	ug/L	1.0	1	12/02/25 18:26	

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Schroeder/2251107
Sample Matrix: Drinking Water
Sample Name: STF-01-RM-IN-CONC-HCT
Lab Code: R2515000-004

Service Request: R2515000
Date Collected: 11/07/25 08:27
Date Received: 11/07/25 15:30
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	3.6	ug/L	1.0	1	12/03/25 14:10	

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Schroeder/2251107
Sample Matrix: Drinking Water
Sample Name: STF-01-RM-IN-CONC-CT
Lab Code: R2515000-005

Service Request: R2515000
Date Collected: 11/07/25 08:26
Date Received: 11/07/25 15:30
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	2.0	ug/L	1.0	1	12/02/25 18:29	

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Schroeder/2251107
Sample Matrix: Drinking Water
Sample Name: STF-01-OD-IN-FNCE-T1
Lab Code: R2515000-006

Service Request: R2515000
Date Collected: 11/07/25 08:31
Date Received: 11/07/25 15:30
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	12/02/25 18:30	

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Schroeder/2251107
Sample Matrix: Drinking Water
Sample Name: STF-01-OD-IN-FNCE-T2
Lab Code: R2515000-007

Service Request: R2515000
Date Collected: 11/07/25 08:32
Date Received: 11/07/25 15:30
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	12/02/25 18:39	

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Schroeder/2251107
Sample Matrix: Drinking Water
Sample Name: STF-01-OD-IN-FNCE-T3
Lab Code: R2515000-008

Service Request: R2515000
Date Collected: 11/07/25 08:33
Date Received: 11/07/25 15:30
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	12/02/25 18:43	

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Schroeder/2251107
Sample Matrix: Drinking Water
Sample Name: STF-01-OD-IN-FNCE-T4
Lab Code: R2515000-009

Service Request: R2515000
Date Collected: 11/07/25 08:34
Date Received: 11/07/25 15:30
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	12/02/25 18:45	

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Schroeder/2251107
Sample Matrix: Drinking Water
Sample Name: STF-01-OD-BY -PFF-T1
Lab Code: R2515000-010

Service Request: R2515000
Date Collected: 11/07/25 08:40
Date Received: 11/07/25 15:30
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	12/02/25 18:46	

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Schroeder/2251107
Sample Matrix: Drinking Water
Sample Name: STF-01-OD-BY -PFF-T2
Lab Code: R2515000-011

Service Request: R2515000
Date Collected: 11/07/25 08:41
Date Received: 11/07/25 15:30
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.4	ug/L	1.0	1	12/02/25 18:47	

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Schroeder/2251107
Sample Matrix: Drinking Water
Sample Name: STF-01-OD-BY -PFF-T3
Lab Code: R2515000-012

Service Request: R2515000
Date Collected: 11/07/25 08:42
Date Received: 11/07/25 15:30

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	12/02/25 18:49	

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Schroeder/2251107
Sample Matrix: Drinking Water
Sample Name: STF-01-OD-BY -PFF-T4
Lab Code: R2515000-013

Service Request: R2515000
Date Collected: 11/07/25 08:43
Date Received: 11/07/25 15:30

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	12/02/25 18:52	



QC Summary Forms

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



Metals

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Schroeder/2251107
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2515000-MB1

Service Request: R2515000
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	12/02/25 17:55	

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Schroeder/2251107
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2515000-MB2

Service Request: R2515000
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	12/02/25 18:37	

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Schroeder/2251107
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2515000-MB3

Service Request: R2515000
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	12/03/25 13:45	

QA/QC Report

Client: Labella Associates, PC
Project: Webster CSD - Schroeder/2251107
Sample Matrix: Drinking Water

Service Request: R2515000
Date Collected: 11/07/25
Date Received: 11/07/25
Date Analyzed: 12/2/25

Duplicate Matrix Spike Summary
Inorganic Parameters

Sample Name: STF-01-OD-IN-FNCE-T1
Lab Code: R2515000-006
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike R2515000-006MS		Result	Duplicate Matrix Spike R2515000-006DMS		% Rec Limits	RPD	RPD Limit
			Spike Amount	% Rec		Spike Amount	% Rec			
Lead, Total	1.0 U	20.3	20.0	101	20.4	20.0	102	70-130	<1	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

QA/QC Report

Client: Labella Associates, PC
Project: Webster CSD - Schroeder/2251107
Sample Matrix: Drinking Water

Service Request: R2515000
Date Collected: 11/07/25
Date Received: 11/07/25
Date Analyzed: 12/2/25

Duplicate Matrix Spike Summary
Inorganic Parameters

Sample Name: STF-01-OD-IN-FNCE-T2
Lab Code: R2515000-007
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike R2515000-007MS		Result	Duplicate Matrix Spike R2515000-007DMS		% Rec Limits	RPD	RPD Limit
			Spike Amount	% Rec		Spike Amount	% Rec			
Lead, Total	1.0 U	20.4	20.0	102	21.6	20.0	108	70-130	6	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

Client: Labella Associates, PC
Project: Webster CSD - Schroeder/2251107
Sample Matrix: Drinking Water

Service Request: R2515000

Date Analyzed: 12/02/25

Lab Control Sample Summary
Inorganic Parameters

Units: ug/L

Basis: NA

Lab Control Sample
R2515000-LCS1

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	20.4	20.0	102	85-115

Client: Labella Associates, PC
Project: Webster CSD - Schroeder/2251107
Sample Matrix: Drinking Water

Service Request: R2515000

Date Analyzed: 12/02/25

Lab Control Sample Summary
Inorganic Parameters

Units: ug/L

Basis: NA

Lab Control Sample
R2515000-LCS2

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	17.7	20.0	89	85-115

Client: Labella Associates, PC
Project: Webster CSD - Schroeder/2251107
Sample Matrix: Drinking Water

Service Request: R2515000

Date Analyzed: 12/03/25

Lab Control Sample Summary
Inorganic Parameters

Units: ug/L

Basis: NA

Lab Control Sample
R2515000-LCS3

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	21.1	20.0	106	85-115



January 07, 2026

Service Request No:R2516770

Cory Stamp
Labella Associates, PC
300 State Street, 2nd Floor
Suite 201
Rochester, NY 14614

Laboratory Results for: Webster CSD - Schroeder

Dear Cory,

Enclosed are the results of the sample(s) submitted to our laboratory December 11, 2025
For your reference, these analyses have been assigned our service request number **R2516770**.

All testing was performed according to our laboratory's quality assurance program and met the requirements of the TNI standards except as noted in the case narrative report. Any testing not included in the lab's accreditation is identified on a Non-Certified Analytes report. All results are intended to be considered in their entirety. ALS Environmental is not responsible for use of less than the complete report. Results apply only to the individual samples submitted to the lab for analysis, as listed in the report. The measurement uncertainty of the results included in this report is within that expected when using the prescribed method(s), and represented by Laboratory Control Sample control limits. Any events, such as QC failures or Holding Time exceedances, which may add to the uncertainty are explained in the report narrative or are flagged with qualifiers. The flags are explained in the Report Qualifiers and Definitions page of this report.

Please contact me if you have any questions. My extension is 7475. You may also contact me via email at Meghan.Pedro@alsglobal.com.

Respectfully submitted,

ALS Group USA, Corp. dba ALS Environmental

Meghan Pedro
Project Manager

ADDRESS 1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
PHONE +1 585 288 5380 | **FAX** +1 585 288 8475
ALS Group USA, Corp.
dba ALS Environmental



Narrative Documents

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



Client: Labella Associates, PC
Project: Webster CSD - Schroeder
Sample Matrix: Drinking Water

Service Request: R2516770
Date Received: 12/11/2025

CASE NARRATIVE

All analyses were performed consistent with the quality assurance program of ALS Environmental. This report contains analytical results for samples for the Tier II level requested by the client.

Sample Receipt:

Twenty five drinking water samples were received for analysis at ALS Environmental on 12/11/2025. Any discrepancies upon initial sample inspection are annotated on the sample receipt and preservation form included within this report. The samples were stored at minimum in accordance with the analytical method requirements.

Metals:

No significant anomalies were noted with this analysis.

A handwritten signature in black ink that reads "Meghan Pedro".

Approved by _____

Date 01/07/2026



SAMPLE DETECTION SUMMARY

This form includes only detections above the reporting levels. For a full listing of sample results, continue to the Sample Results section of this Report.

CLIENT ID: SHS0-01-KIT-IN-58-T1		Lab ID: R2516770-001				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	22.7			1.0	ug/L	200.8

CLIENT ID: SHS0-01-KIT-IN-58-T3		Lab ID: R2516770-005				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.3			1.0	ug/L	200.8

CLIENT ID: SHS0-01-KIT-IN-58-PF3		Lab ID: R2516770-011				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	2.7			1.0	ug/L	200.8

CLIENT ID: SHS0-01-KIT-IN-58-T8		Lab ID: R2516770-013				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.5			1.0	ug/L	200.8

CLIENT ID: SHS0-01-HA-BY-TR-DFR		Lab ID: R2516770-022				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	2.1			1.0	ug/L	200.8

CLIENT ID: SHS0-01-MS-IN-N16-T		Lab ID: R2516770-024				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	2.7			1.0	ug/L	200.8



Sample Receipt Information

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

Client: Labella Associates, PC
Project: Webster CSD - Schroeder/2251107

Service Request:R2516770

SAMPLE CROSS-REFERENCE

<u>SAMPLE #</u>	<u>CLIENT SAMPLE ID</u>	<u>DATE</u>	<u>TIME</u>
R2516770-001	SHS0-01-KIT-IN-58-T1	12/11/2025	0600
R2516770-002	SHS0-01-KIT-IN-58-T2	12/11/2025	0602
R2516770-003	SHS0-01-KIT-IN-58-CT	12/11/2025	0604
R2516770-004	SHS0-01-KIT-IN-58-HCT	12/11/2025	0608
R2516770-005	SHS0-01-KIT-IN-58-T3	12/11/2025	0610
R2516770-006	SHS0-01-KIT-IN-58-T3S	12/11/2025	0611
R2516770-007	SHS0-01-KIT-IN-58-T4	12/11/2025	0614
R2516770-008	SHS0-01-KIT-IN-58-T5	12/11/2025	0615
R2516770-009	SHS0-01-KIT-IN-58-PF1	12/11/2025	0618
R2516770-010	SHS0-01-KIT-IN-58-PF2	12/11/2025	0619
R2516770-011	SHS0-01-KIT-IN-58-PF3	12/11/2025	0622
R2516770-012	SHS0-01-KIT-IN-58-T6	12/11/2025	0623
R2516770-013	SHS0-01-KIT-IN-58-T8	12/11/2025	0626
R2516770-014	SHS0-01-KIT-IN-58-T9	12/11/2025	0627
R2516770-015	SHS0-01-NO-IN-PO-T	12/11/2025	0634
R2516770-016	SHS0-01-NO-IN-BR-T	12/11/2025	0636
R2516770-017	SHS0-01-HA-BY-NOE-DFL	12/11/2025	0637
R2516770-018	SHS0-01-HA-BY-NOE-BF	12/11/2025	0638
R2516770-019	SHS0-01-HA-BY-NOE-BFR	12/11/2025	0639
R2516770-020	SHS0-01-HA-BY-TR-DFL	12/11/2025	0640
R2516770-021	SHS0-01-HA-BY-TR-BF	12/11/2025	0641
R2516770-022	SHS0-01-HA-BY-TR-DFR	12/11/2025	0642
R2516770-023	SHS0-01-TR-IN-S7-IM	12/11/2025	0644
R2516770-024	SHS0-01-MS-IN-N16-T	12/11/2025	0651
R2516770-025	SHS0-01-LIB-IN-N12-T	12/11/2025	0652




1565 Jefferson Road, Building 300, Suite 360 • Rochester, NY 14623 • +1 585 288 5380 • alsglobal.com

Chain of Custody / Analytical Request Form

088772

Cr6 7196/SM3500 ; BOD ; CT ; Cr6 7199/218.6
353.2 NO2 ; OPO4 ; 300/9056A NO2/NO3 ; Sulfide
RES Cl ; DO ; Ferrous Iron ; Sulfite ; UV 254 ; CHL A
Color ; Turbidity ; Set Solids

Report To:		ALL SHADED AREAS MUST BE COMPLETED BY THE CLIENT / SAMPLER			Preservative →		0-None, 1-HCl, 2-HNO3, 3-H2SO4, 4-NaOH, 5-ZnAc, 6-MeOH, 7-NaHSO4, 8-Other												
Company: <i>LeBella</i>		Project Name: <i>Webster CSD - Schroeder</i>			GW WW SW DW S I NA	Number of Containers	MS/MSD?	↓ Tests / Analytes Requested ↓											
Contact: <i>Cory Stump</i>		Project Number: <i>2251107</i>						GC/MS VOA - 8260 • 624 • 524 • TCLP	GC/MS SVOA - 8270 • 625 • TCLP	Pesticides - 8081 • 608 • TCLP	PCBs - 8082 • 608	Herbicides - 8151 • TCLP	Metals, Total - Select Below	Metals, Dissolved - Field / In-Lab Filter	<i>EPA 200 (IIPW)</i>				
Email: <i>cstump@lebellapc.com</i>		ALS Quote #:		DOD? Y/N															
Phone:		Sampler's Signature: <i>[Signature]</i>																	
Address:		Email CC:																	
		Email CC:																	
		State Samples Collected (Circle or Write): NY, MA, PA, CT, Other:																	
Lab ID (ALS)	Sample Collection Information:				Matrix	Number of Containers	MS/MSD?	GC/MS VOA - 8260 • 624 • 524 • TCLP	GC/MS SVOA - 8270 • 625 • TCLP	Pesticides - 8081 • 608 • TCLP	PCBs - 8082 • 608	Herbicides - 8151 • TCLP	Metals, Total - Select Below	Metals, Dissolved - Field / In-Lab Filter					
	Sample ID / Name of Collection Point:	Date	Time																
	<i>See attached spreadsheets</i>	<i>12/11</i>																	
Metals: RCRA 8 • PP 13 • TAL 23 • TCLP • Part 375 • Other (List)					Turnaround Requirements			Report Requirements			Invoice To: (<input type="checkbox"/> Same as Report To)								
VOA/SVOA Report List: TCL • BTEX • TCLP • CP-51/Stars • THM • Part 375 • Other (List)					<input type="checkbox"/> *Rush (Surcharges Apply) <input type="checkbox"/> *Subject to Availability* <input type="checkbox"/> *Please Check with your PM* <input type="checkbox"/> Standard (10 Business Days)			<input type="checkbox"/> Tier II/Cat A - Results/QC <input type="checkbox"/> Tier IV/Cat B - Data Validation Report w/. Data EDD: <input type="checkbox"/> Yes <input type="checkbox"/> No EDD Type:			PO #: Company: Contact: Email: Phone: Address:								
Special Instructions / Comments:					TAT / Date Required:														
Relinquished By / Company Name		Date	Time	Received By / Company Name															
<i>Cory Stump</i>		<i>12/11/25</i>	<i>12:05</i>	<i>2nd MUMM ALS 12/11/25 12:05</i>															

R2516770 5
 Labelle Associates, PC
 Webster CSD - Schroeder


Sample Number	Location	Outlet Type	Detail	Date	Time
SHS-01-KIT-IN-58-T1	Kit Room 58 (Western)	Tap	T	12/11	0600
SHS-01-KIT-IN-58-T2	"	Tap	2	12/11	0602
SHS-01-CIT-IN-58-C1		Coffee tap			0604
SHS-01-KIT-IN-58-HC1		Hot Chocolate tap			0608
SHS-01-KIT-IN-58-T3		Tap	3		0610
SHS-01-KIT-IN-58-T3S		Overhead Sprayer	2, 3		0611
SHS-01-KIT-IN-58-T4		Tap	4		0614
SHS-01-KIT-IN-58-T5		Tap	5		0615
SHS-01-KIT-IN-58-F1		Hot Filler	1		0618
SHS-01-KIT-IN-58-F2		Hot Filler	2		0619
SHS-01-KIT-IN-58-F3		Hot Filler	3		0622
SHS-01-KIT-IN-58-T6		Tap	6		0623
SHS-01-KIT-IN-58-T8		Tap	8		0626
SHS-01-KIT-IN-58-T9		Tap	9		0627
SHS-01-NO-IN-90-T	Nurse's Office - Personal	Tap			0634
SHS-01-NO-IN-90-T	Nurse's Office - Bandage Room	Tap	West		0637
SHS-01-HA-8R-NDE-DR2	Hallway by Nurse's Office (East)	DF	Left		0637
SHS-01-HA-8R-NDE-8P		BF			0638
SHS-01-HA-8R-NDE-DRR		DF	Right		0639
SHS-01-HA-8R-T-R-8P	Hallway by Trainer's Room	DF	Left		0640
SHS-01-HA-8R-T-R-8P		BF			0641
SHS-01-HA-8R-T-R-DRR		DF	Right		0642
SHS-01-TR-IN-57-IM	Trainer's Room 57	IM			0644
SHS-01-MS-IN-N16-T	Makespace N18	T			0651
SHS-01-LTB-IN-N12-T	Library N12	T			0652



Cooler Receipt and Preservation Check

R2516770 **5**
 Labella Associates, PC
 Webster CSD - Schroeder

Project/Client Labella Folder Number _____

Cooler received on 12/11/25 by: RM COURIER: ALS UPS FEDEX VELOCITY CLIENT

1	Were Custody seals on outside of cooler?	Y <input checked="" type="radio"/> N <input type="radio"/>
2	Custody papers properly completed (ink, signed)?	<input checked="" type="radio"/> Y <input type="radio"/> N
3	Did all bottles arrive in good condition (unbroken)?	<input checked="" type="radio"/> Y <input type="radio"/> N
4	Circle: Wet Ice Dry Ice Gel packs present?	Y <input checked="" type="radio"/> N <input type="radio"/>

5a	Did VOA vials have sig* bubbles?	Y <input type="radio"/> N <input checked="" type="radio"/> NA <input type="radio"/>
5b	Sig* bubbles: Alk? Y <input type="radio"/> N <input checked="" type="radio"/> NA <input type="radio"/> Sulfide? Y <input type="radio"/> N <input checked="" type="radio"/> NA <input type="radio"/>	
6	Where did the bottles originate?	ALS/ROC <u>CLIENT</u>
7	Soil VOA received as:	Bulk Encore 5035set <input checked="" type="radio"/> NA <input type="radio"/>

8. Temperature Readings Date: 12/11/25 Time: 12:08 ID: IR#11 IR#12 IR#13 From: Temp Blank Sample Bottle

Temp (°C)	<u>14.3</u>						
Within 0-6°C?	Y <input checked="" type="radio"/> N <input type="radio"/>	Y <input type="radio"/> N <input type="radio"/>	Y <input type="radio"/> N <input type="radio"/>	Y <input type="radio"/> N <input type="radio"/>	Y <input type="radio"/> N <input type="radio"/>	Y <input type="radio"/> N <input type="radio"/>	Y <input type="radio"/> N <input type="radio"/>
If <0°C, were samples frozen?	Y <input type="radio"/> N <input type="radio"/>	Y <input type="radio"/> N <input type="radio"/>	Y <input type="radio"/> N <input type="radio"/>	Y <input type="radio"/> N <input type="radio"/>	Y <input type="radio"/> N <input type="radio"/>	Y <input type="radio"/> N <input type="radio"/>	Y <input type="radio"/> N <input type="radio"/>

If out of Temperature, note packing/ice condition: _____ Ice melted Poorly Packed (described below) Same Day Rule
 & Client Approval to Run Samples: _____ Standing Approval Client aware at drop-off Client notified by: _____

All samples held in storage location: SMD by RM on 12/11 at 12:08
 5035 samples placed in storage location: _____ by _____ on _____ at _____ within 48 hours of sampling? Y N

Cooler Breakdown/Preservation Check**: Date: 12/15 Time: 17:22 by: AG

- 9. Were all bottle labels complete (i.e. analysis, preservation, etc.)? AG 12/15 YES NO
- 10. Did all bottle labels and tags agree with custody papers? YES NO
- 11. Were correct containers used for the tests indicated? YES NO
- 12. Were 5035 vials acceptable (no extra labels, not leaking)? YES NO N/A
- 13. Were dissolved metals filtered in the field? YES NO N/A

pH	Lot of test paper	Reagent	Preserved?		Lot Received	Exp	Sample ID Adjusted	Vol. Added	Lot Added	Final pH
			Yes	No						
≥12		NaOH								
≤2	<u>202325</u>	HNO ₃		X	<u>Client Bottle</u>		<u>All</u>	<u>4mL</u>		<u>4.2</u>
≤2		H ₂ SO ₄								
<4		NaHSO ₄								
5-9		For 608pest			No=Notify for 3day					
Residual Chlorine (-)		For CN, Phenol, 625, 608pest, 522			If +, contact PM to add Na ₂ S ₂ O ₃ (625, 608, CN), ascorbic (phenol).					
		Na ₂ S ₂ O ₃								
		ZnAcetate	-	-						
		HCl	**	**						

**VOAs and 1664 Not to be tested before analysis. Otherwise, all bottles of all samples with chemical preservatives are checked (not just representatives).

Bottle lot numbers: Client Bottles.
 Explain all Discrepancies/ Other Comments: _____

HPROD	BULK
HTR	FLDT
SUB	HGFB
ALS	LL3541

Labels secondary reviewed by: AG *significant air bubbles: VOA > 5-6 mm : WC > 1 in. diameter



Miscellaneous Forms

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



REPORT QUALIFIERS AND DEFINITIONS

- U Analyte was analyzed for but not detected. The sample quantitation limit has been corrected for dilution and for percent moisture, unless otherwise noted in the case narrative.
- J Estimated value due to either being a Tentatively Identified Compound (TIC) or that the concentration is between the MRL and the MDL. Concentrations are not verified within the linear range of the calibration. For DoD: concentration >40% difference between two GC columns (pesticides/Aroclors).
- B Analyte was also detected in the associated method blank at a concentration that may have contributed to the sample result.
- E Inorganics- Concentration is estimated due to the serial dilution was outside control limits.
- E Organics- Concentration has exceeded the calibration range for that specific analysis.
- D Concentration is a result of a dilution, typically a secondary analysis of the sample due to exceeding the calibration range or that a surrogate has been diluted out of the sample and cannot be assessed.
- * Indicates that a quality control parameter has exceeded laboratory limits. Under the "Notes" column of the Form I, this qualifier denotes analysis was performed out of Holding Time.
- H Analysis was performed out of hold time for tests that have an "immediate" hold time criteria.
- # Spike was diluted out.
- + Correlation coefficient for MSA is <0.995.
- N Inorganics- Matrix spike recovery was outside laboratory limits.
- N Organics- Presumptive evidence of a compound (reported as a TIC) based on the MS library search.
- S Concentration has been determined using Method of Standard Additions (MSA).
- W Post-Digestion Spike recovery is outside control limits and the sample absorbance is <50% of the spike absorbance.
- P Concentration >40% difference between the two GC columns.
- C Confirmed by GC/MS
- Q DoD reports: indicates a pesticide/Aroclor is not confirmed ($\geq 100\%$ Difference between two GC columns).
- X See Case Narrative for discussion.
- MRL Method Reporting Limit. Also known as:
- LOQ Limit of Quantitation (LOQ)
The lowest concentration at which the method analyte may be reliably quantified under the method conditions.
- MDL Method Detection Limit. A statistical value derived from a study designed to provide the lowest concentration that will be detected 99% of the time. Values between the MDL and MRL are estimated (see J qualifier).
- LOD Limit of Detection. A value at or above the MDL which has been verified to be detectable.
- ND Non-Detect. Analyte was not detected at the concentration listed. Same as U qualifier.

Rochester Lab ID # for State Accreditations¹



NELAP States
Florida ID # E87674
New Hampshire ID # 2941
New York ID # 10145
Pennsylvania ID# 68-786
Texas ID#T104704581
Virginia #460167

Non-NELAP States
Connecticut ID #PH0556
Delaware Approved
Maine ID #NY01587
North Carolina #36701
North Carolina #676
Rhode Island LAO00333

¹ Analyses were performed according to our laboratory's NELAP-approved quality assurance program and any applicable state or agency requirements. The test results meet requirements of the current NELAP/TNI standards or state or agency requirements, where applicable, except as noted in the case narrative. Since not all analyte/method/matrix combinations are offered for state/NELAC accreditation, this report may contain results which are not accredited. For a specific list of accredited analytes, contact the laboratory. To verify NH accredited analytes, go to <https://www4.des.state.nh.us/CertifiedLabs/Certified-Method.aspx>.

ALS Laboratory Group

Acronyms

ASTM	American Society for Testing and Materials
A2LA	American Association for Laboratory Accreditation
CARB	California Air Resources Board
CAS Number	Chemical Abstract Service registry Number
CFC	Chlorofluorocarbon
CFU	Colony-Forming Unit
DEC	Department of Environmental Conservation
DEQ	Department of Environmental Quality
DHS	Department of Health Services
DOE	Department of Ecology
DOH	Department of Health
EPA	U. S. Environmental Protection Agency
ELAP	Environmental Laboratory Accreditation Program
GC	Gas Chromatography
GC/MS	Gas Chromatography/Mass Spectrometry
LUFT	Leaking Underground Fuel Tank
M	Modified
MCL	Maximum Contaminant Level is the highest permissible concentration of a substance allowed in drinking water as established by the USEPA.
MDL	Method Detection Limit
MPN	Most Probable Number
MRL	Method Reporting Limit
NA	Not Applicable
NC	Not Calculated
NCASI	National Council of the Paper Industry for Air and Stream Improvement
ND	Not Detected
NIOSH	National Institute for Occupational Safety and Health
PQL	Practical Quantitation Limit
RCRA	Resource Conservation and Recovery Act
SIM	Selected Ion Monitoring
TPH	Total Petroleum Hydrocarbons
tr	Trace level is the concentration of an analyte that is less than the PQL but greater than or equal to the MDL.

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Labella Associates, PC
Project: Webster CSD - Schroeder/2251107

Service Request: R2516770

Sample Name: SHS0-01-KIT-IN-58-T1
Lab Code: R2516770-001
Sample Matrix: Drinking Water

Date Collected: 12/11/25
Date Received: 12/11/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: SHS0-01-KIT-IN-58-T2
Lab Code: R2516770-002
Sample Matrix: Drinking Water

Date Collected: 12/11/25
Date Received: 12/11/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: SHS0-01-KIT-IN-58-CT
Lab Code: R2516770-003
Sample Matrix: Drinking Water

Date Collected: 12/11/25
Date Received: 12/11/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: SHS0-01-KIT-IN-58-HCT
Lab Code: R2516770-004
Sample Matrix: Drinking Water

Date Collected: 12/11/25
Date Received: 12/11/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: SHS0-01-KIT-IN-58-T3
Lab Code: R2516770-005
Sample Matrix: Drinking Water

Date Collected: 12/11/25
Date Received: 12/11/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Labella Associates, PC
Project: Webster CSD - Schroeder/2251107

Service Request: R2516770

Sample Name: SHS0-01-KIT-IN-58-T3S
Lab Code: R2516770-006
Sample Matrix: Drinking Water

Date Collected: 12/11/25
Date Received: 12/11/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: SHS0-01-KIT-IN-58-T4
Lab Code: R2516770-007
Sample Matrix: Drinking Water

Date Collected: 12/11/25
Date Received: 12/11/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: SHS0-01-KIT-IN-58-T5
Lab Code: R2516770-008
Sample Matrix: Drinking Water

Date Collected: 12/11/25
Date Received: 12/11/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: SHS0-01-KIT-IN-58-PF1
Lab Code: R2516770-009
Sample Matrix: Drinking Water

Date Collected: 12/11/25
Date Received: 12/11/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: SHS0-01-KIT-IN-58-PF2
Lab Code: R2516770-010
Sample Matrix: Drinking Water

Date Collected: 12/11/25
Date Received: 12/11/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Labella Associates, PC
Project: Webster CSD - Schroeder/2251107

Service Request: R2516770

Sample Name: SHS0-01-KIT-IN-58-PF3
Lab Code: R2516770-011
Sample Matrix: Drinking Water

Date Collected: 12/11/25
Date Received: 12/11/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: SHS0-01-KIT-IN-58-T6
Lab Code: R2516770-012
Sample Matrix: Drinking Water

Date Collected: 12/11/25
Date Received: 12/11/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: SHS0-01-KIT-IN-58-T8
Lab Code: R2516770-013
Sample Matrix: Drinking Water

Date Collected: 12/11/25
Date Received: 12/11/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: SHS0-01-KIT-IN-58-T9
Lab Code: R2516770-014
Sample Matrix: Drinking Water

Date Collected: 12/11/25
Date Received: 12/11/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: SHS0-01-NO-IN-PO-T
Lab Code: R2516770-015
Sample Matrix: Drinking Water

Date Collected: 12/11/25
Date Received: 12/11/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Labella Associates, PC
Project: Webster CSD - Schroeder/2251107

Service Request: R2516770

Sample Name: SHS0-01-NO-IN-BR-T
Lab Code: R2516770-016
Sample Matrix: Drinking Water

Date Collected: 12/11/25
Date Received: 12/11/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: SHS0-01-HA-BY-NOE-DFL
Lab Code: R2516770-017
Sample Matrix: Drinking Water

Date Collected: 12/11/25
Date Received: 12/11/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: SHS0-01-HA-BY-NOE-BF
Lab Code: R2516770-018
Sample Matrix: Drinking Water

Date Collected: 12/11/25
Date Received: 12/11/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: SHS0-01-HA-BY-NOE-BFR
Lab Code: R2516770-019
Sample Matrix: Drinking Water

Date Collected: 12/11/25
Date Received: 12/11/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: SHS0-01-HA-BY-TR-DFL
Lab Code: R2516770-020
Sample Matrix: Drinking Water

Date Collected: 12/11/25
Date Received: 12/11/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Labella Associates, PC
Project: Webster CSD - Schroeder/2251107

Service Request: R2516770

Sample Name: SHS0-01-HA-BY-TR-BF
Lab Code: R2516770-021
Sample Matrix: Drinking Water

Date Collected: 12/11/25
Date Received: 12/11/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: SHS0-01-HA-BY-TR-DFR
Lab Code: R2516770-022
Sample Matrix: Drinking Water

Date Collected: 12/11/25
Date Received: 12/11/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: SHS0-01-TR-IN-S7-IM
Lab Code: R2516770-023
Sample Matrix: Drinking Water

Date Collected: 12/11/25
Date Received: 12/11/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: SHS0-01-MS-IN-N16-T
Lab Code: R2516770-024
Sample Matrix: Drinking Water

Date Collected: 12/11/25
Date Received: 12/11/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: SHS0-01-LIB-IN-N12-T
Lab Code: R2516770-025
Sample Matrix: Drinking Water

Date Collected: 12/11/25
Date Received: 12/11/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER



PREPARATION METHODS

The preparation methods associated with this report are found in these tables unless discussed in the case narrative.

INORGANIC

Water/Liquid Matrix

Analytical Method	Preparation Method
200.7 / 200.8	200.2
6010D	3005A/3010A
6020B	ILM05.3
9034 Sulfide Acid Soluble	9030B
SM 4500-CN-N-2016 Amenable and Residual Cyanide	SM 4500-CN-G and SM 4500-CN-B,C-2016
SM 4500-CN-E WAD Cyanide	SM 4500-CN-I

Solid/Soil/Non-Aqueous Matrix

Analytical Method	Preparation Method
6010D	3050B
6010D TCLP (1311) extract	3005A/3010A
6010D SPLP (1312) extract	3005A/3010A
7199	3060A
300.0 Anions/ 350.1/ 353.2/ SM 2320B/ SM 5210B/ 9056A Anions	DI extraction
For analytical methods not listed, the preparation method is the same as the analytical method reference.	

ORGANIC

Preparation Methods for Organic methods are listed in the header of the Results pages.

Regarding "Bulk/5035A":

For soil/solid samples submitted in soil jars for Volatiles analysis, the prep method is listed as "Bulk/5035A". The lab follows the closed-system EPA 5035A protocols once the sample is transferred to a sealed vial, but collection in bulk in soil jars does not follow the collection protocols listed in EPA 5035A. In accordance with the NYSDOH technical notice of October 2012, all results or reporting limits <200 ug/kg are to be considered estimated due to potential low bias.



Sample Results

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



Metals

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Schroeder/2251107
Sample Matrix: Drinking Water
Sample Name: SHS0-01-KIT-IN-58-T1
Lab Code: R2516770-001

Service Request: R2516770
Date Collected: 12/11/25 06:00
Date Received: 12/11/25 12:05
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	22.7	ug/L	1.0	1	01/05/26 18:25	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Schroeder/2251107
Sample Matrix: Drinking Water
Sample Name: SHS0-01-KIT-IN-58-T2
Lab Code: R2516770-002

Service Request: R2516770
Date Collected: 12/11/25 06:02
Date Received: 12/11/25 12:05
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	01/05/26 18:26	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Schroeder/2251107
Sample Matrix: Drinking Water
Sample Name: SHS0-01-KIT-IN-58-CT
Lab Code: R2516770-003

Service Request: R2516770
Date Collected: 12/11/25 06:04
Date Received: 12/11/25 12:05
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	01/05/26 18:28	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Schroeder/2251107
Sample Matrix: Drinking Water
Sample Name: SHS0-01-KIT-IN-58-HCT
Lab Code: R2516770-004

Service Request: R2516770
Date Collected: 12/11/25 06:08
Date Received: 12/11/25 12:05
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	01/05/26 18:29	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Schroeder/2251107
Sample Matrix: Drinking Water
Sample Name: SHS0-01-KIT-IN-58-T3
Lab Code: R2516770-005

Service Request: R2516770
Date Collected: 12/11/25 06:10
Date Received: 12/11/25 12:05
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.3	ug/L	1.0	1	01/05/26 18:33	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Schroeder/2251107
Sample Matrix: Drinking Water
Sample Name: SHS0-01-KIT-IN-58-T3S
Lab Code: R2516770-006

Service Request: R2516770
Date Collected: 12/11/25 06:11
Date Received: 12/11/25 12:05
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	01/05/26 18:35	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Schroeder/2251107
Sample Matrix: Drinking Water
Sample Name: SHS0-01-KIT-IN-58-T4
Lab Code: R2516770-007

Service Request: R2516770
Date Collected: 12/11/25 06:14
Date Received: 12/11/25 12:05
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	01/05/26 18:36	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Schroeder/2251107
Sample Matrix: Drinking Water
Sample Name: SHS0-01-KIT-IN-58-T5
Lab Code: R2516770-008

Service Request: R2516770
Date Collected: 12/11/25 06:15
Date Received: 12/11/25 12:05

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	01/05/26 18:38	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Schroeder/2251107
Sample Matrix: Drinking Water
Sample Name: SHS0-01-KIT-IN-58-PF1
Lab Code: R2516770-009

Service Request: R2516770
Date Collected: 12/11/25 06:18
Date Received: 12/11/25 12:05
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	01/05/26 18:39	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Schroeder/2251107
Sample Matrix: Drinking Water
Sample Name: SHS0-01-KIT-IN-58-PF2
Lab Code: R2516770-010

Service Request: R2516770
Date Collected: 12/11/25 06:19
Date Received: 12/11/25 12:05
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	01/05/26 18:40	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Schroeder/2251107
Sample Matrix: Drinking Water
Sample Name: SHS0-01-KIT-IN-58-PF3
Lab Code: R2516770-011

Service Request: R2516770
Date Collected: 12/11/25 06:22
Date Received: 12/11/25 12:05

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	2.7	ug/L	1.0	1	01/05/26 18:42	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Schroeder/2251107
Sample Matrix: Drinking Water
Sample Name: SHS0-01-KIT-IN-58-T6
Lab Code: R2516770-012

Service Request: R2516770
Date Collected: 12/11/25 06:23
Date Received: 12/11/25 12:05

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	01/05/26 18:43	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Schroeder/2251107
Sample Matrix: Drinking Water
Sample Name: SHS0-01-KIT-IN-58-T8
Lab Code: R2516770-013

Service Request: R2516770
Date Collected: 12/11/25 06:26
Date Received: 12/11/25 12:05
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.5	ug/L	1.0	1	01/05/26 18:45	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Schroeder/2251107
Sample Matrix: Drinking Water
Sample Name: SHS0-01-KIT-IN-58-T9
Lab Code: R2516770-014

Service Request: R2516770
Date Collected: 12/11/25 06:27
Date Received: 12/11/25 12:05
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	01/05/26 18:46	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Schroeder/2251107
Sample Matrix: Drinking Water
Sample Name: SHS0-01-NO-IN-PO-T
Lab Code: R2516770-015

Service Request: R2516770
Date Collected: 12/11/25 06:34
Date Received: 12/11/25 12:05
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	01/05/26 18:50	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Schroeder/2251107
Sample Matrix: Drinking Water
Sample Name: SHS0-01-NO-IN-BR-T
Lab Code: R2516770-016

Service Request: R2516770
Date Collected: 12/11/25 06:36
Date Received: 12/11/25 12:05
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	01/05/26 18:52	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Schroeder/2251107
Sample Matrix: Drinking Water
Sample Name: SHS0-01-HA-BY-NOE-DFL
Lab Code: R2516770-017

Service Request: R2516770
Date Collected: 12/11/25 06:37
Date Received: 12/11/25 12:05
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	01/05/26 18:53	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Schroeder/2251107
Sample Matrix: Drinking Water
Sample Name: SHS0-01-HA-BY-NOE-BF
Lab Code: R2516770-018

Service Request: R2516770
Date Collected: 12/11/25 06:38
Date Received: 12/11/25 12:05
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	01/05/26 18:54	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Schroeder/2251107
Sample Matrix: Drinking Water
Sample Name: SHS0-01-HA-BY-NOE-BFR
Lab Code: R2516770-019

Service Request: R2516770
Date Collected: 12/11/25 06:39
Date Received: 12/11/25 12:05
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	01/05/26 19:01	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Schroeder/2251107
Sample Matrix: Drinking Water
Sample Name: SHS0-01-HA-BY-TR-DFL
Lab Code: R2516770-020

Service Request: R2516770
Date Collected: 12/11/25 06:40
Date Received: 12/11/25 12:05
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	01/05/26 19:08	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Schroeder/2251107
Sample Matrix: Drinking Water
Sample Name: SHS0-01-HA-BY-TR-BF
Lab Code: R2516770-021

Service Request: R2516770
Date Collected: 12/11/25 06:41
Date Received: 12/11/25 12:05
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	01/05/26 19:10	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Schroeder/2251107
Sample Matrix: Drinking Water
Sample Name: SHS0-01-HA-BY-TR-DFR
Lab Code: R2516770-022

Service Request: R2516770
Date Collected: 12/11/25 06:42
Date Received: 12/11/25 12:05
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	2.1	ug/L	1.0	1	01/05/26 19:11	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Schroeder/2251107
Sample Matrix: Drinking Water
Sample Name: SHS0-01-TR-IN-S7-IM
Lab Code: R2516770-023

Service Request: R2516770
Date Collected: 12/11/25 06:44
Date Received: 12/11/25 12:05

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	01/05/26 19:12	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Schroeder/2251107
Sample Matrix: Drinking Water
Sample Name: SHS0-01-MS-IN-N16-T
Lab Code: R2516770-024

Service Request: R2516770
Date Collected: 12/11/25 06:51
Date Received: 12/11/25 12:05
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	2.7	ug/L	1.0	1	01/05/26 19:14	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Schroeder/2251107
Sample Matrix: Drinking Water
Sample Name: SHS0-01-LIB-IN-N12-T
Lab Code: R2516770-025

Service Request: R2516770
Date Collected: 12/11/25 06:52
Date Received: 12/11/25 12:05
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	01/05/26 19:15	



QC Summary Forms

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



Metals

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Schroeder/2251107
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2516770-MB1

Service Request: R2516770
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	01/05/26 18:17	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Schroeder/2251107
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2516770-MB2

Service Request: R2516770
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	01/05/26 18:58	

Client: Labella Associates, PC
Project: Webster CSD - Schroeder/2251107
Sample Matrix: Drinking Water

Service Request: R2516770
Date Collected: 12/11/25
Date Received: 12/11/25
Date Analyzed: 01/5/26

**Duplicate Matrix Spike Summary
Inorganic Parameters**

Sample Name: SHS0-01-HA-BY-NOE-BF
Lab Code: R2516770-018
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike R2516770-018MS		Result	Duplicate Matrix Spike R2516770-018DMS		% Rec Limits	RPD	RPD Limit
			Spike Amount	% Rec		Spike Amount	% Rec			
Lead, Total	1.0 U	19.3	20.0	97	15.1	20.0	76	70-130	25*	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Labella Associates, PC
Project: Webster CSD - Schroeder/2251107
Sample Matrix: Drinking Water

Service Request: R2516770
Date Collected: 12/11/25
Date Received: 12/11/25
Date Analyzed: 01/5/26

**Duplicate Matrix Spike Summary
Inorganic Parameters**

Sample Name: SHS0-01-HA-BY-NOE-BFR
Lab Code: R2516770-019
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike R2516770-019MS		Duplicate Matrix Spike R2516770-019DMS		% Rec Limits	RPD	RPD Limit	
			Spike Amount	% Rec	Result	Spike Amount				% Rec
Lead, Total	1.0 U	20.1	20.0	101	20.0	20.0	100	70-130	<1	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Labella Associates, PC
Project: Webster CSD - Schroeder/2251107
Sample Matrix: Drinking Water

Service Request: R2516770
Date Analyzed: 01/05/26

Lab Control Sample Summary
Inorganic Parameters

Units:ug/L
Basis:NA

Lab Control Sample
R2516770-LCS1

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	20.8	20.0	104	85-115

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Labella Associates, PC
Project: Webster CSD - Schroeder/2251107
Sample Matrix: Drinking Water

Service Request: R2516770
Date Analyzed: 01/05/26

Lab Control Sample Summary
Inorganic Parameters

Units:ug/L
Basis:NA

Lab Control Sample
R2516770-LCS2

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	18.1	20.0	90	85-115



January 07, 2026

Service Request No:R2516774

Cory Stamp
Labella Associates, PC
300 State Street, 2nd Floor
Suite 201
Rochester, NY 14614

Laboratory Results for: Webster CSD - Schroeder

Dear Cory,

Enclosed are the results of the sample(s) submitted to our laboratory December 11, 2025
For your reference, these analyses have been assigned our service request number **R2516774**.

All testing was performed according to our laboratory's quality assurance program and met the requirements of the TNI standards except as noted in the case narrative report. Any testing not included in the lab's accreditation is identified on a Non-Certified Analytes report. All results are intended to be considered in their entirety. ALS Environmental is not responsible for use of less than the complete report. Results apply only to the individual samples submitted to the lab for analysis, as listed in the report. The measurement uncertainty of the results included in this report is within that expected when using the prescribed method(s), and represented by Laboratory Control Sample control limits. Any events, such as QC failures or Holding Time exceedances, which may add to the uncertainty are explained in the report narrative or are flagged with qualifiers. The flags are explained in the Report Qualifiers and Definitions page of this report.

Please contact me if you have any questions. My extension is 7475. You may also contact me via email at Meghan.Pedro@alsglobal.com.

Respectfully submitted,

ALS Group USA, Corp. dba ALS Environmental

Meghan Pedro
Project Manager

ADDRESS 1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
PHONE +1 585 288 5380 | **FAX** +1 585 288 8475
ALS Group USA, Corp.
dba ALS Environmental



Narrative Documents

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



Client: Labella Associates, PC
Project: Webster CSD - Schroeder
Sample Matrix: Drinking Water

Service Request: R2516774
Date Received: 12/11/2025

CASE NARRATIVE

All analyses were performed consistent with the quality assurance program of ALS Environmental. This report contains analytical results for samples for the Tier II level requested by the client.

Sample Receipt:

Thirty five drinking water samples were received for analysis at ALS Environmental on 12/11/2025. Any discrepancies upon initial sample inspection are annotated on the sample receipt and preservation form included within this report. The samples were stored at minimum in accordance with the analytical method requirements.

Metals:

No significant anomalies were noted with this analysis.

A handwritten signature in black ink that reads "Meghan Pedro".

Approved by _____

Date 01/07/2026



SAMPLE DETECTION SUMMARY

This form includes only detections above the reporting levels. For a full listing of sample results, continue to the Sample Results section of this Report.

CLIENT ID: SHS-01-CONC-IN-SESA-T			Lab ID: R2516774-002			
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.3			1.0	ug/L	200.8

CLIENT ID: SHS-01-GOAL-IN-W11-T			Lab ID: R2516774-008			
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	2.2			1.0	ug/L	200.8

CLIENT ID: SHS-01-SEC-IN-E34-T			Lab ID: R2516774-020			
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	3.1			1.0	ug/L	200.8

CLIENT ID: SHS-02-RM-IN-W28-T			Lab ID: R2516774-021			
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	7.2			1.0	ug/L	200.8

CLIENT ID: SHS-02-FR-IN-W221-T			Lab ID: R2516774-024			
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	2.8			1.0	ug/L	200.8

CLIENT ID: SHS-02-OFF-IN-E202-T			Lab ID: R2516774-029			
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	3.3			1.0	ug/L	200.8



Sample Receipt Information

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

Client: Labella Associates, PC
Project: Webster CSD - Schroeder/2251107

Service Request:R2516774

SAMPLE CROSS-REFERENCE

<u>SAMPLE #</u>	<u>CLIENT SAMPLE ID</u>	<u>DATE</u>	<u>TIME</u>
R2516774-001	SHS-01-OFF-IN-W29-T	12/11/2025	0653
R2516774-002	SHS-01-CONC-IN-SESA-T	12/11/2025	0655
R2516774-003	SHS-01-HA-BY-W28-DF	12/11/2025	0659
R2516774-004	SHS-01-HA-BY-W28-BF	12/11/2025	0700
R2516774-005	SHS-01-FR-IN-W22-T	12/11/2025	0702
R2516774-006	SHS-01-HA-BY-W13-DF	12/11/2025	0705
R2516774-007	SHS-01-HA-BY-W13-BF	12/11/2025	0706
R2516774-008	SHS-01-GOAL-IN-W11-T	12/11/2025	0709
R2516774-009	SHS-01-KIT-IN-W5A-T	12/11/2025	0712
R2516774-010	SHS-01-HA-BY-W2B-DF	12/11/2025	0715
R2516774-011	SHS-01-HA-BY-W2B-BF	12/11/2025	0716
R2516774-012	SHS-01-KIT-IN-MO-T	12/11/2025	0722
R2516774-013	SHS-01-HA-BY-E4-DF	12/11/2025	0723
R2516774-014	SHS-01-HA-BY-E4-BF	12/11/2025	0724
R2516774-015	SHS-01-HA-BY-E18-DF	12/11/2025	0729
R2516774-016	SHS-01-HA-BY-E18-BF	12/11/2025	0730
R2516774-017	SHS-01-UPK-IN-E26-T	12/11/2025	0732
R2516774-018	SHS-01-HA-BY-E33-DF	12/11/2025	0736
R2516774-019	SHS-01-HA-BY-E33-BF	12/11/2025	0737
R2516774-020	SHS-01-SEC-IN-E34-T	12/11/2025	0739
R2516774-021	SHS-02-RM-IN-W28-T	12/11/2025	0740
R2516774-022	SHS-02-HA-BY-W227-DF	12/11/2025	0741
R2516774-023	SHS-02-HA-BY-W227-BF	12/11/2025	0742
R2516774-024	SHS-02-FR-IN-W221-T	12/11/2025	0744
R2516774-025	SHS-02-HA-BY-W211-DF	12/11/2025	0746
R2516774-026	SHS-02-HA-BY-W211-BF	12/11/2025	0747
R2516774-027	SHS-02-HA-BY-W200-DF	12/11/2025	0749
R2516774-028	SHS-01-HA-BY-W200-BF	12/11/2025	0750
R2516774-029	SHS-02-OFF-IN-E202-T	12/11/2025	0757
R2516774-030	SHS-02-HA-BY-E203-DF	12/11/2025	0757
R2516774-031	SHS-02-HA-BY-E203-BF	12/11/2025	0758
R2516774-032	SHS-02-HA-BY-E219-DF	12/11/2025	0759
R2516774-033	SHS-02-HA-BY-E219-BF	12/11/2025	0800
R2516774-034	SHS-02-HA-BY-E234-DF	12/11/2025	0805
R2516774-035	SHS-02-HA-BY-E234-BF	12/11/2025	0806



Chain of Custody / Analytical Request Form

1565 Jefferson Road, Building 300, Suite 360 • Rochester, NY 14623 • +1 585 288 5380 • alsglobal.com

088772

Cr6 7196/SM3500; BOD; CT; Cr6 7199/218.6
353.2 NO2; OPO4; 300/9056A NO2/NO3; Sulfide
RES Cl; DO; Ferrous Iron; Sulfite; UV 254; CHL A
Color; Turbidity; Set Solids

Report To:		ALL SHADED AREAS MUST BE COMPLETED BY THE CLIENT / SAMPLER			Preservative →		0-None, 1-HCl, 2-HNO3, 3-H2SO4, 4-NaOH, 5-ZnAc, 6-MeOH, 7-NaHSO4, 8-Other											
Company: <i>LeBella</i>		Project Name: <i>Webster CSD - Schroeder</i>			GW WW SW DW S L NA	Matrix	Number of Containers	MS/MSD?	↓ Tests / Analytes Requested ↓									
Contact: <i>Cory Stump</i>		Project Number: <i>2251107</i>							GC/MS VOA - 8260 • 624 • 524 • TCLP	GC/MS SVOA - 8270 • 625 • TCLP	Pesticides - 8081 • 608 • TCLP	PCBs - 8082 • 608	Herbicides - 8151 • TCLP	Metals, Total - Select Below	Metals, Dissolved - Field / In-Lab Filter	<i>EPA 200. (LIPW)</i>		
Email: <i>cstump@lebellapc.com</i>		ALS Quote #:		DOD? Y / N														
Phone:		Sampler's Signature: <i>[Signature]</i>																
Address:		Email CC:																
		Email CC:																
		State Samples Collected (Circle or Write): NY, MA, PA, CT, Other:																
Lab ID (ALS)	Sample Collection Information:																	
	Sample ID / Name of Collection Point:	Date	Time															
	<i>See attached spreadsheets</i>	<i>12/11</i>																
Metals: RCRA 8 • PP 13 • TAL 23 • TCLP • Part 375 • Other (List)				Turnaround Requirements			Report Requirements			Invoice To: <input type="checkbox"/> Same as Report To								
VOA/SVOA Report List: TCL • BTEX • TCLP • CP-51/Stars • THM • Part 375 • Other (List)				*Rush (Surcharges Apply) *Subject to Availability *Please Check with your PM*			Tier II/Cat A - Results/QC Tier IV/Cat B - Data Validation Report w/. Data			PO #:								
Special Instructions / Comments:				Standard (10 Business Days) TAT / Date Required:			EDD: Yes ___ No ___ EDD Type:			Company:								
										Contact:								
										Email:								
										Phone:								
Relinquished By / Company Name		Date	Time	Received By / Company Name		Address												
<i>Cory Stump</i>		<i>12/11/25</i>	<i>12:05</i>	<i>Michelle Munn ALS</i>		R2516774 5 Lebella Associates, PC Webster CSD - Schroeder												
						Page ___ of ___												

Sample Number	Location	Outlet Type	Detail	Date	Time
SHS-01-OFF-IN-W29-T	Office W29	Tap		12/11	0653
SHS-01-CONC-IN-SESA-T	Concessions SESA	Tap			0655
SHS-01-HA-BY-W28-DF	Hallway by W28	DF			0659
SHS-01-HA-BY-W28-BF	" "	BF			0700
SHS-01-FR-IN-W22-T	Faculty Room W22	Tap			0702
SHS-01-HA-BY-W13-DF	Hallway by W13	DF			0705
SHS-01-HA-BY-W13-BF	" "	BF			0706
SHS-01-GOAL-IN-W11-T	Goal Room W11	T			0709
SHS-01-KIT-IN-W5A-T	Classroom Kitchen W5A	T			0712
SHS-01-HA-BY-W2B-DF	Hallway by W2B	DF			0715
SHS-01-HA-BY-W2B-BF	" "	BF			0716
SHS-01-KIT-IN-MO-T	Main Office Kitchen	T			0722
SHS-01-HA-BY-E4-DF	Hallway by E4	DF			0723
SHS-01-HA-BY-E4-BF	" "	BF			0724
SHS-01-HA-BY-E18-DF	Hallway by E18	DF			0729
SHS-01-HA-BY-E18-BF	" "	BF			0730
SHS-01-UPK-IN-E26-T	UPK Classroom E26	T			0732
SHS-01-HA-BY-E33-DF	Hallway by E33	DF			0736
SHS-01-HA-BY-E33-BF	Hallway by E33	BF			0737
SHS-01-SEC-IN-E34-T	Security E34	T			0739
SHS-02-PM-IN-W28-T	W28	T			0740
SHS-02-HA-BY-W227-DF	Hallway by W227	DF			0741
SHS-02-HA-BY-W227-BF	" "	BF			0742
SHS-02-FR-IN-W221-T	Faculty Room W221	T			0744
SHS-02-HA-BY-W211-DF	Hallway by W211	DF		↓	0746


Sample Number	Location	Outlet Type	Detail	Date	Time
SHS-02-HA-BY-W211-BF	Hallway by W211	BF		12/11	0747
SHS-02-HA-BY-W200-DF	Hallway by W200	DF		↓	0749
SHS-02-HA-BY-W200-BF	"	BF			0750
SHS-02-OFF-IN-E202-T	Office E202	T			0757
SHS-02-HA-OF-E203-DF	Hallway by E203	DF			0757
SHS-02-HA-BY-E203-BF	"	BF			0758
SHS-02-HA-BY-E219-DF	Hallway by E219	DF			0759
SHS-02-HA-BY-E219-BF	Hallway by E219	BF			0800
SHS-02-HA-BY-E234-DF	Hallway by E234	DF			0805
SHS-02-HA-BY-E234-BF	"	BF			0806



R2516774
Labella Associates, PC
Webster CSD - Schroeder

5

Cooler Receipt and Preservation Check Fo



Project/Client Labella Folder Number _____

Cooler received on 12/11/25 by: RM COURIER: ALS UPS FEDEX VELOCITY CLIENT

1	Were Custody seals on outside of cooler?	Y <input type="checkbox"/> N <input checked="" type="checkbox"/>
2	Custody papers properly completed (ink, signed)?	Y <input checked="" type="checkbox"/> N <input type="checkbox"/>
3	Did all bottles arrive in good condition (unbroken)?	Y <input checked="" type="checkbox"/> N <input type="checkbox"/>
4	Circle: Wet Ice Dry Ice Gel packs present?	Y <input checked="" type="checkbox"/> N <input type="checkbox"/>

5a	Did VOA vials have sig* bubbles?	Y <input type="checkbox"/> N <input checked="" type="checkbox"/> NA <input type="checkbox"/>
5b	Sig* bubbles: Alk?	Y <input type="checkbox"/> N <input checked="" type="checkbox"/> NA <input type="checkbox"/>
	Sulfide?	Y <input type="checkbox"/> N <input checked="" type="checkbox"/> NA <input type="checkbox"/>
6	Where did the bottles originate?	ALS/ROC <u>CLIENT</u>
7	Soil VOA received as:	Bulk Encore 5035set <u>NA</u>

8. Temperature Readings Date: 12/11/25 Time: 12:08 ID: IR#11 IR#12 IR#13 From: Temp Blank Sample Bottle

Temp (°C)	19.3						
Within 0-6°C?	Y <input checked="" type="checkbox"/> N <input type="checkbox"/>	Y <input type="checkbox"/> N <input type="checkbox"/>	Y <input type="checkbox"/> N <input type="checkbox"/>	Y <input type="checkbox"/> N <input type="checkbox"/>	Y <input type="checkbox"/> N <input type="checkbox"/>	Y <input type="checkbox"/> N <input type="checkbox"/>	Y <input type="checkbox"/> N <input type="checkbox"/>
If <0°C, were samples frozen?	Y <input type="checkbox"/> N <input type="checkbox"/>	Y <input type="checkbox"/> N <input type="checkbox"/>	Y <input type="checkbox"/> N <input type="checkbox"/>	Y <input type="checkbox"/> N <input type="checkbox"/>	Y <input type="checkbox"/> N <input type="checkbox"/>	Y <input type="checkbox"/> N <input type="checkbox"/>	Y <input type="checkbox"/> N <input type="checkbox"/>

If out of Temperature, note packing/ice condition: _____ Ice melted Poorly Packed (described below) Same Day Rule
& Client Approval to Run Samples: _____ Standing Approval Client aware at drop-off Client notified by: _____

All samples held in storage location: SMD by RM on 12/11 at 12:08
5035 samples placed in storage location: _____ by _____ on _____ at _____ within 48 hours of sampling? Y N

Cooler Breakdown/Preservation Check**: Date: 12/15 Time: 1923 by: AG

- 9. Were all bottle labels complete (i.e. analysis, preservation, etc.)? AG 12/15 YES NO
- 10. Did all bottle labels and tags agree with custody papers? YES NO
- 11. Were correct containers used for the tests indicated? YES NO
- 12. Were 5035 vials acceptable (no extra labels, not leaking)? YES NO
- 13. Were dissolved metals filtered in the field? YES NO NA

pH	Lot of test paper	Reagent	Preserved?		Lot Received	Exp	Sample ID Adjusted	Vol. Added	Lot Added	Final pH
			Yes	No						
≥12		NaOH								
≤2	<u>12/15</u>	HNO ₃		<u>x</u>	<u>Client Bottles</u>		<u>All</u>	<u>4ml</u>		<u>6.2</u>
≤2		H ₂ SO ₄								
<4		NaHSO ₄								
5-9		For 608pest			No=Notify for 3day					
Residual Chlorine (-)		For CN, Phenol, 625, 608pest, 522			If +, contact PM to add Na ₂ S ₂ O ₃ (625, 608, CN), ascorbic (phenol).					
		Na ₂ S ₂ O ₃								
		ZnAcetate	-	-						
		HCl	**	**						

**VOAs and 1664 Not to be tested before analysis. Otherwise, all bottles of all samples with chemical preservatives are checked (not just representatives).

Bottle lot numbers: Client Bottles
Explain all Discrepancies/ Other Comments: _____

HPROD	BULK
HTR	FLDT
SUB	HGFB
ALS	LL3541

Labels secondary reviewed by: AG *significant air bubbles: VOA > 5-6 mm : WC > 1 in. diameter



Miscellaneous Forms

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



REPORT QUALIFIERS AND DEFINITIONS

- | | |
|---|--|
| <p>U Analyte was analyzed for but not detected. The sample quantitation limit has been corrected for dilution and for percent moisture, unless otherwise noted in the case narrative.</p> <p>J Estimated value due to either being a Tentatively Identified Compound (TIC) or that the concentration is between the MRL and the MDL. Concentrations are not verified within the linear range of the calibration. For DoD: concentration >40% difference between two GC columns (pesticides/Aroclors).</p> <p>B Analyte was also detected in the associated method blank at a concentration that may have contributed to the sample result.</p> <p>E Inorganics- Concentration is estimated due to the serial dilution was outside control limits.</p> <p>E Organics- Concentration has exceeded the calibration range for that specific analysis.</p> <p>D Concentration is a result of a dilution, typically a secondary analysis of the sample due to exceeding the calibration range or that a surrogate has been diluted out of the sample and cannot be assessed.</p> <p>* Indicates that a quality control parameter has exceeded laboratory limits. Under the “Notes” column of the Form I, this qualifier denotes analysis was performed out of Holding Time.</p> <p>H Analysis was performed out of hold time for tests that have an “immediate” hold time criteria.</p> <p># Spike was diluted out.</p> | <p>+ Correlation coefficient for MSA is <0.995.</p> <p>N Inorganics- Matrix spike recovery was outside laboratory limits.</p> <p>N Organics- Presumptive evidence of a compound (reported as a TIC) based on the MS library search.</p> <p>S Concentration has been determined using Method of Standard Additions (MSA).</p> <p>W Post-Digestion Spike recovery is outside control limits and the sample absorbance is <50% of the spike absorbance.</p> <p>P Concentration >40% difference between the two GC columns.</p> <p>C Confirmed by GC/MS</p> <p>Q DoD reports: indicates a pesticide/Aroclor is not confirmed ($\geq 100\%$ Difference between two GC columns).</p> <p>X See Case Narrative for discussion.</p> <p>MRL Method Reporting Limit. Also known as:</p> <p>LOQ Limit of Quantitation (LOQ)
The lowest concentration at which the method analyte may be reliably quantified under the method conditions.</p> <p>MDL Method Detection Limit. A statistical value derived from a study designed to provide the lowest concentration that will be detected 99% of the time. Values between the MDL and MRL are estimated (see J qualifier).</p> <p>LOD Limit of Detection. A value at or above the MDL which has been verified to be detectable.</p> <p>ND Non-Detect. Analyte was not detected at the concentration listed. Same as U qualifier.</p> |
|---|--|

Rochester Lab ID # for State Accreditations¹



NELAP States
Florida ID # E87674
New Hampshire ID # 2941
New York ID # 10145
Pennsylvania ID# 68-786
Texas ID#T104704581
Virginia #460167

Non-NELAP States
Connecticut ID #PH0556
Delaware Approved
Maine ID #NY01587
North Carolina #36701
North Carolina #676
Rhode Island LAO00333

¹ Analyses were performed according to our laboratory’s NELAP-approved quality assurance program and any applicable state or agency requirements. The test results meet requirements of the current NELAP/TNI standards or state or agency requirements, where applicable, except as noted in the case narrative. Since not all analyte/method/matrix combinations are offered for state/NELAC accreditation, this report may contain results which are not accredited. For a specific list of accredited analytes, contact the laboratory. To verify NH accredited analytes, go to <https://www4.des.state.nh.us/CertifiedLabs/Certified-Method.aspx>.

ALS Laboratory Group

Acronyms

ASTM	American Society for Testing and Materials
A2LA	American Association for Laboratory Accreditation
CARB	California Air Resources Board
CAS Number	Chemical Abstract Service registry Number
CFC	Chlorofluorocarbon
CFU	Colony-Forming Unit
DEC	Department of Environmental Conservation
DEQ	Department of Environmental Quality
DHS	Department of Health Services
DOE	Department of Ecology
DOH	Department of Health
EPA	U. S. Environmental Protection Agency
ELAP	Environmental Laboratory Accreditation Program
GC	Gas Chromatography
GC/MS	Gas Chromatography/Mass Spectrometry
LUFT	Leaking Underground Fuel Tank
M	Modified
MCL	Maximum Contaminant Level is the highest permissible concentration of a substance allowed in drinking water as established by the USEPA.
MDL	Method Detection Limit
MPN	Most Probable Number
MRL	Method Reporting Limit
NA	Not Applicable
NC	Not Calculated
NCASI	National Council of the Paper Industry for Air and Stream Improvement
ND	Not Detected
NIOSH	National Institute for Occupational Safety and Health
PQL	Practical Quantitation Limit
RCRA	Resource Conservation and Recovery Act
SIM	Selected Ion Monitoring
TPH	Total Petroleum Hydrocarbons
tr	Trace level is the concentration of an analyte that is less than the PQL but greater than or equal to the MDL.

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Labella Associates, PC
Project: Webster CSD - Schroeder/2251107

Service Request: R2516774

Sample Name: SHS-01-OFF-IN-W29-T
Lab Code: R2516774-001
Sample Matrix: Drinking Water

Date Collected: 12/11/25
Date Received: 12/11/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: SHS-01-CONC-IN-SESA-T
Lab Code: R2516774-002
Sample Matrix: Drinking Water

Date Collected: 12/11/25
Date Received: 12/11/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: SHS-01-HA-BY-W28-DF
Lab Code: R2516774-003
Sample Matrix: Drinking Water

Date Collected: 12/11/25
Date Received: 12/11/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: SHS-01-HA-BY-W28-BF
Lab Code: R2516774-004
Sample Matrix: Drinking Water

Date Collected: 12/11/25
Date Received: 12/11/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: SHS-01-FR-IN-W22-T
Lab Code: R2516774-005
Sample Matrix: Drinking Water

Date Collected: 12/11/25
Date Received: 12/11/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Labella Associates, PC
Project: Webster CSD - Schroeder/2251107

Service Request: R2516774

Sample Name: SHS-01-HA-BY-W13-DF
Lab Code: R2516774-006
Sample Matrix: Drinking Water

Date Collected: 12/11/25
Date Received: 12/11/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: SHS-01-HA-BY-W13-BF
Lab Code: R2516774-007
Sample Matrix: Drinking Water

Date Collected: 12/11/25
Date Received: 12/11/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: SHS-01-GOAL-IN-W11-T
Lab Code: R2516774-008
Sample Matrix: Drinking Water

Date Collected: 12/11/25
Date Received: 12/11/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: SHS-01-KIT-IN-W5A-T
Lab Code: R2516774-009
Sample Matrix: Drinking Water

Date Collected: 12/11/25
Date Received: 12/11/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: SHS-01-HA-BY-W2B-DF
Lab Code: R2516774-010
Sample Matrix: Drinking Water

Date Collected: 12/11/25
Date Received: 12/11/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Labella Associates, PC
Project: Webster CSD - Schroeder/2251107

Service Request: R2516774

Sample Name: SHS-01-HA-BY-W2B-BF
Lab Code: R2516774-011
Sample Matrix: Drinking Water

Date Collected: 12/11/25
Date Received: 12/11/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: SHS-01-KIT-IN-MO-T
Lab Code: R2516774-012
Sample Matrix: Drinking Water

Date Collected: 12/11/25
Date Received: 12/11/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: SHS-01-HA-BY-E4-DF
Lab Code: R2516774-013
Sample Matrix: Drinking Water

Date Collected: 12/11/25
Date Received: 12/11/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: SHS-01-HA-BY-E4-BF
Lab Code: R2516774-014
Sample Matrix: Drinking Water

Date Collected: 12/11/25
Date Received: 12/11/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: SHS-01-HA-BY-E18-DF
Lab Code: R2516774-015
Sample Matrix: Drinking Water

Date Collected: 12/11/25
Date Received: 12/11/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Labella Associates, PC
Project: Webster CSD - Schroeder/2251107

Service Request: R2516774

Sample Name: SHS-01-HA-BY-E18-BF
Lab Code: R2516774-016
Sample Matrix: Drinking Water

Date Collected: 12/11/25
Date Received: 12/11/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: SHS-01-UPK-IN-E26-T
Lab Code: R2516774-017
Sample Matrix: Drinking Water

Date Collected: 12/11/25
Date Received: 12/11/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: SHS-01-HA-BY-E33-DF
Lab Code: R2516774-018
Sample Matrix: Drinking Water

Date Collected: 12/11/25
Date Received: 12/11/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: SHS-01-HA-BY-E33-BF
Lab Code: R2516774-019
Sample Matrix: Drinking Water

Date Collected: 12/11/25
Date Received: 12/11/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: SHS-01-SEC-IN-E34-T
Lab Code: R2516774-020
Sample Matrix: Drinking Water

Date Collected: 12/11/25
Date Received: 12/11/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Labella Associates, PC
Project: Webster CSD - Schroeder/2251107

Service Request: R2516774

Sample Name: SHS-02-RM-IN-W28-T
Lab Code: R2516774-021
Sample Matrix: Drinking Water

Date Collected: 12/11/25
Date Received: 12/11/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: SHS-02-HA-BY-W227-DF
Lab Code: R2516774-022
Sample Matrix: Drinking Water

Date Collected: 12/11/25
Date Received: 12/11/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: SHS-02-HA-BY-W227-BF
Lab Code: R2516774-023
Sample Matrix: Drinking Water

Date Collected: 12/11/25
Date Received: 12/11/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: SHS-02-FR-IN-W221-T
Lab Code: R2516774-024
Sample Matrix: Drinking Water

Date Collected: 12/11/25
Date Received: 12/11/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: SHS-02-HA-BY-W211-DF
Lab Code: R2516774-025
Sample Matrix: Drinking Water

Date Collected: 12/11/25
Date Received: 12/11/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Labella Associates, PC
Project: Webster CSD - Schroeder/2251107

Service Request: R2516774

Sample Name: SHS-02-HA-BY-W211-BF
Lab Code: R2516774-026
Sample Matrix: Drinking Water

Date Collected: 12/11/25
Date Received: 12/11/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: SHS-02-HA-BY-W200-DF
Lab Code: R2516774-027
Sample Matrix: Drinking Water

Date Collected: 12/11/25
Date Received: 12/11/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: SHS-01-HA-BY-W200-BF
Lab Code: R2516774-028
Sample Matrix: Drinking Water

Date Collected: 12/11/25
Date Received: 12/11/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: SHS-02-OFF-IN-E202-T
Lab Code: R2516774-029
Sample Matrix: Drinking Water

Date Collected: 12/11/25
Date Received: 12/11/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: SHS-02-HA-BY-E203-DF
Lab Code: R2516774-030
Sample Matrix: Drinking Water

Date Collected: 12/11/25
Date Received: 12/11/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Labella Associates, PC
Project: Webster CSD - Schroeder/2251107

Service Request: R2516774

Sample Name: SHS-02-HA-BY-E203-BF
Lab Code: R2516774-031
Sample Matrix: Drinking Water

Date Collected: 12/11/25
Date Received: 12/11/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: SHS-02-HA-BY-E219-DF
Lab Code: R2516774-032
Sample Matrix: Drinking Water

Date Collected: 12/11/25
Date Received: 12/11/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: SHS-02-HA-BY-E219-BF
Lab Code: R2516774-033
Sample Matrix: Drinking Water

Date Collected: 12/11/25
Date Received: 12/11/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: SHS-02-HA-BY-E234-BF
Lab Code: R2516774-034
Sample Matrix: Drinking Water

Date Collected: 12/11/25
Date Received: 12/11/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: SHS-02-HA-BY-E234-BF
Lab Code: R2516774-035
Sample Matrix: Drinking Water

Date Collected: 12/11/25
Date Received: 12/11/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER



PREPARATION METHODS

The preparation methods associated with this report are found in these tables unless discussed in the case narrative.

INORGANIC

Water/Liquid Matrix

Analytical Method	Preparation Method
200.7 / 200.8	200.2
6010D	3005A/3010A
6020B	ILM05.3
9034 Sulfide Acid Soluble	9030B
SM 4500-CN-N-2016 Amenable and Residual Cyanide	SM 4500-CN-G and SM 4500-CN-B,C-2016
SM 4500-CN-E WAD Cyanide	SM 4500-CN-I

Solid/Soil/Non-Aqueous Matrix

Analytical Method	Preparation Method
6010D	3050B
6010D TCLP (1311) extract	3005A/3010A
6010D SPLP (1312) extract	3005A/3010A
7199	3060A
300.0 Anions/ 350.1/ 353.2/ SM 2320B/ SM 5210B/ 9056A Anions	DI extraction
For analytical methods not listed, the preparation method is the same as the analytical method reference.	

ORGANIC

Preparation Methods for Organic methods are listed in the header of the Results pages.

Regarding "Bulk/5035A":

For soil/solid samples submitted in soil jars for Volatiles analysis, the prep method is listed as "Bulk/5035A". The lab follows the closed-system EPA 5035A protocols once the sample is transferred to a sealed vial, but collection in bulk in soil jars does not follow the collection protocols listed in EPA 5035A. In accordance with the NYSDOH technical notice of October 2012, all results or reporting limits <200 ug/kg are to be considered estimated due to potential low bias.



Sample Results

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



Metals

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Schroeder/2251107
Sample Matrix: Drinking Water
Sample Name: SHS-01-OFF-IN-W29-T
Lab Code: R2516774-001

Service Request: R2516774
Date Collected: 12/11/25 06:53
Date Received: 12/11/25 12:05

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	01/05/26 19:17	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Schroeder/2251107
Sample Matrix: Drinking Water
Sample Name: SHS-01-CONC-IN-SESA-T
Lab Code: R2516774-002

Service Request: R2516774
Date Collected: 12/11/25 06:55
Date Received: 12/11/25 12:05
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.3	ug/L	1.0	1	01/05/26 19:18	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Schroeder/2251107
Sample Matrix: Drinking Water
Sample Name: SHS-01-HA-BY-W28-DF
Lab Code: R2516774-003

Service Request: R2516774
Date Collected: 12/11/25 06:59
Date Received: 12/11/25 12:05

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	01/05/26 19:19	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Schroeder/2251107
Sample Matrix: Drinking Water
Sample Name: SHS-01-HA-BY-W28-BF
Lab Code: R2516774-004

Service Request: R2516774
Date Collected: 12/11/25 07:00
Date Received: 12/11/25 12:05
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	01/05/26 19:24	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Schroeder/2251107
Sample Matrix: Drinking Water
Sample Name: SHS-01-FR-IN-W22-T
Lab Code: R2516774-005

Service Request: R2516774
Date Collected: 12/11/25 07:02
Date Received: 12/11/25 12:05

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	01/05/26 19:25	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Schroeder/2251107
Sample Matrix: Drinking Water
Sample Name: SHS-01-HA-BY-W13-DF
Lab Code: R2516774-006

Service Request: R2516774
Date Collected: 12/11/25 07:05
Date Received: 12/11/25 12:05

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	01/05/26 19:26	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Schroeder/2251107
Sample Matrix: Drinking Water
Sample Name: SHS-01-HA-BY-W13-BF
Lab Code: R2516774-007

Service Request: R2516774
Date Collected: 12/11/25 07:06
Date Received: 12/11/25 12:05
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	01/05/26 19:28	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Schroeder/2251107
Sample Matrix: Drinking Water
Sample Name: SHS-01-GOAL-IN-W11-T
Lab Code: R2516774-008

Service Request: R2516774
Date Collected: 12/11/25 07:09
Date Received: 12/11/25 12:05
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	2.2	ug/L	1.0	1	01/05/26 19:29	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Schroeder/2251107
Sample Matrix: Drinking Water
Sample Name: SHS-01-KIT-IN-W5A-T
Lab Code: R2516774-009

Service Request: R2516774
Date Collected: 12/11/25 07:12
Date Received: 12/11/25 12:05

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	01/05/26 19:31	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Schroeder/2251107
Sample Matrix: Drinking Water
Sample Name: SHS-01-HA-BY-W2B-DF
Lab Code: R2516774-010

Service Request: R2516774
Date Collected: 12/11/25 07:15
Date Received: 12/11/25 12:05
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	01/05/26 19:32	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Schroeder/2251107
Sample Matrix: Drinking Water
Sample Name: SHS-01-HA-BY-W2B-BF
Lab Code: R2516774-011

Service Request: R2516774
Date Collected: 12/11/25 07:16
Date Received: 12/11/25 12:05
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	01/05/26 19:33	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Schroeder/2251107
Sample Matrix: Drinking Water
Sample Name: SHS-01-KIT-IN-MO-T
Lab Code: R2516774-012

Service Request: R2516774
Date Collected: 12/11/25 07:22
Date Received: 12/11/25 12:05
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	01/05/26 19:35	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Schroeder/2251107
Sample Matrix: Drinking Water
Sample Name: SHS-01-HA-BY-E4-DF
Lab Code: R2516774-013

Service Request: R2516774
Date Collected: 12/11/25 07:23
Date Received: 12/11/25 12:05
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	01/05/26 19:36	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Schroeder/2251107
Sample Matrix: Drinking Water
Sample Name: SHS-01-HA-BY-E4-BF
Lab Code: R2516774-014

Service Request: R2516774
Date Collected: 12/11/25 07:24
Date Received: 12/11/25 12:05
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	01/05/26 19:49	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Schroeder/2251107
Sample Matrix: Drinking Water
Sample Name: SHS-01-HA-BY-E18-DF
Lab Code: R2516774-015

Service Request: R2516774
Date Collected: 12/11/25 07:29
Date Received: 12/11/25 12:05
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	01/05/26 19:53	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Schroeder/2251107
Sample Matrix: Drinking Water
Sample Name: SHS-01-HA-BY-E18-BF
Lab Code: R2516774-016

Service Request: R2516774
Date Collected: 12/11/25 07:30
Date Received: 12/11/25 12:05
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	01/05/26 19:54	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Schroeder/2251107
Sample Matrix: Drinking Water
Sample Name: SHS-01-UPK-IN-E26-T
Lab Code: R2516774-017

Service Request: R2516774
Date Collected: 12/11/25 07:32
Date Received: 12/11/25 12:05

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	01/05/26 19:56	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Schroeder/2251107
Sample Matrix: Drinking Water
Sample Name: SHS-01-HA-BY-E33-DF
Lab Code: R2516774-018

Service Request: R2516774
Date Collected: 12/11/25 07:36
Date Received: 12/11/25 12:05
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	01/05/26 19:57	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Schroeder/2251107
Sample Matrix: Drinking Water
Sample Name: SHS-01-HA-BY-E33-BF
Lab Code: R2516774-019

Service Request: R2516774
Date Collected: 12/11/25 07:37
Date Received: 12/11/25 12:05
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	01/05/26 19:58	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Schroeder/2251107
Sample Matrix: Drinking Water
Sample Name: SHS-01-SEC-IN-E34-T
Lab Code: R2516774-020

Service Request: R2516774
Date Collected: 12/11/25 07:39
Date Received: 12/11/25 12:05
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	3.1	ug/L	1.0	1	01/05/26 20:02	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Schroeder/2251107
Sample Matrix: Drinking Water
Sample Name: SHS-02-RM-IN-W28-T
Lab Code: R2516774-021

Service Request: R2516774
Date Collected: 12/11/25 07:40
Date Received: 12/11/25 12:05
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	7.2	ug/L	1.0	1	01/05/26 20:04	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Schroeder/2251107
Sample Matrix: Drinking Water
Sample Name: SHS-02-HA-BY-W227-DF
Lab Code: R2516774-022

Service Request: R2516774
Date Collected: 12/11/25 07:41
Date Received: 12/11/25 12:05

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	01/05/26 20:05	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Schroeder/2251107
Sample Matrix: Drinking Water
Sample Name: SHS-02-HA-BY-W227-BF
Lab Code: R2516774-023

Service Request: R2516774
Date Collected: 12/11/25 07:42
Date Received: 12/11/25 12:05
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	01/05/26 20:07	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Schroeder/2251107
Sample Matrix: Drinking Water
Sample Name: SHS-02-FR-IN-W221-T
Lab Code: R2516774-024

Service Request: R2516774
Date Collected: 12/11/25 07:44
Date Received: 12/11/25 12:05
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	2.8	ug/L	1.0	1	01/05/26 20:08	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Schroeder/2251107
Sample Matrix: Drinking Water
Sample Name: SHS-02-HA-BY-W211-DF
Lab Code: R2516774-025

Service Request: R2516774
Date Collected: 12/11/25 07:46
Date Received: 12/11/25 12:05
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	01/05/26 20:09	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Schroeder/2251107
Sample Matrix: Drinking Water
Sample Name: SHS-02-HA-BY-W211-BF
Lab Code: R2516774-026

Service Request: R2516774
Date Collected: 12/11/25 07:47
Date Received: 12/11/25 12:05
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	01/05/26 20:11	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Schroeder/2251107
Sample Matrix: Drinking Water
Sample Name: SHS-02-HA-BY-W200-DF
Lab Code: R2516774-027

Service Request: R2516774
Date Collected: 12/11/25 07:49
Date Received: 12/11/25 12:05
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	01/05/26 20:12	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Schroeder/2251107
Sample Matrix: Drinking Water
Sample Name: SHS-01-HA-BY-W200-BF
Lab Code: R2516774-028

Service Request: R2516774
Date Collected: 12/11/25 07:50
Date Received: 12/11/25 12:05
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	01/05/26 20:14	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Schroeder/2251107
Sample Matrix: Drinking Water
Sample Name: SHS-02-OFF-IN-E202-T
Lab Code: R2516774-029

Service Request: R2516774
Date Collected: 12/11/25 07:57
Date Received: 12/11/25 12:05
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	3.3	ug/L	1.0	1	01/05/26 20:15	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Schroeder/2251107
Sample Matrix: Drinking Water
Sample Name: SHS-02-HA-BY-E203-DF
Lab Code: R2516774-030

Service Request: R2516774
Date Collected: 12/11/25 07:57
Date Received: 12/11/25 12:05
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	01/05/26 20:19	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Schroeder/2251107
Sample Matrix: Drinking Water
Sample Name: SHS-02-HA-BY-E203-BF
Lab Code: R2516774-031

Service Request: R2516774
Date Collected: 12/11/25 07:58
Date Received: 12/11/25 12:05
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	01/05/26 20:20	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Schroeder/2251107
Sample Matrix: Drinking Water
Sample Name: SHS-02-HA-BY-E219-DF
Lab Code: R2516774-032

Service Request: R2516774
Date Collected: 12/11/25 07:59
Date Received: 12/11/25 12:05
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	01/05/26 20:22	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Schroeder/2251107
Sample Matrix: Drinking Water
Sample Name: SHS-02-HA-BY-E219-BF
Lab Code: R2516774-033

Service Request: R2516774
Date Collected: 12/11/25 08:00
Date Received: 12/11/25 12:05
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	01/05/26 20:23	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Schroeder/2251107
Sample Matrix: Drinking Water
Sample Name: SHS-02-HA-BY-E234-DF
Lab Code: R2516774-034

Service Request: R2516774
Date Collected: 12/11/25 08:05
Date Received: 12/11/25 12:05
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	01/05/26 20:30	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Schroeder/2251107
Sample Matrix: Drinking Water
Sample Name: SHS-02-HA-BY-E234-BF
Lab Code: R2516774-035

Service Request: R2516774
Date Collected: 12/11/25 08:06
Date Received: 12/11/25 12:05
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	01/05/26 20:37	



QC Summary Forms

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



Metals

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Schroeder/2251107
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2516774-MB1

Service Request: R2516774
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	01/05/26 18:58	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Schroeder/2251107
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2516774-MB2

Service Request: R2516774
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	01/05/26 19:46	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Schroeder/2251107
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2516774-MB3

Service Request: R2516774
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	01/05/26 20:27	

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Labella Associates, PC
Project: Webster CSD - Schroeder/2251107
Sample Matrix: Drinking Water

Service Request: R2516774
Date Collected: 12/11/25
Date Received: 12/11/25
Date Analyzed: 01/5/26

**Duplicate Matrix Spike Summary
Inorganic Parameters**

Sample Name: SHS-01-HA-BY-E4-DF
Lab Code: R2516774-013
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike R2516774-013MS		Duplicate Matrix Spike R2516774-013DMS		% Rec Limits	RPD	RPD Limit	
			Spike Amount	% Rec	Result	Spike Amount				% Rec
Lead, Total	1.0 U	19.5	20.0	97	19.0	20.0	95	70-130	3	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Labella Associates, PC
Project: Webster CSD - Schroeder/2251107
Sample Matrix: Drinking Water

Service Request: R2516774
Date Collected: 12/11/25
Date Received: 12/11/25
Date Analyzed: 01/5/26

**Duplicate Matrix Spike Summary
Inorganic Parameters**

Sample Name: SHS-01-HA-BY-E4-BF
Lab Code: R2516774-014
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike R2516774-014MS		Result	Duplicate Matrix Spike R2516774-014DMS		% Rec Limits	RPD	RPD Limit
			Spike Amount	% Rec		Spike Amount	% Rec			
Lead, Total	1.0 U	20.3	20.0	102	18.7	20.0	94	70-130	8	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

Client: Labella Associates, PC
Project: Webster CSD - Schroeder/2251107
Sample Matrix: Drinking Water

Service Request: R2516774
Date Collected: 12/11/25
Date Received: 12/11/25
Date Analyzed: 01/5/26

**Duplicate Matrix Spike Summary
Inorganic Parameters**

Sample Name: SHS-02-HA-BY-E219-BF
Lab Code: R2516774-033
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike R2516774-033MS		Duplicate Matrix Spike R2516774-033DMS		% Rec Limits	RPD	RPD Limit	
			Spike Amount	% Rec	Result	Spike Amount				% Rec
Lead, Total	1.0 U	20.1	20.0	101	20.1	20.0	100	70-130	<1	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

Client: Labella Associates, PC
Project: Webster CSD - Schroeder/2251107
Sample Matrix: Drinking Water

Service Request: R2516774
Date Collected: 12/11/25
Date Received: 12/11/25
Date Analyzed: 01/5/26

**Duplicate Matrix Spike Summary
Inorganic Parameters**

Sample Name: SHS-02-HA-BY-E234-DF
Lab Code: R2516774-034
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike R2516774-034MS		Result	Duplicate Matrix Spike R2516774-034DMS		% Rec Limits	RPD	RPD Limit
			Spike Amount	% Rec		Spike Amount	% Rec			
Lead, Total	1.0 U	21.2	20.0	106	21.1	20.0	106	70-130	<1	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Labella Associates, PC
Project: Webster CSD - Schroeder/2251107
Sample Matrix: Drinking Water

Service Request: R2516774
Date Analyzed: 01/05/26

Lab Control Sample Summary
Inorganic Parameters

Units:ug/L
Basis:NA

Lab Control Sample
R2516774-LCS1

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	18.1	20.0	90	85-115

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Labella Associates, PC
Project: Webster CSD - Schroeder/2251107
Sample Matrix: Drinking Water

Service Request: R2516774
Date Analyzed: 01/05/26

Lab Control Sample Summary
Inorganic Parameters

Units:ug/L
Basis:NA

Lab Control Sample
R2516774-LCS2

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	19.3	20.0	97	85-115

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Labella Associates, PC
Project: Webster CSD - Schroeder/2251107
Sample Matrix: Drinking Water

Service Request: R2516774
Date Analyzed: 01/05/26

Lab Control Sample Summary
Inorganic Parameters

Units:ug/L
Basis:NA

Lab Control Sample
R2516774-LCS3

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	20.8	20.0	104	85-115



December 30, 2025

Service Request No:R2517105

Cory Stamp
Labella Associates, PC
300 State Street, 2nd Floor
Suite 201
Rochester, NY 14614

Laboratory Results for: Webster CSD - Schroeder 12/18

Dear Cory,

Enclosed are the results of the sample(s) submitted to our laboratory December 18, 2025
For your reference, these analyses have been assigned our service request number **R2517105**.

All testing was performed according to our laboratory's quality assurance program and met the requirements of the TNI standards except as noted in the case narrative report. Any testing not included in the lab's accreditation is identified on a Non-Certified Analytes report. All results are intended to be considered in their entirety. ALS Environmental is not responsible for use of less than the complete report. Results apply only to the individual samples submitted to the lab for analysis, as listed in the report. The measurement uncertainty of the results included in this report is within that expected when using the prescribed method(s), and represented by Laboratory Control Sample control limits. Any events, such as QC failures or Holding Time exceedances, which may add to the uncertainty are explained in the report narrative or are flagged with qualifiers. The flags are explained in the Report Qualifiers and Definitions page of this report.

Please contact me if you have any questions. My extension is 7475. You may also contact me via email at Meghan.Pedro@alsglobal.com.

Respectfully submitted,

ALS Group USA, Corp. dba ALS Environmental

Meghan Pedro
Project Manager

ADDRESS 1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
PHONE +1 585 288 5380 | **FAX** +1 585 288 8475
ALS Group USA, Corp.
dba ALS Environmental



Narrative Documents

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



Client: Labella Associates, PC
Project: Webster CSD - Schroeder 12/18
Sample Matrix: Drinking Water

Service Request: R2517105
Date Received: 12/18/2025

CASE NARRATIVE

All analyses were performed consistent with the quality assurance program of ALS Environmental. This report contains analytical results for samples for the Tier II level requested by the client.

Sample Receipt:

Three drinking water samples were received for analysis at ALS Environmental on 12/18/2025. Any discrepancies upon initial sample inspection are annotated on the sample receipt and preservation form included within this report. The samples were stored at minimum in accordance with the analytical method requirements.

Metals:

No significant anomalies were noted with this analysis.

A handwritten signature in black ink that reads "Meghan Pedro".

Approved by _____

Date 12/30/2025



SAMPLE DETECTION SUMMARY

This form includes only detections above the reporting levels. For a full listing of sample results, continue to the Sample Results section of this Report.

CLIENT ID: SHS-01-RM-IN-WR-B			Lab ID: R2517105-002			
-------------------------------------	--	--	-----------------------------	--	--	--

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	2.61			0.50	ug/L	200.8

CLIENT ID: SHS-02-RM-IN-LAC-T			Lab ID: R2517105-003			
--------------------------------------	--	--	-----------------------------	--	--	--

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	0.63			0.50	ug/L	200.8



Sample Receipt Information

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

Client: Labella Associates, PC
Project: Webster CSD - Schroeder 12/18/2251107

Service Request:R2517105

SAMPLE CROSS-REFERENCE

<u>SAMPLE #</u>	<u>CLIENT SAMPLE ID</u>	<u>DATE</u>	<u>TIME</u>
R2517105-001	SHS-01-RM-IN-GRNH-IM	12/18/2025	0720
R2517105-002	SHS-01-RM-IN-WR-B	12/18/2025	0727
R2517105-003	SHS-02-RM-IN-LAC-T	12/18/2025	0729



ALS Environmental

Laboratory location:
Rochester NY

Chain of Custody Form

Page 1 of 1

Customer Information			Project Information				Parameter/Method Request for Analysis										
Purchase Order		Project Name	Webster CSD - Schroeder 12/18		A	EPA 200.8 Lead in Drinking Water											
Work Order		Project Number	2251107		B												
Company Name	LaBella Associates	Bill To Company	LaBella Associates		C												
Send Report To	Cory Stamp	Invoice Attn:	Cory Stamp		D												
Address	300 State Street, Suite 200	Address	300 State Street, Suite 200		E												
					F												
City/State/Zip	Rochester, NY 14614	City/State/Zip	Rochester, NY 14614		G												
Phone	(607) 591-7516	Phone	(607) 591-7516		H												
Fax		Fax			I												
e-Mail Address	cstamp@labellapc.com	e-Mail Address	cstamp@labellapc.com		J												
No.	Sample Description	Date	Time	Matrix	Pres.	# Bottles	A	B	C	D	E	F	G	H	I	J	Hold
1	SHS-01-RM-IN-GRNH-IM	12/18/25	7:20 AM		N/A	1	X										
2	SHS-01-RM-IN-WR-B	12/18/25	7:27 AM		↓	↓	↓										
3	SHS-02-RM-IN-LAC-T	12/18/25	7:29 AM		↓	↓	↓										
4																	
5																	
6																	
7																	
8																	
9																	
10																	

Sampler(s): Please Print & Sign <i>Simon Ruckler</i>	Shipment Method: Delivered	Required Turnaround Time: <input checked="" type="checkbox"/> STD 10 Wk Days <input type="checkbox"/> 5 Wk Days <input type="checkbox"/> 2 Wk Days <input type="checkbox"/> 24 Hour	Results Due Date:
Relinquished by: <i>Simon Ruckler</i>	Date: 12-18-25	Time: 1316	Received by: <i>[Signature]</i>
Relinquished by:	Date:	Time:	Received by (Laboratory):
Logged by (Laboratory):	Date:	Time:	Checked by (Laboratory):
Preservative Key: 1-HCL 2-HNO3 3-H2SO4 4-NaOH 5-Na2S2O3 6-NaHSO4 7-Other 8-4 degrees C 9-5035			Notes:
Cooler Temp.:			QC Package: (Check Box Below)
			<input type="checkbox"/> Level II: Standard QC
			<input type="checkbox"/> Level III: Std OC + Raw Data
			<input type="checkbox"/> Level IV: SWB46 CLP-Like
			Other: _____

Note: Any changes must be made in writing once samples and COC Form have been submitted to ALS Laboratory Group.
 Signature denotes acceptance of ALS Group USA, Corp. Terms and Conditions - Please click the link below for detailed Terms & Conditions:
<https://www.alsglobal.com/ALSGroupUSACorpTC>
 ALS copyright © 2024. All rights reserved.

R2517105 **5**
 LaBella Associates, PC
 Webster CSD - Schroeder 12/18



Cooler Receipt and Preservation Check Form

R2517105

5

Labella Associates, PC
Webster CSD - Schroeder 12/18



Project/Client Labella

Folder Number _____

Cooler received on 12/18/25 by: KE

COURIER: ALS UPS FEDEX VELOCITY CLIENT

1	Were Custody seals on outside of cooler?	Y <input checked="" type="checkbox"/> N <input type="checkbox"/>	5a	Did VOA vials have sig* bubbles?	Y <input type="checkbox"/> N <input checked="" type="checkbox"/> NA <input type="checkbox"/>
2	Custody papers properly completed (ink, signed)?	Y <input checked="" type="checkbox"/> N <input type="checkbox"/>	5b	Sig* bubbles: Alk?	Y <input type="checkbox"/> N <input checked="" type="checkbox"/> NA <input type="checkbox"/> Sulfide? Y <input type="checkbox"/> N <input checked="" type="checkbox"/> NA <input type="checkbox"/>
3	Did all bottles arrive in good condition (unbroken)?	Y <input checked="" type="checkbox"/> N <input type="checkbox"/>	6	Where did the bottles originate?	ALS/ROC <u>CLIENT</u>
4	Circle: Wet Ice Dry Ice Gel packs present?	Y <input checked="" type="checkbox"/> N <input type="checkbox"/>	7	Soil VOA received as:	Bulk Encore 5035set <u>NA</u>

8. Temperature Readings Date: 12/18/25 Time: 13:18 ID: IR#11 IR#12 IR#13 From: Temp Blank Sample Bottle

Temp (°C)	<u>20.9</u>						
Within 0-6°C?	Y <input checked="" type="checkbox"/> N <input type="checkbox"/>	Y <input type="checkbox"/> N <input type="checkbox"/>	Y <input type="checkbox"/> N <input type="checkbox"/>	Y <input type="checkbox"/> N <input type="checkbox"/>	Y <input type="checkbox"/> N <input type="checkbox"/>	Y <input type="checkbox"/> N <input type="checkbox"/>	Y <input type="checkbox"/> N <input type="checkbox"/>
If <0°C, were samples frozen?	Y <input type="checkbox"/> N <input type="checkbox"/>	Y <input type="checkbox"/> N <input type="checkbox"/>	Y <input type="checkbox"/> N <input type="checkbox"/>	Y <input type="checkbox"/> N <input type="checkbox"/>	Y <input type="checkbox"/> N <input type="checkbox"/>	Y <input type="checkbox"/> N <input type="checkbox"/>	Y <input type="checkbox"/> N <input type="checkbox"/>

If out of Temperature, note packing/ice condition: _____ Ice melted Poorly Packed (described below) Same Day Rule
& Client Approval to Run Samples: _____ Standing Approval Client aware at drop-off Client notified by: _____

All samples held in storage location: SMO by KE on 12/18/25 at 13:20
5035 samples placed in storage location: _____ by _____ on _____ at _____ within 48 hours of sampling? Y N

Cooler Breakdown/Preservation Check**: Date: 12/18/25 Time: 1649 by: CL

- 9. Were all bottle labels complete (i.e. analysis, preservation, etc.)? YES NO
- 10. Did all bottle labels and tags agree with custody papers? YES NO
- 11. Were correct containers used for the tests indicated? YES NO
- 12. Were 5035 vials acceptable (no extra labels, not leaking)? YES NO N/A
- 13. Were dissolved metals filtered in the field? YES NO N/A

pH	Lot of test paper	Reagent	Preserved?		Lot Received	Exp	Sample ID Adjusted	Vol. Added	Lot Added	Final pH
			Yes	No						
≥12		NaOH								
≤2	<u>202325</u>	HNO ₃		<input checked="" type="checkbox"/>			<u>All</u>	<u>4ml</u>	<u>245078</u>	<u><2</u>
≤2		H ₂ SO ₄								
<4		NaHSO ₄								
5-9		For 608pest			No=Notify for 3day					
Residual Chlorine (-)		For CN, Phenol, 625, 608pest, 522			If +, contact PM to add Na ₂ S ₂ O ₃ (625, 608, CN), ascorbic (phenol).					
		Na ₂ S ₂ O ₃								
		ZnAcetate	-	-						
		HCl	**	**						

**VOAs and 1664 Not to be tested before analysis. Otherwise, all bottles of all samples with chemical preservatives are checked (not just representatives).

Bottle lot numbers: client bottle
Explain all Discrepancies/ Other Comments:

9/10) No bottle labels

HPROD	BULK
HTR	FLDT
SUB	HGFB
ALS	LL3541

Labels secondary reviewed by: CL *significant air bubbles: VOA > 5-6 mm : WC > 1 in. diameter



Miscellaneous Forms

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



REPORT QUALIFIERS AND DEFINITIONS

- U Analyte was analyzed for but not detected. The sample quantitation limit has been corrected for dilution and for percent moisture, unless otherwise noted in the case narrative.
- J Estimated value due to either being a Tentatively Identified Compound (TIC) or that the concentration is between the MRL and the MDL. Concentrations are not verified within the linear range of the calibration. For DoD: concentration >40% difference between two GC columns (pesticides/Aroclors).
- B Analyte was also detected in the associated method blank at a concentration that may have contributed to the sample result.
- E Inorganics- Concentration is estimated due to the serial dilution was outside control limits.
- E Organics- Concentration has exceeded the calibration range for that specific analysis.
- D Concentration is a result of a dilution, typically a secondary analysis of the sample due to exceeding the calibration range or that a surrogate has been diluted out of the sample and cannot be assessed.
- * Indicates that a quality control parameter has exceeded laboratory limits. Under the “Notes” column of the Form I, this qualifier denotes analysis was performed out of Holding Time.
- H Analysis was performed out of hold time for tests that have an “immediate” hold time criteria.
- # Spike was diluted out.
- + Correlation coefficient for MSA is <0.995.
- N Inorganics- Matrix spike recovery was outside laboratory limits.
- N Organics- Presumptive evidence of a compound (reported as a TIC) based on the MS library search.
- S Concentration has been determined using Method of Standard Additions (MSA).
- W Post-Digestion Spike recovery is outside control limits and the sample absorbance is <50% of the spike absorbance.
- P Concentration >40% difference between the two GC columns.
- C Confirmed by GC/MS
- Q DoD reports: indicates a pesticide/Aroclor is not confirmed ($\geq 100\%$ Difference between two GC columns).
- X See Case Narrative for discussion.
- MRL Method Reporting Limit. Also known as:
- LOQ Limit of Quantitation (LOQ)
The lowest concentration at which the method analyte may be reliably quantified under the method conditions.
- MDL Method Detection Limit. A statistical value derived from a study designed to provide the lowest concentration that will be detected 99% of the time. Values between the MDL and MRL are estimated (see J qualifier).
- LOD Limit of Detection. A value at or above the MDL which has been verified to be detectable.
- ND Non-Detect. Analyte was not detected at the concentration listed. Same as U qualifier.

Rochester Lab ID # for State Accreditations¹



NELAP States
Florida ID # E87674
New Hampshire ID # 2941
New York ID # 10145
Pennsylvania ID# 68-786
Texas ID#T104704581
Virginia #460167

Non-NELAP States
Connecticut ID #PH0556
Delaware Approved
Maine ID #NY01587
North Carolina #36701
North Carolina #676
Rhode Island LAO00333

¹ Analyses were performed according to our laboratory’s NELAP-approved quality assurance program and any applicable state or agency requirements. The test results meet requirements of the current NELAP/TNI standards or state or agency requirements, where applicable, except as noted in the case narrative. Since not all analyte/method/matrix combinations are offered for state/NELAC accreditation, this report may contain results which are not accredited. For a specific list of accredited analytes, contact the laboratory. To verify NH accredited analytes, go to <https://www4.des.state.nh.us/CertifiedLabs/Certified-Method.aspx>.

ALS Laboratory Group

Acronyms

ASTM	American Society for Testing and Materials
A2LA	American Association for Laboratory Accreditation
CARB	California Air Resources Board
CAS Number	Chemical Abstract Service registry Number
CFC	Chlorofluorocarbon
CFU	Colony-Forming Unit
DEC	Department of Environmental Conservation
DEQ	Department of Environmental Quality
DHS	Department of Health Services
DOE	Department of Ecology
DOH	Department of Health
EPA	U. S. Environmental Protection Agency
ELAP	Environmental Laboratory Accreditation Program
GC	Gas Chromatography
GC/MS	Gas Chromatography/Mass Spectrometry
LUFT	Leaking Underground Fuel Tank
M	Modified
MCL	Maximum Contaminant Level is the highest permissible concentration of a substance allowed in drinking water as established by the USEPA.
MDL	Method Detection Limit
MPN	Most Probable Number
MRL	Method Reporting Limit
NA	Not Applicable
NC	Not Calculated
NCASI	National Council of the Paper Industry for Air and Stream Improvement
ND	Not Detected
NIOSH	National Institute for Occupational Safety and Health
PQL	Practical Quantitation Limit
RCRA	Resource Conservation and Recovery Act
SIM	Selected Ion Monitoring
TPH	Total Petroleum Hydrocarbons
tr	Trace level is the concentration of an analyte that is less than the PQL but greater than or equal to the MDL.

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Labella Associates, PC
Project: Webster CSD - Schroeder 12/18/2251107

Service Request: R2517105

Sample Name: SHS-01-RM-IN-GRNH-IM
Lab Code: R2517105-001
Sample Matrix: Drinking Water

Date Collected: 12/18/25
Date Received: 12/18/25

Analysis Method
200.8

Extracted/Digested By
GCONSTANTINO

Analyzed By
NMANSEN

Sample Name: SHS-01-RM-IN-WR-B
Lab Code: R2517105-002
Sample Matrix: Drinking Water

Date Collected: 12/18/25
Date Received: 12/18/25

Analysis Method
200.8

Extracted/Digested By
GCONSTANTINO

Analyzed By
NMANSEN

Sample Name: SHS-02-RM-IN-LAC-T
Lab Code: R2517105-003
Sample Matrix: Drinking Water

Date Collected: 12/18/25
Date Received: 12/18/25

Analysis Method
200.8

Extracted/Digested By
GCONSTANTINO

Analyzed By
NMANSEN



PREPARATION METHODS

The preparation methods associated with this report are found in these tables unless discussed in the case narrative.

INORGANIC

Water/Liquid Matrix

Analytical Method	Preparation Method
200.7 / 200.8	200.2
6010D	3005A/3010A
6020B	ILM05.3
9034 Sulfide Acid Soluble	9030B
SM 4500-CN-N-2016 Amenable and Residual Cyanide	SM 4500-CN-G and SM 4500-CN-B,C-2016
SM 4500-CN-E WAD Cyanide	SM 4500-CN-I

Solid/Soil/Non-Aqueous Matrix

Analytical Method	Preparation Method
6010D	3050B
6010D TCLP (1311) extract	3005A/3010A
6010D SPLP (1312) extract	3005A/3010A
7199	3060A
300.0 Anions/ 350.1/ 353.2/ SM 2320B/ SM 5210B/ 9056A Anions	DI extraction
For analytical methods not listed, the preparation method is the same as the analytical method reference.	

ORGANIC

Preparation Methods for Organic methods are listed in the header of the Results pages.

Regarding "Bulk/5035A":

For soil/solid samples submitted in soil jars for Volatiles analysis, the prep method is listed as "Bulk/5035A". The lab follows the closed-system EPA 5035A protocols once the sample is transferred to a sealed vial, but collection in bulk in soil jars does not follow the collection protocols listed in EPA 5035A. In accordance with the NYSDOH technical notice of October 2012, all results or reporting limits <200 ug/kg are to be considered estimated due to potential low bias.



Sample Results

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



Metals

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Schroeder 12/18/2251107
Sample Matrix: Drinking Water
Sample Name: SHS-01-RM-IN-GRNH-IM
Lab Code: R2517105-001

Service Request: R2517105
Date Collected: 12/18/25 07:20
Date Received: 12/18/25 13:16
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Date Extracted	Q
Lead, Total	200.8	0.50 U	ug/L	0.50	1	12/24/25 11:16	12/23/25	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Schroeder 12/18/2251107
Sample Matrix: Drinking Water
Sample Name: SHS-01-RM-IN-WR-B
Lab Code: R2517105-002

Service Request: R2517105
Date Collected: 12/18/25 07:27
Date Received: 12/18/25 13:16
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Date Extracted	Q
Lead, Total	200.8	2.61	ug/L	0.50	1	12/24/25 11:18	12/23/25	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Schroeder 12/18/2251107
Sample Matrix: Drinking Water
Sample Name: SHS-02-RM-IN-LAC-T
Lab Code: R2517105-003

Service Request: R2517105
Date Collected: 12/18/25 07:29
Date Received: 12/18/25 13:16
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Date Extracted	Q
Lead, Total	200.8	0.63	ug/L	0.50	1	12/24/25 11:19	12/23/25	



QC Summary Forms

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



Metals

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Schroeder 12/18/2251107
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2517105-MB

Service Request: R2517105
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Date Extracted	Q
Lead, Total	200.8	0.50 U	ug/L	0.50	1	12/24/25 10:45	12/23/25	

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Labella Associates, PC
Project: Webster CSD - Schroeder 12/18/2251107
Sample Matrix: Drinking Water

Service Request: R2517105
Date Analyzed: 12/24/25

Lab Control Sample Summary
Inorganic Parameters

Units:ug/L
Basis:NA

Lab Control Sample
R2517105-LCS

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	21.6	20.0	108	85-115



APPENDIX C:
LICENSES AND CERTIFICATIONS

United States Environmental Protection Agency

This is to certify that

LaBella Associates, D.P.C.

has fulfilled the requirements of the Toxic Substances Control Act (TSCA) Section 402, and has received certification to conduct lead-based paint activities pursuant to 40 CFR Part 745.226

In the Jurisdiction of:

All EPA Administered Lead-based Paint Activities Program States, Tribes and Territories

This certification is valid from the date of issuance and expires September 26, 2027

LBP-2226-3

Certification #

August 01, 2024

Issued On



A handwritten signature in black ink, appearing to read "Marc Edmonds".

Marc Edmonds, Chief

Risk Assessment Management Branch 2.

United States Environmental Protection Agency

This is to certify that



Cory J Stamp

has fulfilled the requirements of the Toxic Substances Control Act (TSCA) Section 402, and has received certification to conduct lead-based paint activities pursuant to 40 CFR Part 745.226 as:

Risk Assessor

In the Jurisdiction of:

All EPA Administered Lead-based Paint Activities Program States, Tribes and Territories

This certification is valid from the date of issuance and expires October 24, 2028

LBP-R-I206349-3

Certification #

October 15, 2025

Issued On



A handwritten signature in black ink that reads "Ben Conetta".

Ben Conetta, Manager

Chemicals and Multimedia Programs Branch

NEW YORK STATE DEPARTMENT OF HEALTH
WADSWORTH CENTER



Expires 12:01 AM April 01, 2026
Issued April 01, 2025

CERTIFICATE OF APPROVAL FOR LABORATORY SERVICE

Issued in accordance with and pursuant to section 502 Public Health Law of New York State

MS. CHRISTINE KUTZER
ALS ENVIRONMENTAL - ROCHESTER
1565 JEFFERSON ROAD BUILDING 300, SUITE 360
ROCHESTER, NY 14623

NY Lab Id No: 10145

*is hereby APPROVED as an Environmental Laboratory in conformance with the
National Environmental Laboratory Accreditation Conference Standards (2016) for the category
ENVIRONMENTAL ANALYSES POTABLE WATER
All approved analytes are listed below:*

Bacteriology

Coliform, Total / E. coli (Qualitative) SM 20, 21-23 9223B (-04) (Colilert)

Dissolved Gases

Acetylene RSK-175
Ethane RSK-175
Ethene (Ethylene) RSK-175
Methane RSK-175
Propane RSK-175

Fuel Additives

Methyl tert-butyl ether EPA 524.2
Naphthalene EPA 524.2

Metals I

Arsenic, Total EPA 200.8 Rev. 5.4
Barium, Total EPA 200.8 Rev. 5.4
Cadmium, Total EPA 200.8 Rev. 5.4
Chromium, Total EPA 200.7 Rev. 4.4
Copper, Total EPA 200.8 Rev. 5.4
Iron, Total EPA 200.7 Rev. 4.4
Lead, Total EPA 200.8 Rev. 5.4
Manganese, Total EPA 200.7 Rev. 4.4
Mercury, Total EPA 245.1 Rev. 3.0
Selenium, Total EPA 200.8 Rev. 5.4
Silver, Total EPA 200.7 Rev. 4.4
Zinc, Total EPA 200.7 Rev. 4.4



Serial No.: 70111

Property of the New York State Department of Health. Certificates are valid only at the address shown and must be conspicuously posted by the laboratory. Continued accreditation depends on the laboratory's successful ongoing participation in the Program. Consumers may verify a laboratory's accreditation status online at <https://apps.health.ny.gov/pubdoh/applinks/wc/elappublicweb/>, by phone (518) 485-5570 or by email to elap@health.ny.gov.

