

Lead in Drinking Water Testing – State Road Elementary School November 13, 2025

Location:

Webster Central School District
1028 Ridge Road, Suite 12
Webster, New York 14580



LaBella Project No.

2251107

December 15, 2025



Table of Contents

| | | |
|------------|--|----------|
| 1.0 | BACKGROUND..... | 1 |
| 2.0 | SAMPLING PROCEDURES..... | 1 |
| 3.0 | RESULTS..... | 2 |
| 3.1 | Total Water Sample Summary..... | 2 |
| 4.0 | RESPONSE MEASURES..... | 2 |
| 5.0 | REPORTING AND RECORD KEEPING..... | 2 |

Appendices

Appendix A – Detailed Results Spreadsheet

Appendix B – Laboratory Analytical Results

Appendix C – Licenses and Certifications



1.0 BACKGROUND

LaBella Associates, D.P.C. (LaBella) sampled potable water outlets throughout the Webster Central School District (WCSD) in accordance with Subpart 67-4 of Title 10 of the New York State Codes, Rules, and Regulations (Subpart 67-4). Under Subpart 67-4, “all school districts and boards of cooperative educational services are required to test potable water for lead contamination, and to develop and implement a lead remediation plan, where applicable.”

Lead contamination is a significant public health concern. Lead has been linked to various harmful conditions such as central nervous system and kidney damage. Children, especially those under the age of 6, are particularly susceptible to the toxic effects of lead. There is no known safe level of lead in blood, and the US Environmental Protection Agency (USEPA) has set a Maximum Contaminant Level Goal of zero. As of 2022, Subpart 67-4 establishes an action level of 5 parts per billion (ppb) in school drinking water. If test results exceed this level, the district must undertake remedial action.

The Subpart 67-4 testing requirement was first promulgated under emergency legislation in 2016, and subsequently signed into permanent law. Subsequently, Senate Bill S2122A was signed into law on December 22, 2022, changing various components of Subpart 67-4. Key revisions to the standard include a reduced action level down to 5 parts per billion (ppb), and requires that testing be performed every three years. The next round of sampling reports are due by the end of 2025. This report has been designed to fulfill the initial testing and reporting requirements outlined in Subpart 67-4.

LaBella conducted the initial water sampling on November 13, 2025 at the State Road Elementary School located at 1401 State Road in Webster, NY. Outlets that were selected for sampling include drinking fountains, bottle fillers, kitchen sinks, classroom sinks, medical office sinks, and ice machines. Outlets categorically excluded from testing included laboratory sinks, bathroom sinks, art room sinks, single-handle faucets, showers, toilets, janitor’s sinks, and mechanical room outlets. Typically, excluded outlets are capable of being isolated by custodial staff, and will require warning signs to prohibit consumption.

2.0 SAMPLING PROCEDURES

The target water fixtures were left to stagnate for a period of 8 to 18 hours prior to the start of the sampling. The water conditions were reported to be representative of normal consumptive patterns with building occupancy controlled during stagnation and sampling periods.

In accordance with Subpart 67-4 requirements, sampling was limited to “first-draw” samples. A volume of the first 250 mL of water was taken from each cold-water fixture in the sampling inventory.

The samples were then promptly packaged and shipped to a NYS Department of Health Environmental Laboratory Approval Program (ELAP) accredited laboratory. Samples were analyzed utilizing EPA environmental analysis method 200.8 for lead in potable water. Results from the sampling rounds were then delivered to WCSD.



3.0 RESULTS

3.1 Total Water Sample Summary

The following table summarizes the results from the November 13, 2025 sampling round:

| State Road Elementary School – November 13, 2025 Water Sample Summary | | |
|---|-------------------------|---------------------------------------|
| Building | Number of Total Samples | Number of Fixtures above Action Level |
| State Road Elementary School | 32 | 0 |

Based on laboratory analyses of the samples collected, none of the outlets were determined to exceed the Subpart 67-4 action level of 5 micrograms per liter ($\mu\text{g/L}$).

For a full list of fixtures sampled, see Appendix A.

4.0 RESPONSE MEASURES

According to section Subpart 67-4.4 “Response” of the regulation, school districts shall prohibit the use of all outlets which exceed the 5 ppb ($\mu\text{g/L}$) action level. These outlets shall remain out of service until a lead remediation plan is implemented to reduce the level of lead, and resampling indicates lead levels at or below the action level. While the outlet is out of service, the district must supply an appropriate amount of potable water for drinking or cooking to building occupants.

As no outlets were found to exceed the action level as part of this sampling round, no response measure are necessary at this time.

5.0 REPORTING AND RECORD KEEPING

In accordance with Subpart 67-4 the district shall:

1. Report the test results to the local health department as soon as practicable, but no more than 1 business day after the school received the laboratory report.
2. Notify all staff and all persons in parental relation to children or students of the test results, in writing, as soon as practicable, but no more than 10 business days after the school received the laboratory report.
3. The school shall make available, on the school’s website, the results of all lead testing performed and lead remediation plans implemented pursuant to Subpart 67-4, as soon as practicable, but no more than 6 weeks after the school received the laboratory reports.
4. As soon as practicable, but no more than 10 business days after the school received the laboratory reports, the school shall report data relating to test results to the NYS Health Department, local health department, and NYS Education Department, through the NYS Health Department’s designated statewide electronic reporting system.
5. The school shall retain all records of test results, lead remediation plans, and waiver requests, for ten years following the creation of such documentation. Copies of such documentation



shall be immediately provided to the NYS Health Department, local health department, or NYS Education Department, upon request.



APPENDIX A:
DETAILED RESULTS SPREADSHEET

| State Road Elementary School | | | | |
|------------------------------|--|--------------|--------------|---------------|
| Identification Code | Description | Date Sampled | Time Sampled | Result (µg/L) |
| SR-00-RM-IN-KI-T1 | Kitchen Sink 1 (Moving Clockwise) | 11/13/2025 | 0620 | <1.0 |
| SR-00-RM-IN-KI-T3 | Kitchen Sink 3 (Moving Clockwise) | 11/13/2025 | 0621 | 1.2 |
| SR-00-RM-IN-CAFÉ-BF | Cafeteria Bottle Filler - Elkay | 11/13/2025 | 0622 | <1.0 |
| SR-00-RM-IN-CAFÉ-DF | Cafeteria Drinking Fountain - Elkay | 11/13/2025 | 0623 | <1.0 |
| SR-00-RM-IN-KI-PF | Kitchen Pot Filler | 11/13/2025 | 0625 | 3.4 |
| SR-01-CR-IN-114-T1 | Left Sink In Classroom 114 | 11/13/2025 | 0631 | <1.0 |
| SR-01-CR-IN-114-T2 | Right Sink In Classroom 114 | 11/13/2025 | 0632 | 3.2 |
| SR-01-RM-IN-LI-T | Library Sink | 11/13/2025 | 0633 | <1.0 |
| SR-01-RM-IN-BLR-DF | Boys Locker Room Drinking Fountain | 11/13/2025 | 0634 | <1.0 |
| SR-01-RM-IN-115B-T | Room 115B Sink | 11/13/2025 | 0636 | <1.0 |
| SR-01-RM-IN-GLR-DF | Girls Locker Room Drinking Fountain | 11/13/2025 | 0637 | <1.0 |
| SR-01-HA-BY-MO-DF | Hallway by Main Office Drinking Fountain - Elkay | 11/13/2025 | 0640 | <1.0 |
| SR-01-HA-BY-MO-BF | Hallway by Main Office Bottle Filler - Elkay | 11/13/2025 | 0641 | <1.0 |
| SR-01-RM-IN-MO-T | Sink in Main Office Room 113 | 11/13/2025 | 0642 | <1.0 |
| SR-01-RM-IN-NO-T | Nurse's Office 110 Sink | 11/13/2025 | 0644 | 2.9 |
| SR-01-HA-BY-108-DF | Hallway by Room 108 Drinking Fountain - Elkay | 11/13/2025 | 0646 | <1.0 |
| SR-01-HA-BY-108-BF | Hallway by Room 108 Bottle Filler - Elkay | 11/13/2025 | 0647 | <1.0 |
| SR-01-CR-IN-101-T | Classroom 101 Sink | 11/13/2025 | 0649 | 2.1 |
| SR-01-CR-IN-101-B | Classroom 101 Bubbler | 11/13/2025 | 0650 | 1.8 |
| SR-01-CR-IN-102-T | Classroom 102 Sink | 11/13/2025 | 0652 | 5.0 |
| SR-01-CR-IN-102-B | Classroom 102 Bubbler | 11/13/2025 | 0653 | <1.0 |
| SR-01-HA-BY-116-DF | Hallway by Room 116 Drinking Fountain - Elkay | 11/13/2025 | 0655 | <1.0 |
| SR-01-HA-BY-116-BF | Hallway by Room 116 Bottle Filler - Elkay | 11/13/2025 | 0656 | <1.0 |
| SR-02-RM-IN-TL-T | 2nd Floor Teacher's Lounge Sink | 11/13/2025 | 0700 | 2.1 |
| SR-02-CR-IN-201-T | Room 201 Sink | 11/13/2025 | 0701 | 3.9 |
| SR-02-CR-IN-201-B | Room 201 Bubbler | 11/13/2025 | 0702 | 4.2 |
| SR-02-HA-BY-202-DF | Drinking Fountain Near Room 202 | 11/13/2025 | 0704 | <1.0 |
| SR-02-HA-BY-202-BF | Bottle Filler Near Room 202 | 11/13/2025 | 0705 | <1.0 |
| SR-02-HA-BY-214-T | Centrum Near Room 214 Sink | 11/13/2025 | 0707 | <1.0 |
| SR-02-HA-BY-214-B | Centrum Near Room 214 Bubbler | 11/13/2025 | 0708 | <1.0 |
| SR-02-HA-BY-215-T | Centrum Near Room 215 Sink | 11/13/2025 | 0709 | <1.0 |
| SR-02-HA-BY-215-B | Centrum Near Room 215 Bubbler | 11/13/2025 | 0710 | <1.0 |



APPENDIX B:
LABORATORY ANALYTICAL
REPORTS



December 05, 2025

Service Request No:R2515322

Cory Stamp
Labella Associates, PC
300 State Street, 2nd Floor
Suite 201
Rochester, NY 14614

Laboratory Results for: Webster CSD - State Road

Dear Cory,

Enclosed are the results of the sample(s) submitted to our laboratory November 14, 2025
For your reference, these analyses have been assigned our service request number R2515322.

All testing was performed according to our laboratory's quality assurance program and met the requirements of the TNI standards except as noted in the case narrative report. Any testing not included in the lab's accreditation is identified on a Non-Certified Analytes report. All results are intended to be considered in their entirety. ALS Environmental is not responsible for use of less than the complete report. Results apply only to the individual samples submitted to the lab for analysis, as listed in the report. The measurement uncertainty of the results included in this report is within that expected when using the prescribed method(s), and represented by Laboratory Control Sample control limits. Any events, such as QC failures or Holding Time exceedances, which may add to the uncertainty are explained in the report narrative or are flagged with qualifiers. The flags are explained in the Report Qualifiers and Definitions page of this report.

Please contact me if you have any questions. My extension is 7475. You may also contact me via email at Meghan.Pedro@alsglobal.com.

Respectfully submitted,

ALS Group USA, Corp. dba ALS Environmental

Meghan Pedro
Project Manager

ADDRESS 1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
PHONE +1 585 288 5380 | FAX +1 585 288 8475
ALS Group USA, Corp.
dba ALS Environmental



Narrative Documents

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



Client: Labella Associates, PC
Project: Webster CSD - State Road
Sample Matrix: Drinking Water

Service Request: R2515322
Date Received: 11/14/2025

CASE NARRATIVE

All analyses were performed consistent with the quality assurance program of ALS Environmental. This report contains analytical results for samples for the Tier II level requested by the client.

Sample Receipt:

Thirty two drinking water samples were received for analysis at ALS Environmental on 11/14/2025. Any discrepancies upon initial sample inspection are annotated on the sample receipt and preservation form included within this report. The samples were stored at minimum in accordance with the analytical method requirements.

Metals:

No significant anomalies were noted with this analysis.

A handwritten signature in black ink that reads 'Meghan Pedro'.

Approved by _____

Date 12/05/2025



SAMPLE DETECTION SUMMARY

This form includes only detections above the reporting levels. For a full listing of sample results, continue to the Sample Results section of this Report.

| CLIENT ID: SR-00-RM-IN-KI-T3 | | Lab ID: R2515322-004 | | | | | |
|-------------------------------|---------|----------------------|-----|-----|-------|--------|--|
| Analyte | Results | Flag | MDL | MRL | Units | Method | |
| Lead, Total | 1.2 | | | 1.0 | ug/L | 200.8 | |
| CLIENT ID: SR-02-RM-IN-TL-T | | Lab ID: R2515322-011 | | | | | |
| Analyte | Results | Flag | MDL | MRL | Units | Method | |
| Lead, Total | 2.1 | | | 1.0 | ug/L | 200.8 | |
| CLIENT ID: SR-02-CR-IN-201-T | | Lab ID: R2515322-012 | | | | | |
| Analyte | Results | Flag | MDL | MRL | Units | Method | |
| Lead, Total | 3.9 | | | 1.0 | ug/L | 200.8 | |
| CLIENT ID: SR-02-CR-IN-201-B | | Lab ID: R2515322-013 | | | | | |
| Analyte | Results | Flag | MDL | MRL | Units | Method | |
| Lead, Total | 4.2 | | | 1.0 | ug/L | 200.8 | |
| CLIENT ID: SR-01-CR-IN-101-T | | Lab ID: R2515322-014 | | | | | |
| Analyte | Results | Flag | MDL | MRL | Units | Method | |
| Lead, Total | 2.1 | | | 1.0 | ug/L | 200.8 | |
| CLIENT ID: SR-01-CR-IN-101-B | | Lab ID: R2515322-015 | | | | | |
| Analyte | Results | Flag | MDL | MRL | Units | Method | |
| Lead, Total | 1.8 | | | 1.0 | ug/L | 200.8 | |
| CLIENT ID: SR-01-CR-IN-102-T | | Lab ID: R2515322-016 | | | | | |
| Analyte | Results | Flag | MDL | MRL | Units | Method | |
| Lead, Total | 5.0 | | | 1.0 | ug/L | 200.8 | |
| CLIENT ID: SR-01-RM-IN-LI-T | | Lab ID: R2515322-020 | | | | | |
| Analyte | Results | Flag | MDL | MRL | Units | Method | |
| Lead, Total | 4.3 | | | 1.0 | ug/L | 200.8 | |
| CLIENT ID: SR-01-CR-IN-114-T2 | | Lab ID: R2515322-022 | | | | | |
| Analyte | Results | Flag | MDL | MRL | Units | Method | |
| Lead, Total | 3.2 | | | 1.0 | ug/L | 200.8 | |
| CLIENT ID: SR-01-RM-IN-NO-T | | Lab ID: R2515322-025 | | | | | |
| Analyte | Results | Flag | MDL | MRL | Units | Method | |
| Lead, Total | 2.9 | | | 1.0 | ug/L | 200.8 | |
| CLIENT ID: SR-00-RM-IN-KI-PF | | Lab ID: R2515322-032 | | | | | |
| Analyte | Results | Flag | MDL | MRL | Units | Method | |
| Lead, Total | 3.4 | | | 1.0 | ug/L | 200.8 | |



Sample Receipt Information

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

Client: Labella Associates, PC
Project: Webster CSD - State Road/2251107

Service Request:R2515322

SAMPLE CROSS-REFERENCE

| <u>SAMPLE #</u> | <u>CLIENT SAMPLE ID</u> | <u>DATE</u> | <u>TIME</u> |
|-----------------|-------------------------|-------------|-------------|
| R2515322-001 | SR-00-RM-IN-CAFE-DF | 11/13/2025 | 0623 |
| R2515322-002 | SR-00-RM-IN-CAFE-BF | 11/13/2025 | 0622 |
| R2515322-003 | SR-00-RM-IN-KI-T1 | 11/13/2025 | 0620 |
| R2515322-004 | SR-00-RM-IN-KI-T3 | 11/13/2025 | 0621 |
| R2515322-005 | SR-00-HA-BY-214-T | 11/13/2025 | 0707 |
| R2515322-006 | SR-02-HA-BY-214-B | 11/13/2025 | 0708 |
| R2515322-007 | SR-02-HA-0BY-215-T | 11/13/2025 | 0709 |
| R2515322-008 | SR-02-HA-BY-215-B | 11/13/2025 | 0710 |
| R2515322-009 | SR-02-HA-BY-202-DF | 11/13/2025 | 0704 |
| R2515322-010 | SR-02-HA-BY-202-BF | 11/13/2025 | 0705 |
| R2515322-011 | SR-02-RM-IN-TL-T | 11/13/2025 | 0700 |
| R2515322-012 | SR-02-CR-IN-201-T | 11/13/2025 | 0701 |
| R2515322-013 | SR-02-CR-IN-201-B | 11/13/2025 | 0702 |
| R2515322-014 | SR-01-CR-IN-101-T | 11/13/2025 | 0649 |
| R2515322-015 | SR-01-CR-IN-101-B | 11/13/2025 | 0650 |
| R2515322-016 | SR-01-CR-IN-102-T | 11/13/2025 | 0652 |
| R2515322-017 | SR-01-CR-IN-102-B | 11/13/2025 | 0653 |
| R2515322-018 | SR-01-RM-IN-GLR-DF | 11/13/2025 | 0637 |
| R2515322-019 | SR-01-RM-IN-BLR-DF | 11/13/2025 | 0634 |
| R2515322-020 | SR-01-RM-IN-LI-T | 11/13/2025 | 0633 |
| R2515322-021 | SR-01-CR-IN-114-T1 | 11/13/2025 | 0631 |
| R2515322-022 | SR-01-CR-IN-114-T2 | 11/13/2025 | 0632 |
| R2515322-023 | SR-01-RM-IN-115B-T | 11/13/2025 | 0636 |
| R2515322-024 | SR-01-RM-IN-MO-T | 11/13/2025 | 0642 |
| R2515322-025 | SR-01-RM-IN-NO-T | 11/13/2025 | 0644 |
| R2515322-026 | SR-01-HA-BY-108-DF | 11/13/2025 | 0646 |
| R2515322-027 | SR-01-HA-BY-108-BF | 11/13/2025 | 0647 |
| R2515322-028 | SR-01-HA-BY-MO-DF | 11/13/2025 | 0640 |
| R2515322-029 | SR-01-HA-BY-MO-BF | 11/13/2025 | 0641 |
| R2515322-030 | SR-01-HA-BY-116-DF | 11/13/2025 | 0655 |
| R2515322-031 | SR-01-HA-BY-116-BF | 11/13/2025 | 0656 |
| R2515322-032 | SR-00-RM-IN-KI-PF | 11/13/2025 | 0625 |



ALS Environmental

Laboratory location:
Rochester NY

Chain of Custody Form

Page 1 of 2

| Customer Information | | Project Information | | | | Parameter/Method Request for Analysis | | | | | | | | | | | | |
|---|---------------------------------------|-------------------------------|--|--|------------------------------|---------------------------------------|----------------------------------|---|-------------------|---|---|---|---|---|---|---|------|--|
| Purchase Order | | Project Name | Webster CSD - State Road | | | A | EPA 200.8 Lead in Drinking Water | | | | | | | | | | | |
| Work Order | | Project Number | 2251107 | | | B | | | | | | | | | | | | |
| Company Name | LaBella Associates | Bill To Company | LaBella Associates | | | C | | | | | | | | | | | | |
| Send Report To | Cory Stamp | Invoice Attn. | Cory Stamp | | | D | | | | | | | | | | | | |
| Address | 300 State Street, Suite 200 | Address | 300 State Street, Suite 200 | | | E | | | | | | | | | | | | |
| | | | | | | F | | | | | | | | | | | | |
| City/State/Zip | Rochester, NY 14614 | City/State/Zip | Rochester, NY 14614 | | | G | | | | | | | | | | | | |
| Phone | (607) 591-7516 | Phone | (607) 591-7516 | | | H | | | | | | | | | | | | |
| Fax | | Fax | | | | I | | | | | | | | | | | | |
| e-Mail Address | cstamp@labellapc.com | e-Mail Address | cstamp@labellapc.com | | | J | | | | | | | | | | | | |
| No. | Sample Description | Date | Time | Matrix | Pres. | # Bottles | A | B | C | D | E | F | G | H | I | J | Hold | |
| 1 | See attached spreadsheets for sample | | | | N/A | | X | | | | | | | | | | | |
| 2 | descriptions. All samples are 250 mL | | | | | | | | | | | | | | | | | |
| 3 | plastic bottles, drinking water, with | | | | | | | | | | | | | | | | | |
| 4 | no preservative | | | | | | | | | | | | | | | | | |
| 5 | | | | | | | | | | | | | | | | | | |
| 6 | | | | | | | | | | | | | | | | | | |
| 7 | | | | | | | | | | | | | | | | | | |
| 8 | | | | | | | | | | | | | | | | | | |
| 9 | | | | | | | | | | | | | | | | | | |
| 10 | | | | | | | | | | | | | | | | | | |
| Sampler(s): Please Print & Sign <i>Cory Stamp</i> | | Shipment Method: Delivered | | Required Turnaround Time: <input checked="" type="checkbox"/> STD 10 Wk Days <input type="checkbox"/> 5 Wk Days <input type="checkbox"/> 2 Wk Days <input type="checkbox"/> 24 Hour | | | Other | | Results Due Date: | | | | | | | | | |
| Relinquished By: <i>[Signature]</i> | Date: 11/14/25 | Time: 0845 | Received by: <i>Christopher Cudde</i> | | ALS 11/14/25 0845 | | Notes: | | | | | | | | | | | |
| Relinquished by: | Date: | Time: | Received by (Laboratory): | | Cooler Temp. | | QC Package: (Check Box Below) | | | | | | | | | | | |
| Logged by (Laboratory): | Date: | Time: | Checked by (Laboratory): | | Level II: Standard QC | | TRRP-Checklist | | | | | | | | | | | |
| | | | | | Level III: Std QC + Raw Data | | TRRP Level IV | | | | | | | | | | | |
| | | | | | Level IV: SW846 CLP-Like | | | | | | | | | | | | | |
| Preservative Key: 1-HCL 2-HNO3 3-H2SO4 4-NaOH 5-Na2S2O8 6-NaHSO4 7-Other 8-4 degrees C 9-8035 | | | | | Oth | | R2515322 | | | | | 5 | | | | | | |

Note: Any changes must be made in writing once samples and COC Form have been submitted to ALS Laboratory Group. Signature denotes acceptance of ALS Group USA, Corp. Terms and Conditions - Please click the link below for detailed Terms & Conditions:

<https://www.alsglobal.com/ALSGroupUSACorpTC>

ALS copyright © 2024. All rights reserved.





Cooler Receipt and Preservation Check

R2515322 **5**
 Labella Associates, PC
 Webster CSD - State Road

Project/Client _____ Folder Number _____

Cooler received on 11/14/25 by: CC

COURIER: ALS UPS FEDEX VELOCITY CLIENT

| | | |
|---|--|------------|
| 1 | Were Custody seals on outside of cooler? | Y <u>N</u> |
| 2 | Custody papers properly completed (ink, signed)? | <u>Y</u> N |
| 3 | Did all bottles arrive in good condition (unbroken)? | <u>Y</u> N |
| 4 | Circle: Wet Ice Dry Ice Gel packs present? | Y <u>N</u> |

| | | |
|----|---|-----------------------|
| 5a | Did VOA vials have sig* bubbles? | Y N <u>NA</u> |
| 5b | Sig* bubbles: Alk? Y N <u>NA</u> Sulfide? Y N <u>NA</u> | |
| 6 | Where did the bottles originate? | <u>ALS/ROC</u> CLIENT |
| 7 | Soil VOA received as: Bulk Encore 5035set | <u>NA</u> |

8. Temperature Readings Date: 11/17/25 Time: 1336 ID: IR#12 IR#11 From: Temp Blank Sample Bottle

| | | | | | | | |
|-------------------------------|-------------|-----|-----|-----|-----|-----|-----|
| Temp (°C) | <u>15.9</u> | | | | | | |
| Within 0-6°C? | Y <u>N</u> | Y N | Y N | Y N | Y N | Y N | Y N |
| If <0°C, were samples frozen? | Y N | Y N | Y N | Y N | Y N | Y N | Y N |

If out of Temperature, note packing/ice condition: _____ Ice melted Poorly Packed (described below) Same Day Rule
 & Client Approval to Run Samples: _____ Standing Approval Client aware at drop-off Client notified by: _____

All samples held in storage location: SMO by CC on 11/14/25 at 0845
 5035 samples placed in storage location: _____ by _____ on _____ at _____ within 48 hours of sampling? Y N

Cooler Breakdown/Preservation Check**: Date: 11/26 Time: 1308 by: AG

- 9. Were all bottle labels complete (i.e. analysis, preservation, etc.)? YES NO
- 10. Did all bottle labels and tags agree with custody papers? YES NO
- 11. Were correct containers used for the tests indicated? YES NO
- 12. Were 5035 vials acceptable (no extra labels, not leaking)? YES NO NA
- 13. Were dissolved metals filtered in the field? YES NO NA
- 14. Air Samples: Cassettes / Tubes Intact Y/N with MS Y/N Canisters Pressurized Tedlar® Bags Inflated NA

| pH | Lot of test paper | Reagent | Preserved? | | Lot Received | Exp | Sample ID Adjusted | Vol. Added | Lot Added | Final pH |
|-----------------------|-------------------|---|------------|----|--|-----|--------------------|------------|-----------|----------|
| | | | Yes | No | | | | | | |
| >12 | | NaOH | | | | | | | | |
| <u>2</u> | <u>202325</u> | HNO ₃ | | X | <u>NO Lot info</u> | | <u>All</u> | <u>4ml</u> | | <u>2</u> |
| <2 | | H ₂ SO ₄ | | | | | | | | |
| <4 | | NaHSO ₄ | | | | | | | | |
| 5-9 | | For 608pest | | | No=Notify for 3day | | | | | |
| Residual Chlorine (-) | | For CN, Phenol, 625, 608pest, 522 | | | If +, contact PM to add Na ₂ S ₂ O ₃ (625, 608, CN), ascorbic (phenol). | | | | | |
| | | Na ₂ S ₂ O ₃ | | | | | | | | |
| | | ZnAcetate | - | - | | | | | | |
| | | HCl | ** | ** | | | | | | |

**VOAs and 1664 Not to be tested before analysis. Otherwise, all bottles of all samples with chemical preservatives are checked (not just representatives).

Bottle lot numbers: no lot info
 Explain all Discrepancies/ Other Comments: _____

No ice

| | |
|-------|--------|
| HPROD | BULK |
| HTR | FLDT |
| SUB | HGFB |
| ALS | LL3541 |

Labels secondary reviewed by: AG *significant air bubbles: VOA > 5-6 mm : WC > 1 in. diameter



Miscellaneous Forms

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



REPORT QUALIFIERS AND DEFINITIONS

- | | |
|---|--|
| <p>U Analyte was analyzed for but not detected. The sample quantitation limit has been corrected for dilution and for percent moisture, unless otherwise noted in the case narrative.</p> <p>J Estimated value due to either being a Tentatively Identified Compound (TIC) or that the concentration is between the MRL and the MDL. Concentrations are not verified within the linear range of the calibration. For DoD: concentration >40% difference between two GC columns (pesticides/Aroclors).</p> <p>B Analyte was also detected in the associated method blank at a concentration that may have contributed to the sample result.</p> <p>E Inorganics- Concentration is estimated due to the serial dilution was outside control limits.</p> <p>E Organics- Concentration has exceeded the calibration range for that specific analysis.</p> <p>D Concentration is a result of a dilution, typically a secondary analysis of the sample due to exceeding the calibration range or that a surrogate has been diluted out of the sample and cannot be assessed.</p> <p>* Indicates that a quality control parameter has exceeded laboratory limits. Under the “Notes” column of the Form I, this qualifier denotes analysis was performed out of Holding Time.</p> <p>H Analysis was performed out of hold time for tests that have an “immediate” hold time criteria.</p> <p># Spike was diluted out.</p> | <p>+ Correlation coefficient for MSA is <0.995.</p> <p>N Inorganics- Matrix spike recovery was outside laboratory limits.</p> <p>N Organics- Presumptive evidence of a compound (reported as a TIC) based on the MS library search.</p> <p>S Concentration has been determined using Method of Standard Additions (MSA).</p> <p>W Post-Digestion Spike recovery is outside control limits and the sample absorbance is <50% of the spike absorbance.</p> <p>P Concentration >40% difference between the two GC columns.</p> <p>C Confirmed by GC/MS</p> <p>Q DoD reports: indicates a pesticide/Aroclor is not confirmed ($\geq 100\%$ Difference between two GC columns).</p> <p>X See Case Narrative for discussion.</p> <p>MRL Method Reporting Limit. Also known as:</p> <p>LOQ Limit of Quantitation (LOQ) The lowest concentration at which the method analyte may be reliably quantified under the method conditions.</p> <p>MDL Method Detection Limit. A statistical value derived from a study designed to provide the lowest concentration that will be detected 99% of the time. Values between the MDL and MRL are estimated (see J qualifier).</p> <p>LOD Limit of Detection. A value at or above the MDL which has been verified to be detectable.</p> <p>ND Non-Detect. Analyte was not detected at the concentration listed. Same as U qualifier.</p> |
|---|--|

Rochester Lab ID # for State Accreditations¹



| NELAP States |
|-------------------------|
| Florida ID # E87674 |
| New Hampshire ID # 2941 |
| New York ID # 10145 |
| Pennsylvania ID# 68-786 |
| Texas ID#T104704581 |
| Virginia #460167 |

| Non-NELAP States |
|------------------------|
| Connecticut ID #PH0556 |
| Delaware Approved |
| Maine ID #NY01587 |
| North Carolina #36701 |
| North Carolina #676 |
| Rhode Island LAO00333 |

¹ Analyses were performed according to our laboratory’s NELAP-approved quality assurance program and any applicable state or agency requirements. The test results meet requirements of the current NELAP/TNI standards or state or agency requirements, where applicable, except as noted in the case narrative. Since not all analyte/method/matrix combinations are offered for state/NELAC accreditation, this report may contain results which are not accredited. For a specific list of accredited analytes, contact the laboratory. To verify NH accredited analytes, go to <https://www4.des.state.nh.us/CertifiedLabs/Certified-Method.aspx>.

ALS Laboratory Group

Acronyms

| | |
|------------|--|
| ASTM | American Society for Testing and Materials |
| A2LA | American Association for Laboratory Accreditation |
| CARB | California Air Resources Board |
| CAS Number | Chemical Abstract Service registry Number |
| CFC | Chlorofluorocarbon |
| CFU | Colony-Forming Unit |
| DEC | Department of Environmental Conservation |
| DEQ | Department of Environmental Quality |
| DHS | Department of Health Services |
| DOE | Department of Ecology |
| DOH | Department of Health |
| EPA | U. S. Environmental Protection Agency |
| ELAP | Environmental Laboratory Accreditation Program |
| GC | Gas Chromatography |
| GC/MS | Gas Chromatography/Mass Spectrometry |
| LUFT | Leaking Underground Fuel Tank |
| M | Modified |
| MCL | Maximum Contaminant Level is the highest permissible concentration of a substance allowed in drinking water as established by the USEPA. |
| MDL | Method Detection Limit |
| MPN | Most Probable Number |
| MRL | Method Reporting Limit |
| NA | Not Applicable |
| NC | Not Calculated |
| NCASI | National Council of the Paper Industry for Air and Stream Improvement |
| ND | Not Detected |
| NIOSH | National Institute for Occupational Safety and Health |
| PQL | Practical Quantitation Limit |
| RCRA | Resource Conservation and Recovery Act |
| SIM | Selected Ion Monitoring |
| TPH | Total Petroleum Hydrocarbons |
| tr | Trace level is the concentration of an analyte that is less than the PQL but greater than or equal to the MDL. |

ALS Group USA, Corp.
dba ALS Environmental
Analyst Summary report

Client: Labella Associates, PC
Project: Webster CSD - State Road/2251107

Service Request: R2515322

Sample Name: SR-00-RM-IN-CAFE-DF
Lab Code: R2515322-001
Sample Matrix: Drinking Water

Date Collected: 11/13/25
Date Received: 11/14/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: SR-00-RM-IN-CAFE-BF
Lab Code: R2515322-002
Sample Matrix: Drinking Water

Date Collected: 11/13/25
Date Received: 11/14/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: SR-00-RM-IN-KI-T1
Lab Code: R2515322-003
Sample Matrix: Drinking Water

Date Collected: 11/13/25
Date Received: 11/14/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: SR-00-RM-IN-KI-T3
Lab Code: R2515322-004
Sample Matrix: Drinking Water

Date Collected: 11/13/25
Date Received: 11/14/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: SR-00-HA-BY-214-T
Lab Code: R2515322-005
Sample Matrix: Drinking Water

Date Collected: 11/13/25
Date Received: 11/14/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

ALS Group USA, Corp.
dba ALS Environmental
Analyst Summary report

Client: Labella Associates, PC
Project: Webster CSD - State Road/2251107

Service Request: R2515322

Sample Name: SR-02-HA-BY -214-B
Lab Code: R2515322-006
Sample Matrix: Drinking Water

Date Collected: 11/13/25
Date Received: 11/14/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: SR-02-HA-0BY -215-T
Lab Code: R2515322-007
Sample Matrix: Drinking Water

Date Collected: 11/13/25
Date Received: 11/14/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: SR-02-HA-BY -215-B
Lab Code: R2515322-008
Sample Matrix: Drinking Water

Date Collected: 11/13/25
Date Received: 11/14/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: SR-02-HA-BY -202-DF
Lab Code: R2515322-009
Sample Matrix: Drinking Water

Date Collected: 11/13/25
Date Received: 11/14/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: SR-02-HA-BY -202-BF
Lab Code: R2515322-010
Sample Matrix: Drinking Water

Date Collected: 11/13/25
Date Received: 11/14/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

ALS Group USA, Corp.
dba ALS Environmental
Analyst Summary report

Client: Labella Associates, PC
Project: Webster CSD - State Road/2251107

Service Request: R2515322

Sample Name: SR-02-RM-IN-TL-T
Lab Code: R2515322-011
Sample Matrix: Drinking Water

Date Collected: 11/13/25
Date Received: 11/14/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: SR-02-CR-IN-201-T
Lab Code: R2515322-012
Sample Matrix: Drinking Water

Date Collected: 11/13/25
Date Received: 11/14/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: SR-02-CR-IN-201-B
Lab Code: R2515322-013
Sample Matrix: Drinking Water

Date Collected: 11/13/25
Date Received: 11/14/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: SR-01-CR-IN-101-T
Lab Code: R2515322-014
Sample Matrix: Drinking Water

Date Collected: 11/13/25
Date Received: 11/14/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: SR-01-CR-IN-101-B
Lab Code: R2515322-015
Sample Matrix: Drinking Water

Date Collected: 11/13/25
Date Received: 11/14/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

ALS Group USA, Corp.
dba ALS Environmental
Analyst Summary report

Client: Labella Associates, PC
Project: Webster CSD - State Road/2251107

Service Request: R2515322

Sample Name: SR-01-CR-IN-102-T
Lab Code: R2515322-016
Sample Matrix: Drinking Water

Date Collected: 11/13/25
Date Received: 11/14/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: SR-01-CR-IN-102-B
Lab Code: R2515322-017
Sample Matrix: Drinking Water

Date Collected: 11/13/25
Date Received: 11/14/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: SR-01-RM-IN-GLR-DF
Lab Code: R2515322-018
Sample Matrix: Drinking Water

Date Collected: 11/13/25
Date Received: 11/14/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: SR-01-RM-IN-BLR-DF
Lab Code: R2515322-019
Sample Matrix: Drinking Water

Date Collected: 11/13/25
Date Received: 11/14/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: SR-01-RM-IN-LI-T
Lab Code: R2515322-020
Sample Matrix: Drinking Water

Date Collected: 11/13/25
Date Received: 11/14/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

ALS Group USA, Corp.
dba ALS Environmental
Analyst Summary report

Client: Labella Associates, PC
Project: Webster CSD - State Road/2251107

Service Request: R2515322

Sample Name: SR-01-CR-IN-114-T1
Lab Code: R2515322-021
Sample Matrix: Drinking Water

Date Collected: 11/13/25
Date Received: 11/14/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: SR-01-CR-IN-114-T2
Lab Code: R2515322-022
Sample Matrix: Drinking Water

Date Collected: 11/13/25
Date Received: 11/14/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: SR-01-RM-IN-115B-T
Lab Code: R2515322-023
Sample Matrix: Drinking Water

Date Collected: 11/13/25
Date Received: 11/14/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: SR-01-RM-IN-MO-T
Lab Code: R2515322-024
Sample Matrix: Drinking Water

Date Collected: 11/13/25
Date Received: 11/14/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: SR-01-RM-IN-NO-T
Lab Code: R2515322-025
Sample Matrix: Drinking Water

Date Collected: 11/13/25
Date Received: 11/14/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

ALS Group USA, Corp.
dba ALS Environmental
Analyst Summary report

Client: Labella Associates, PC
Project: Webster CSD - State Road/2251107

Service Request: R2515322

Sample Name: SR-01-HA-BY -108-DF
Lab Code: R2515322-026
Sample Matrix: Drinking Water

Date Collected: 11/13/25
Date Received: 11/14/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: SR-01-HA-BY -108-BF
Lab Code: R2515322-027
Sample Matrix: Drinking Water

Date Collected: 11/13/25
Date Received: 11/14/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: SR-01-HA-BY -MO-DF
Lab Code: R2515322-028
Sample Matrix: Drinking Water

Date Collected: 11/13/25
Date Received: 11/14/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: SR-01-HA-BY -MO-BF
Lab Code: R2515322-029
Sample Matrix: Drinking Water

Date Collected: 11/13/25
Date Received: 11/14/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: SR-01-HA-BY -116-DF
Lab Code: R2515322-030
Sample Matrix: Drinking Water

Date Collected: 11/13/25
Date Received: 11/14/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

ALS Group USA, Corp.
dba ALS Environmental
Analyst Summary report

Client: Labella Associates, PC
Project: Webster CSD - State Road/2251107

Service Request: R2515322

Sample Name: SR-01-HA-BY -116-BF
Lab Code: R2515322-031
Sample Matrix: Drinking Water

Date Collected: 11/13/25
Date Received: 11/14/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: SR-00-RM-IN-KI-PF
Lab Code: R2515322-032
Sample Matrix: Drinking Water

Date Collected: 11/13/25
Date Received: 11/14/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN



PREPARATION METHODS

The preparation methods associated with this report are found in these tables unless discussed in the case narrative.

INORGANIC

Water/Liquid Matrix

| Analytical Method | Preparation Method |
|---|---|
| 200.7 / 200.8 | 200.2 |
| 6010D | 3005A/3010A |
| 6020B | ILM05.3 |
| 9034 Sulfide Acid Soluble | 9030B |
| SM 4500-CN-N-2016 Amenable and Residual Cyanide | SM 4500-CN-G and SM 4500-CN-B,C-2016 |
| SM 4500-CN-E WAD Cyanide | SM 4500-CN-I |

Solid/Soil/Non-Aqueous Matrix

| Analytical Method | Preparation Method |
|---|--------------------|
| 6010D | 3050B |
| 6010D TCLP (1311) extract | 3005A/3010A |
| 6010D SPLP (1312) extract | 3005A/3010A |
| 7199 | 3060A |
| 300.0 Anions/ 350.1/ 353.2/ SM 2320B/ SM 5210B/ 9056A Anions | DI extraction |
| For analytical methods not listed, the preparation method is the same as the analytical method reference. | |

ORGANIC

Preparation Methods for Organic methods are listed in the header of the Results pages.

Regarding "Bulk/5035A":

For soil/solid samples submitted in soil jars for Volatiles analysis, the prep method is listed as "Bulk/5035A". The lab follows the closed-system EPA 5035A protocols once the sample is transferred to a sealed vial, but collection in bulk in soil jars does not follow the collection protocols listed in EPA 5035A. In accordance with the NYSDOH technical notice of October 2012, all results or reporting limits <200 ug/kg are to be considered estimated due to potential low bias.



Sample Results

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



Metals

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - State Road/2251107
Sample Matrix: Drinking Water
Sample Name: SR-00-RM-IN-CAFE-DF
Lab Code: R2515322-001

Service Request: R2515322
Date Collected: 11/13/25 06:23
Date Received: 11/14/25 08:45
Basis: NA

Inorganic Parameters

| Analyte Name | Analysis Method | Result | Units | MRL | Dil. | Date Analyzed | Q |
|--------------|-----------------|--------|-------|-----|------|----------------|---|
| Lead, Total | 200.8 | 1.0 U | ug/L | 1.0 | 1 | 12/03/25 18:01 | |

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - State Road/2251107
Sample Matrix: Drinking Water
Sample Name: SR-00-RM-IN-CAFE-BF
Lab Code: R2515322-002

Service Request: R2515322
Date Collected: 11/13/25 06:22
Date Received: 11/14/25 08:45
Basis: NA

Inorganic Parameters

| Analyte Name | Analysis Method | Result | Units | MRL | Dil. | Date Analyzed | Q |
|--------------|-----------------|--------|-------|-----|------|----------------|---|
| Lead, Total | 200.8 | 1.0 U | ug/L | 1.0 | 1 | 12/03/25 18:02 | |

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - State Road/2251107
Sample Matrix: Drinking Water
Sample Name: SR-00-RM-IN-KI-T1
Lab Code: R2515322-003

Service Request: R2515322
Date Collected: 11/13/25 06:20
Date Received: 11/14/25 08:45
Basis: NA

Inorganic Parameters

| Analyte Name | Analysis Method | Result | Units | MRL | Dil. | Date Analyzed | Q |
|--------------|-----------------|--------|-------|-----|------|----------------|---|
| Lead, Total | 200.8 | 1.0 U | ug/L | 1.0 | 1 | 12/03/25 18:04 | |

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - State Road/2251107
Sample Matrix: Drinking Water
Sample Name: SR-00-RM-IN-KI-T3
Lab Code: R2515322-004

Service Request: R2515322
Date Collected: 11/13/25 06:21
Date Received: 11/14/25 08:45
Basis: NA

Inorganic Parameters

| Analyte Name | Analysis Method | Result | Units | MRL | Dil. | Date Analyzed | Q |
|--------------|-----------------|--------|-------|-----|------|----------------|---|
| Lead, Total | 200.8 | 1.2 | ug/L | 1.0 | 1 | 12/03/25 18:05 | |

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - State Road/2251107
Sample Matrix: Drinking Water
Sample Name: SR-00-HA-BY -214-T
Lab Code: R2515322-005

Service Request: R2515322
Date Collected: 11/13/25 07:07
Date Received: 11/14/25 08:45
Basis: NA

Inorganic Parameters

| Analyte Name | Analysis Method | Result | Units | MRL | Dil. | Date Analyzed | Q |
|--------------|-----------------|--------|-------|-----|------|----------------|---|
| Lead, Total | 200.8 | 1.0 U | ug/L | 1.0 | 1 | 12/03/25 18:07 | |

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - State Road/2251107
Sample Matrix: Drinking Water
Sample Name: SR-02-HA-BY -214-B
Lab Code: R2515322-006

Service Request: R2515322
Date Collected: 11/13/25 07:08
Date Received: 11/14/25 08:45
Basis: NA

Inorganic Parameters

| Analyte Name | Analysis Method | Result | Units | MRL | Dil. | Date Analyzed | Q |
|--------------|-----------------|--------|-------|-----|------|----------------|---|
| Lead, Total | 200.8 | 1.0 U | ug/L | 1.0 | 1 | 12/03/25 18:09 | |

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - State Road/2251107
Sample Matrix: Drinking Water
Sample Name: SR-02-HA-0BY -215-T
Lab Code: R2515322-007

Service Request: R2515322
Date Collected: 11/13/25 07:09
Date Received: 11/14/25 08:45
Basis: NA

Inorganic Parameters

| Analyte Name | Analysis Method | Result | Units | MRL | Dil. | Date Analyzed | Q |
|--------------|-----------------|--------|-------|-----|------|----------------|---|
| Lead, Total | 200.8 | 1.0 U | ug/L | 1.0 | 1 | 12/03/25 18:13 | |

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - State Road/2251107
Sample Matrix: Drinking Water
Sample Name: SR-02-HA-BY -215-B
Lab Code: R2515322-008

Service Request: R2515322
Date Collected: 11/13/25 07:10
Date Received: 11/14/25 08:45
Basis: NA

Inorganic Parameters

| Analyte Name | Analysis Method | Result | Units | MRL | Dil. | Date Analyzed | Q |
|--------------|-----------------|--------|-------|-----|------|----------------|---|
| Lead, Total | 200.8 | 1.0 U | ug/L | 1.0 | 1 | 12/03/25 18:15 | |

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - State Road/2251107
Sample Matrix: Drinking Water
Sample Name: SR-02-HA-BY -202-DF
Lab Code: R2515322-009

Service Request: R2515322
Date Collected: 11/13/25 07:04
Date Received: 11/14/25 08:45
Basis: NA

Inorganic Parameters

| Analyte Name | Analysis Method | Result | Units | MRL | Dil. | Date Analyzed | Q |
|--------------|-----------------|--------|-------|-----|------|----------------|---|
| Lead, Total | 200.8 | 1.0 U | ug/L | 1.0 | 1 | 12/03/25 18:16 | |

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - State Road/2251107
Sample Matrix: Drinking Water
Sample Name: SR-02-HA-BY -202-BF
Lab Code: R2515322-010

Service Request: R2515322
Date Collected: 11/13/25 07:05
Date Received: 11/14/25 08:45
Basis: NA

Inorganic Parameters

| Analyte Name | Analysis Method | Result | Units | MRL | Dil. | Date Analyzed | Q |
|--------------|-----------------|--------|-------|-----|------|----------------|---|
| Lead, Total | 200.8 | 1.0 U | ug/L | 1.0 | 1 | 12/03/25 18:18 | |

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - State Road/2251107
Sample Matrix: Drinking Water
Sample Name: SR-02-RM-IN-TL-T
Lab Code: R2515322-011

Service Request: R2515322
Date Collected: 11/13/25 07:00
Date Received: 11/14/25 08:45
Basis: NA

Inorganic Parameters

| Analyte Name | Analysis Method | Result | Units | MRL | Dil. | Date Analyzed | Q |
|--------------|-----------------|--------|-------|-----|------|----------------|---|
| Lead, Total | 200.8 | 2.1 | ug/L | 1.0 | 1 | 12/03/25 18:28 | |

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - State Road/2251107
Sample Matrix: Drinking Water
Sample Name: SR-02-CR-IN-201-T
Lab Code: R2515322-012

Service Request: R2515322
Date Collected: 11/13/25 07:01
Date Received: 11/14/25 08:45
Basis: NA

Inorganic Parameters

| Analyte Name | Analysis Method | Result | Units | MRL | Dil. | Date Analyzed | Q |
|--------------|-----------------|--------|-------|-----|------|----------------|---|
| Lead, Total | 200.8 | 3.9 | ug/L | 1.0 | 1 | 12/03/25 18:33 | |

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - State Road/2251107
Sample Matrix: Drinking Water
Sample Name: SR-02-CR-IN-201-B
Lab Code: R2515322-013

Service Request: R2515322
Date Collected: 11/13/25 07:02
Date Received: 11/14/25 08:45
Basis: NA

Inorganic Parameters

| Analyte Name | Analysis Method | Result | Units | MRL | Dil. | Date Analyzed | Q |
|--------------|-----------------|--------|-------|-----|------|----------------|---|
| Lead, Total | 200.8 | 4.2 | ug/L | 1.0 | 1 | 12/03/25 18:35 | |

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - State Road/2251107
Sample Matrix: Drinking Water
Sample Name: SR-01-CR-IN-101-T
Lab Code: R2515322-014

Service Request: R2515322
Date Collected: 11/13/25 06:49
Date Received: 11/14/25 08:45
Basis: NA

Inorganic Parameters

| Analyte Name | Analysis Method | Result | Units | MRL | Dil. | Date Analyzed | Q |
|--------------|-----------------|--------|-------|-----|------|----------------|---|
| Lead, Total | 200.8 | 2.1 | ug/L | 1.0 | 1 | 12/03/25 18:36 | |

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - State Road/2251107
Sample Matrix: Drinking Water
Sample Name: SR-01-CR-IN-101-B
Lab Code: R2515322-015

Service Request: R2515322
Date Collected: 11/13/25 06:50
Date Received: 11/14/25 08:45
Basis: NA

Inorganic Parameters

| Analyte Name | Analysis Method | Result | Units | MRL | Dil. | Date Analyzed | Q |
|--------------|-----------------|--------|-------|-----|------|----------------|---|
| Lead, Total | 200.8 | 1.8 | ug/L | 1.0 | 1 | 12/03/25 18:38 | |

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - State Road/2251107
Sample Matrix: Drinking Water
Sample Name: SR-01-CR-IN-102-T
Lab Code: R2515322-016

Service Request: R2515322
Date Collected: 11/13/25 06:52
Date Received: 11/14/25 08:45
Basis: NA

Inorganic Parameters

| Analyte Name | Analysis Method | Result | Units | MRL | Dil. | Date Analyzed | Q |
|--------------|-----------------|--------|-------|-----|------|----------------|---|
| Lead, Total | 200.8 | 5.0 | ug/L | 1.0 | 1 | 12/03/25 18:39 | |

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - State Road/2251107
Sample Matrix: Drinking Water
Sample Name: SR-01-CR-IN-102-B
Lab Code: R2515322-017

Service Request: R2515322
Date Collected: 11/13/25 06:53
Date Received: 11/14/25 08:45
Basis: NA

Inorganic Parameters

| Analyte Name | Analysis Method | Result | Units | MRL | Dil. | Date Analyzed | Q |
|--------------|-----------------|--------|-------|-----|------|----------------|---|
| Lead, Total | 200.8 | 1.0 U | ug/L | 1.0 | 1 | 12/03/25 18:44 | |

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - State Road/2251107
Sample Matrix: Drinking Water
Sample Name: SR-01-RM-IN-GLR-DF
Lab Code: R2515322-018

Service Request: R2515322
Date Collected: 11/13/25 06:37
Date Received: 11/14/25 08:45
Basis: NA

Inorganic Parameters

| Analyte Name | Analysis Method | Result | Units | MRL | Dil. | Date Analyzed | Q |
|--------------|-----------------|--------|-------|-----|------|----------------|---|
| Lead, Total | 200.8 | 1.0 U | ug/L | 1.0 | 1 | 12/03/25 18:45 | |

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - State Road/2251107
Sample Matrix: Drinking Water
Sample Name: SR-01-RM-IN-BLR-DF
Lab Code: R2515322-019

Service Request: R2515322
Date Collected: 11/13/25 06:34
Date Received: 11/14/25 08:45
Basis: NA

Inorganic Parameters

| Analyte Name | Analysis Method | Result | Units | MRL | Dil. | Date Analyzed | Q |
|--------------|-----------------|--------|-------|-----|------|----------------|---|
| Lead, Total | 200.8 | 1.0 U | ug/L | 1.0 | 1 | 12/03/25 18:47 | |

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - State Road/2251107
Sample Matrix: Drinking Water
Sample Name: SR-01-RM-IN-LI-T
Lab Code: R2515322-020

Service Request: R2515322
Date Collected: 11/13/25 06:33
Date Received: 11/14/25 08:45
Basis: NA

Inorganic Parameters

| Analyte Name | Analysis Method | Result | Units | MRL | Dil. | Date Analyzed | Q |
|--------------|-----------------|--------|-------|-----|------|----------------|---|
| Lead, Total | 200.8 | 4.3 | ug/L | 1.0 | 1 | 12/03/25 18:48 | |

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - State Road/2251107
Sample Matrix: Drinking Water
Sample Name: SR-01-CR-IN-114-T1
Lab Code: R2515322-021

Service Request: R2515322
Date Collected: 11/13/25 06:31
Date Received: 11/14/25 08:45
Basis: NA

Inorganic Parameters

| Analyte Name | Analysis Method | Result | Units | MRL | Dil. | Date Analyzed | Q |
|--------------|-----------------|--------|-------|-----|------|----------------|---|
| Lead, Total | 200.8 | 1.0 U | ug/L | 1.0 | 1 | 12/03/25 18:50 | |

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - State Road/2251107
Sample Matrix: Drinking Water
Sample Name: SR-01-CR-IN-114-T2
Lab Code: R2515322-022

Service Request: R2515322
Date Collected: 11/13/25 06:32
Date Received: 11/14/25 08:45

Basis: NA

Inorganic Parameters

| Analyte Name | Analysis Method | Result | Units | MRL | Dil. | Date Analyzed | Q |
|--------------|-----------------|--------|-------|-----|------|----------------|---|
| Lead, Total | 200.8 | 3.2 | ug/L | 1.0 | 1 | 12/03/25 18:51 | |

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - State Road/2251107
Sample Matrix: Drinking Water
Sample Name: SR-01-RM-IN-115B-T
Lab Code: R2515322-023

Service Request: R2515322
Date Collected: 11/13/25 06:36
Date Received: 11/14/25 08:45

Basis: NA

Inorganic Parameters

| Analyte Name | Analysis Method | Result | Units | MRL | Dil. | Date Analyzed | Q |
|--------------|-----------------|--------|-------|-----|------|----------------|---|
| Lead, Total | 200.8 | 1.0 U | ug/L | 1.0 | 1 | 12/03/25 18:53 | |

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - State Road/2251107
Sample Matrix: Drinking Water
Sample Name: SR-01-RM-IN-MO-T
Lab Code: R2515322-024

Service Request: R2515322
Date Collected: 11/13/25 06:42
Date Received: 11/14/25 08:45
Basis: NA

Inorganic Parameters

| Analyte Name | Analysis Method | Result | Units | MRL | Dil. | Date Analyzed | Q |
|--------------|-----------------|--------|-------|-----|------|----------------|---|
| Lead, Total | 200.8 | 1.0 U | ug/L | 1.0 | 1 | 12/03/25 18:55 | |

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - State Road/2251107
Sample Matrix: Drinking Water
Sample Name: SR-01-RM-IN-NO-T
Lab Code: R2515322-025

Service Request: R2515322
Date Collected: 11/13/25 06:44
Date Received: 11/14/25 08:45
Basis: NA

Inorganic Parameters

| Analyte Name | Analysis Method | Result | Units | MRL | Dil. | Date Analyzed | Q |
|--------------|-----------------|--------|-------|-----|------|----------------|---|
| Lead, Total | 200.8 | 2.9 | ug/L | 1.0 | 1 | 12/03/25 18:56 | |

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - State Road/2251107
Sample Matrix: Drinking Water
Sample Name: SR-01-HA-BY -108-DF
Lab Code: R2515322-026

Service Request: R2515322
Date Collected: 11/13/25 06:46
Date Received: 11/14/25 08:45

Basis: NA

Inorganic Parameters

| Analyte Name | Analysis Method | Result | Units | MRL | Dil. | Date Analyzed | Q |
|--------------|-----------------|--------|-------|-----|------|----------------|---|
| Lead, Total | 200.8 | 1.0 U | ug/L | 1.0 | 1 | 12/03/25 18:58 | |

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - State Road/2251107
Sample Matrix: Drinking Water
Sample Name: SR-01-HA-BY -108-BF
Lab Code: R2515322-027

Service Request: R2515322
Date Collected: 11/13/25 06:47
Date Received: 11/14/25 08:45
Basis: NA

Inorganic Parameters

| Analyte Name | Analysis Method | Result | Units | MRL | Dil. | Date Analyzed | Q |
|--------------|-----------------|--------|-------|-----|------|----------------|---|
| Lead, Total | 200.8 | 1.0 U | ug/L | 1.0 | 1 | 12/03/25 19:02 | |

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - State Road/2251107
Sample Matrix: Drinking Water
Sample Name: SR-01-HA-BY -MO-DF
Lab Code: R2515322-028

Service Request: R2515322
Date Collected: 11/13/25 06:40
Date Received: 11/14/25 08:45
Basis: NA

Inorganic Parameters

| Analyte Name | Analysis Method | Result | Units | MRL | Dil. | Date Analyzed | Q |
|--------------|-----------------|--------|-------|-----|------|----------------|---|
| Lead, Total | 200.8 | 1.0 U | ug/L | 1.0 | 1 | 12/03/25 19:04 | |

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - State Road/2251107
Sample Matrix: Drinking Water
Sample Name: SR-01-HA-BY -MO-BF
Lab Code: R2515322-029

Service Request: R2515322
Date Collected: 11/13/25 06:41
Date Received: 11/14/25 08:45
Basis: NA

Inorganic Parameters

| Analyte Name | Analysis Method | Result | Units | MRL | Dil. | Date Analyzed | Q |
|--------------|-----------------|--------|-------|-----|------|----------------|---|
| Lead, Total | 200.8 | 1.0 U | ug/L | 1.0 | 1 | 12/03/25 19:05 | |

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - State Road/2251107
Sample Matrix: Drinking Water
Sample Name: SR-01-HA-BY -116-DF
Lab Code: R2515322-030

Service Request: R2515322
Date Collected: 11/13/25 06:55
Date Received: 11/14/25 08:45
Basis: NA

Inorganic Parameters

| Analyte Name | Analysis Method | Result | Units | MRL | Dil. | Date Analyzed | Q |
|--------------|-----------------|--------|-------|-----|------|----------------|---|
| Lead, Total | 200.8 | 1.0 U | ug/L | 1.0 | 1 | 12/03/25 19:07 | |

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - State Road/2251107
Sample Matrix: Drinking Water
Sample Name: SR-01-HA-BY -116-BF
Lab Code: R2515322-031

Service Request: R2515322
Date Collected: 11/13/25 06:56
Date Received: 11/14/25 08:45
Basis: NA

Inorganic Parameters

| Analyte Name | Analysis Method | Result | Units | MRL | Dil. | Date Analyzed | Q |
|--------------|-----------------|--------|-------|-----|------|----------------|---|
| Lead, Total | 200.8 | 1.0 U | ug/L | 1.0 | 1 | 12/03/25 19:18 | |

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - State Road/2251107
Sample Matrix: Drinking Water
Sample Name: SR-00-RM-IN-KI-PF
Lab Code: R2515322-032

Service Request: R2515322
Date Collected: 11/13/25 06:25
Date Received: 11/14/25 08:45
Basis: NA

Inorganic Parameters

| Analyte Name | Analysis Method | Result | Units | MRL | Dil. | Date Analyzed | Q |
|--------------|-----------------|--------|-------|-----|------|----------------|---|
| Lead, Total | 200.8 | 3.4 | ug/L | 1.0 | 1 | 12/03/25 19:22 | |



QC Summary Forms

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



Metals

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - State Road/2251107
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2515322-MB1

Service Request: R2515322
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

| Analyte Name | Analysis Method | Result | Units | MRL | Dil. | Date Analyzed | Q |
|--------------|-----------------|--------|-------|-----|------|----------------|---|
| Lead, Total | 200.8 | 1.0 U | ug/L | 1.0 | 1 | 12/03/25 18:25 | |

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - State Road/2251107
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2515322-MB2

Service Request: R2515322
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

| Analyte Name | Analysis Method | Result | Units | MRL | Dil. | Date Analyzed | Q |
|--------------|-----------------|--------|-------|-----|------|----------------|---|
| Lead, Total | 200.8 | 1.0 U | ug/L | 1.0 | 1 | 12/03/25 17:36 | |

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - State Road/2251107
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2515322-MB3

Service Request: R2515322
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

| Analyte Name | Analysis Method | Result | Units | MRL | Dil. | Date Analyzed | Q |
|--------------|-----------------|--------|-------|-----|------|----------------|---|
| Lead, Total | 200.8 | 1.0 U | ug/L | 1.0 | 1 | 12/03/25 19:14 | |

QA/QC Report

Client: Labella Associates, PC
Project: Webster CSD - State Road/2251107
Sample Matrix: Drinking Water

Service Request: R2515322
Date Collected: 11/13/25
Date Received: 11/14/25
Date Analyzed: 12/3/25

Duplicate Matrix Spike Summary
Inorganic Parameters

Sample Name: SR-02-HA-BY-202-BF
Lab Code: R2515322-010
Analysis Method: 200.8

Units: ug/L
Basis: NA

| Analyte Name | Sample Result | Result | Matrix Spike R2515322-010MS | | Result | Duplicate Matrix Spike R2515322-010DMS | | % Rec Limits | RPD | RPD Limit |
|--------------|---------------|--------|--------------------------------|-------|--------|---|-------|-----------------|-----|--------------|
| | | | Spike Amount | % Rec | | Spike Amount | % Rec | | | |
| Lead, Total | 1.0 U | 19.1 | 20.0 | 96 | 19.5 | 20.0 | 98 | 70-130 | 2 | 20 |

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

QA/QC Report

Client: Labella Associates, PC
Project: Webster CSD - State Road/2251107
Sample Matrix: Drinking Water

Service Request: R2515322
Date Collected: 11/13/25
Date Received: 11/14/25
Date Analyzed: 12/3/25

Duplicate Matrix Spike Summary
Inorganic Parameters

Sample Name: SR-02-RM-IN-TL-T
Lab Code: R2515322-011
Analysis Method: 200.8

Units: ug/L
Basis: NA

| Analyte Name | Sample Result | Result | Matrix Spike R2515322-011MS | | Result | Duplicate Matrix Spike R2515322-011DMS | | % Rec Limits | RPD | RPD Limit |
|--------------|---------------|--------|--------------------------------|-------|--------|---|-------|-----------------|-----|--------------|
| | | | Spike Amount | % Rec | | Spike Amount | % Rec | | | |
| Lead, Total | 2.1 | 21.7 | 20.0 | 98 | 21.5 | 20.0 | 97 | 70-130 | <1 | 20 |

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

QA/QC Report

Client: Labella Associates, PC
Project: Webster CSD - State Road/2251107
Sample Matrix: Drinking Water

Service Request: R2515322
Date Collected: 11/13/25
Date Received: 11/14/25
Date Analyzed: 12/3/25

Duplicate Matrix Spike Summary
Inorganic Parameters

Sample Name: SR-01-HA-BY -116-DF
Lab Code: R2515322-030
Analysis Method: 200.8

Units: ug/L
Basis: NA

| Analyte Name | Sample Result | Result | Matrix Spike R2515322-030MS | | Result | Duplicate Matrix Spike R2515322-030DMS | | % Rec Limits | RPD | RPD Limit |
|--------------|---------------|--------|--------------------------------|-------|--------|---|-------|-----------------|-----|--------------|
| | | | Spike Amount | % Rec | | Spike Amount | % Rec | | | |
| Lead, Total | 1.0 U | 19.3 | 20.0 | 96 | 19.1 | 20.0 | 95 | 70-130 | 1 | 20 |

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

QA/QC Report

Client: Labella Associates, PC
Project: Webster CSD - State Road/2251107
Sample Matrix: Drinking Water

Service Request: R2515322
Date Collected: 11/13/25
Date Received: 11/14/25
Date Analyzed: 12/3/25

Duplicate Matrix Spike Summary
Inorganic Parameters

Sample Name: SR-01-HA-BY -116-BF
Lab Code: R2515322-031
Analysis Method: 200.8

Units: ug/L
Basis: NA

| Analyte Name | Sample Result | Result | Matrix Spike R2515322-031MS | | Result | Duplicate Matrix Spike R2515322-031DMS | | % Rec Limits | RPD | RPD Limit |
|--------------|---------------|--------|--------------------------------|-------|--------|---|-------|-----------------|-----|--------------|
| | | | Spike Amount | % Rec | | Spike Amount | % Rec | | | |
| Lead, Total | 1.0 U | 19.3 | 20.0 | 96 | 20.0 | 20.0 | 100 | 70-130 | 4 | 20 |

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

QA/QC Report

Client: Labella Associates, PC
Project: Webster CSD - State Road/2251107
Sample Matrix: Drinking Water

Service Request: R2515322
Date Analyzed: 12/03/25

Lab Control Sample Summary
Inorganic Parameters

Units: ug/L
Basis: NA

Lab Control Sample
R2515322-LCS1

| Analyte Name | Analytical Method | Result | Spike Amount | % Rec | % Rec Limits |
|--------------|-------------------|--------|--------------|-------|--------------|
| Lead, Total | 200.8 | 19.5 | 20.0 | 98 | 85-115 |

QA/QC Report

Client: Labella Associates, PC
Project: Webster CSD - State Road/2251107
Sample Matrix: Drinking Water

Service Request: R2515322
Date Analyzed: 12/03/25

Lab Control Sample Summary
Inorganic Parameters

Units: ug/L
Basis: NA

Lab Control Sample
R2515322-LCS2

| Analyte Name | Analytical Method | Result | Spike Amount | % Rec | % Rec Limits |
|--------------|-------------------|--------|--------------|-------|--------------|
| Lead, Total | 200.8 | 19.0 | 20.0 | 95 | 85-115 |

QA/QC Report

Client: Labella Associates, PC
Project: Webster CSD - State Road/2251107
Sample Matrix: Drinking Water

Service Request: R2515322
Date Analyzed: 12/03/25

Lab Control Sample Summary
Inorganic Parameters

Units: ug/L
Basis: NA

Lab Control Sample
R2515322-LCS3

| Analyte Name | Analytical Method | Result | Spike Amount | % Rec | % Rec Limits |
|--------------|-------------------|--------|--------------|-------|--------------|
| Lead, Total | 200.8 | 20.2 | 20.0 | 101 | 85-115 |



**APPENDIX C:
LICENSES AND CERTIFICATIONS**

United States Environmental Protection Agency

This is to certify that

LaBella Associates, D.P.C.

has fulfilled the requirements of the Toxic Substances Control Act (TSCA) Section 402, and has received certification to conduct lead-based paint activities pursuant to 40 CFR Part 745.226

In the Jurisdiction of:

All EPA Administered Lead-based Paint Activities Program States, Tribes and Territories

This certification is valid from the date of issuance and expires September 26, 2027

LBP-2226-3

Certification #

August 01, 2024

Issued On



A handwritten signature in black ink, appearing to read "Marc Edmonds".

Marc Edmonds, Chief

Risk Assessment Management Branch 2.

United States Environmental Protection Agency

This is to certify that



Cory J Stamp

has fulfilled the requirements of the Toxic Substances Control Act (TSCA) Section 402, and has received certification to conduct lead-based paint activities pursuant to 40 CFR Part 745.226 as:

Risk Assessor

In the Jurisdiction of:

All EPA Administered Lead-based Paint Activities Program States, Tribes and Territories

This certification is valid from the date of issuance and expires October 24, 2028

LBP-R-I206349-3

Certification #

October 15, 2025

Issued On



A handwritten signature in black ink that reads "Ben Conetta".

Ben Conetta, Manager

Chemicals and Multimedia Programs Branch

NEW YORK STATE DEPARTMENT OF HEALTH
WADSWORTH CENTER



Expires 12:01 AM April 01, 2026
Issued April 01, 2025

CERTIFICATE OF APPROVAL FOR LABORATORY SERVICE

Issued in accordance with and pursuant to section 502 Public Health Law of New York State

MS. CHRISTINE KUTZER
ALS ENVIRONMENTAL - ROCHESTER
1565 JEFFERSON ROAD BUILDING 300, SUITE 360
ROCHESTER, NY 14623

NY Lab Id No: 10145

*is hereby APPROVED as an Environmental Laboratory in conformance with the
National Environmental Laboratory Accreditation Conference Standards (2016) for the category
ENVIRONMENTAL ANALYSES POTABLE WATER
All approved analytes are listed below:*

Bacteriology

Coliform, Total / E. coli (Qualitative) SM 20, 21-23 9223B (-04) (Colilert)

Dissolved Gases

Acetylene RSK-175
Ethane RSK-175
Ethene (Ethylene) RSK-175
Methane RSK-175
Propane RSK-175

Fuel Additives

Methyl tert-butyl ether EPA 524.2
Naphthalene EPA 524.2

Metals I

Arsenic, Total EPA 200.8 Rev. 5.4
Barium, Total EPA 200.8 Rev. 5.4
Cadmium, Total EPA 200.8 Rev. 5.4
Chromium, Total EPA 200.7 Rev. 4.4
Copper, Total EPA 200.8 Rev. 5.4
Iron, Total EPA 200.7 Rev. 4.4
Lead, Total EPA 200.8 Rev. 5.4
Manganese, Total EPA 200.7 Rev. 4.4
Mercury, Total EPA 245.1 Rev. 3.0
Selenium, Total EPA 200.8 Rev. 5.4
Silver, Total EPA 200.7 Rev. 4.4
Zinc, Total EPA 200.7 Rev. 4.4



Serial No.: 70111

Property of the New York State Department of Health. Certificates are valid only at the address shown and must be conspicuously posted by the laboratory. Continued accreditation depends on the laboratory's successful ongoing participation in the Program. Consumers may verify a laboratory's accreditation status online at <https://apps.health.ny.gov/pubdoh/applinks/wc/elappublicweb/>, by phone (518) 485-5570 or by email to elap@health.ny.gov.

