

Lead in Drinking Water Testing – Webster Thomas High School

Location:

Webster Central School District
1028 Ridge Road, Suite 12
Webster, New York 14580



LaBella Project No.

2251107

January 13, 2026



Table of Contents

1.0	BACKGROUND	1
2.0	SAMPLING PROCEDURES	1
3.0	RESULTS	2
3.1	<i>Total Water Sample Summary</i>	2
4.0	RESPONSE MEASURES	2
4.1	<i>Immediate Response</i>	Error! Bookmark not defined.
4.2	<i>Short-Term Control Measures</i>	Error! Bookmark not defined.
4.3	<i>Permanent Control Measures</i>	Error! Bookmark not defined.
5.0	REPORTING AND RECORD KEEPING	2

Appendices

Appendix A – Detailed Results Spreadsheet

Appendix B – Laboratory Analytical Results

Appendix C – Licenses and Certifications



1.0 BACKGROUND

LaBella Associates, D.P.C. (LaBella) sampled potable water outlets throughout the Webster Central School District (WCSD) in accordance with Subpart 67-4 of Title 10 of the New York State Codes, Rules, and Regulations (Subpart 67-4). Under Subpart 67-4, “all school districts and boards of cooperative educational services are required to test potable water for lead contamination, and to develop and implement a lead remediation plan, where applicable.”

Lead contamination is a significant public health concern. Lead has been linked to various harmful conditions such as central nervous system and kidney damage. Children, especially those under the age of 6, are particularly susceptible to the toxic effects of lead. There is no known safe level of lead in blood, and the US Environmental Protection Agency (USEPA) has set a Maximum Contaminant Level Goal of zero. As of 2022, Subpart 67-4 establishes an action level of 5 parts per billion (ppb) in school drinking water. If test results exceed this level, the district must undertake remedial action.

The Subpart 67-4 testing requirement was first promulgated under emergency legislation in 2016, and subsequently signed into permanent law. Subsequently, Senate Bill S2122A was signed into law on December 22, 2022, changing various components of Subpart 67-4. Key revisions to the standard include a reduced action level down to 5 parts per billion (ppb), and requires that testing be performed every three years. The next round of sampling reports are due by the end of 2025. This report has been designed to fulfill the initial testing and reporting requirements outlined in Subpart 67-4.

LaBella conducted the initial water sampling at the Webster Thomas High School located at 800 Five Mile Line Road in Webster, NY in two separate sampling events. The first sampling round was conducted on November 7, 2025, in order to sample exterior outlets prior to them being shut down for the winter. The second round of sampling on December 17, 2025, consisted of the sampling of the remaining applicable outlets within the school.

Outlets that were selected for sampling include drinking fountains, bottle fillers, kitchen sinks, classroom sinks, medical office sinks, and ice machines. Outlets categorically excluded from testing included laboratory sinks, bathroom sinks, art room sinks, single-handle faucets, showers, toilets, janitor’s sinks, and mechanical room outlets. Typically, excluded outlets are capable of being isolated by custodial staff, and will require warning signs to prohibit consumption.

2.0 SAMPLING PROCEDURES

The target water fixtures were left to stagnate for a period of 8 to 18 hours prior to the start of the sampling. The water conditions were reported to be representative of normal consumptive patterns with building occupancy controlled during stagnation and sampling periods.

In accordance with Subpart 67-4 requirements, sampling was limited to “first-draw” samples. A volume of the first 250 mL of water was taken from each cold-water fixture in the sampling inventory.

The samples were then promptly packaged and shipped to a NYS Department of Health Environmental Laboratory Approval Program (ELAP) accredited laboratory. Samples were analyzed utilizing EPA environmental analysis method 200.8 for lead in potable water. Results from the sampling rounds were then delivered to WCSD.



3.0 RESULTS

3.1 Total Water Sample Summary

The following table summarizes the results from the sampling rounds:

Webster Thomas High School – Water Sample Summary		
Building	Number of Total Samples	Number of Fixtures above Action Level
Webster Thomas High School	57	0

Based on laboratory analyses of the samples collected, none of the outlets were determined to exceed the Subpart 67-4 action level of 5 micrograms per liter ($\mu\text{g}/\text{L}$).

For a full list of fixtures sampled, see Appendix A.

4.0 RESPONSE MEASURES

According to section Subpart 67-4.4 “Response” of the regulation, school districts shall prohibit the use of all outlets which exceed the 5 ppb ($\mu\text{g}/\text{L}$) action level. These outlets shall remain out of service until a lead remediation plan is implemented to reduce the level of lead, and resampling indicates lead levels at or below the action level. While the outlet is out of service, the district must supply an appropriate amount of potable water for drinking or cooking to building occupants.

As no outlets were found to exceed the action level as part of this sampling round, no response measure are necessary at this time.

5.0 REPORTING AND RECORD KEEPING

In accordance with Subpart 67-4 the district shall:

1. Report the test results to the local health department as soon as practicable, but no more than 1 business day after the school received the laboratory report.
2. Notify all staff and all persons in parental relation to children or students of the test results, in writing, as soon as practicable, but no more than 10 business days after the school received the laboratory report.
3. The school shall make available, on the school’s website, the results of all lead testing performed and lead remediation plans implemented pursuant to Subpart 67-4, as soon as practicable, but no more than 6 weeks after the school received the laboratory reports.
4. As soon as practicable, but no more than 10 business days after the school received the laboratory reports, the school shall report data relating to test results to the NYS Health Department, local health department, and NYS Education Department, through the NYS Health Department’s designated statewide electronic reporting system.
5. The school shall retain all records of test results, lead remediation plans, and waiver requests, for ten years following the creation of such documentation. Copies of such documentation



shall be immediately provided to the NYS Health Department, local health department, or NYS Education Department, upon request.



APPENDIX A:
DETAILED RESULTS SPREADSHEET

Webster Thomas High School				
Identification Code	Description	Date Sampled	Time Sampled	Result (µg/L)
THS-01-KIT-IN-445-T5	Kitchen 445 East Standalone Tap	12/17/2025	0555	<1.00
THS-01-KIT-IN-445-PFL	Kitchen 445 Left Hand Pot Filler	12/17/2025	0556	<1.00
THS-01-KIT-IN-445-CTL	Kitchen 445 Left Coffee Tap	12/17/2025	0558	<1.00
THS-01-KIT-IN-445-CTR	Kitchen 445 Right Coffee Tap	12/17/2025	0558	2.8
THS-01-KIT-IN-445-PFR	Kitchen 445 Right Hand Pot Filler	12/17/2025	0558	<1.00
THS-01-KIT-IN-445-T1	Kitchen Prep Area Right Tap	12/17/2025	0559	<1.00
THS-01-KIT-IN-445-T2	Tap Near Northern Serving Area in Kitchen 445	12/17/2025	0559	<1.00
THS-01-KIT-IN-445-T3	Kitchen 445 Southeast Corner Left Sink	12/17/2025	0600	<1.00
THS-01-RM-IN-422-T1	Tap In Room 422 Closest to Hallway (Left Tap)	12/17/2025	0624	1.5
THS-01-RM-IN-422-T2	Tap In Room 422 Furthest From Hallway (Right Tap)	12/17/2025	0624	<1.00
THS-01-RM-IN-422-IM	Ice Machine In Room 422	12/17/2025	0625	<1.00
THS-01-HA-BY-402-DFL	Hallway by Room 402 Left Drinking Fountain	12/17/2025	0635	<1.00
THS-01-HA-BY-402-BFL	Hallway by Room 402 Left Bottle Filler	12/17/2025	0636	<1.00
THS-01-HA-BY-402-DFR	Hallway by Room 402 Right Drinking Fountain	12/17/2025	0637	<1.00
THS-01-HA-BY-402-BFR	Hallway by Room 402 Bottle Filler	12/17/2025	0638	<1.00
THS-01-HA-BY-212-DF	Hallway by Room 212 Drinking Fountain	12/17/2025	0647	<1.00
THS-01-HA-BY-212-BF	Hallway by Room 212 Bottle Filler	12/17/2025	0647	<1.00
THS-01-RM-IN-251-T	Tap In Room 251	12/17/2025	0648	<1.00
THS-01-HA-BY-236-DF	Hallway by Room 236 Drinking Fountain	12/17/2025	0648	<1.00
THS-01-HA-BY-236-BF	Hallway by Room 236 Bottle Filler	12/17/2025	0648	<1.00
THS-01-RM-IN-TR-T	Training Room Tap	12/17/2025	0650	<1.00
THS-01-CR-IN-145-T	Classroom 145 Tap	12/17/2025	0655	<1.00
THS-01-RM-IN-240-T	Tap In Room 240	12/17/2025	0655	1.1
THS-01-HA-BY-CAFE-DFL	Hallway by South Cafeteria Left Drinking Fountain	12/17/2025	0705	<1.00
THS-01-HA-BY-CAFE-BFL	Hallway by South Cafeteria Left Bottle Filler	12/17/2025	0706	<1.00
THS-01-HA-BY-CAFE-DFR	Hallway by South Cafeteria Right Drinking Fountain	12/17/2025	0707	<1.00
THS-01-HA-BY-CAFE-BFR	Hallway by South Cafeteria Bottle Filler	12/17/2025	0708	<1.00
THS-01-RM-IN-POOL-DF	Pool Drinking Fountain	12/17/2025	0710	<1.00
THS-01-RM-IN-POOL-BF	Pool Bottle Filler	12/17/2025	0711	<1.00
TTF-01-OD-IN-FNCE-B2	Turf Field Outdoor Right Hand Bubbler	11/7/2025	0713	<1.00
TTF-01-OD-IN-FNCE-B1	Turf Field Outdoor Left Hand Bubbler	11/7/2025	0714	<1.00
TTF-01-RM-IN-CONC-T	Tap In Outdoor Concessions Stand	11/7/2025	0715	3.1

Webster Thomas High School				
Identification Code	Description	Date Sampled	Time Sampled	Result (µg/L)
THS-01-HA-BY-GYM-DFL	Hallway by Gym Left Drinking Fountain	12/17/2025	0715	<1.00
TTF-01-RM-IN-CONC-CT	Coffee Tap In Outdoor Concessions Stand	11/7/2025	0716	<1.00
THS-01-HA-BY-GYM-BFL	Hallway by Gym Left Bottle Filler	12/17/2025	0716	<1.00
THS-01-HA-BY-GYM-DFR	Hallway by Gym Right Drinking Fountain	12/17/2025	0717	<1.00
TTF-01-OD-BY-TURF-T1	Water Tree by Turf Field Spout 1	11/7/2025	0718	1.1
THS-01-HA-BY-GYM-BFR	Hallway by Gym Bottle Filler	12/17/2025	0718	<1.00
TTF-01-OD-BY-TURF-T2	Water Tree by Turf Field Spout 2	11/7/2025	0719	1.3
THS-01-HA-BY-GCONC-DF	Hallway by Gym Concession Stand Drinking Fountain	12/17/2025	0719	<1.00
TTF-01-OD-BY-TURF-T3	Water Tree by Turf Field Spout 3	11/7/2025	0720	1.3
THS-01-HA-BY-GCONC-BF	Hallway by Gym Concession Stand Bottle Filler	12/17/2025	0720	<1.00
TTF-01-OD-BY-TURF-T4	Water Tree by Turf Field Spout 4	11/7/2025	0721	2.7
THS-01-HA-BY-216-DFL	Hallway by West Library Left Drinking Fountain	12/17/2025	0721	<1.00
THS-01-HA-BY-216-DFR	Hallway by West Library Right Drinking Fountain	12/17/2025	0722	1.2
THS-01-RM-IN-C243-T	Tap in Receiving Room C243	12/17/2025	0724	<1.00
THS-01-FR-IN-A134-T	Tap in Faculty Break Room A134	12/17/2025	0725	3.3
THS-01-CR-IN-303-IM	Classroom 303 Ice Machine	12/17/2025	0728	<1.00
THS-01-RM-IN-328-T	Tap In Room 328	12/17/2025	0728	<1.00
THS-01-FH-IN-470-DF1	Field House 470 - Northwest Left Drinking Fountain	12/17/2025	0728	<1.00
THS-01-RM-IN-332-T	Tap In Room 332	12/17/2025	0729	<1.00
THS-01-FH-IN-470-DF2	Field House 470 - Northwest Right Drinking Fountain	12/17/2025	0729	<1.00
THS-01-FH-IN-470-DF3	Field House 470 - Northeast Left Drinking Fountain	12/17/2025	0730	<1.00
THS-01-FH-IN-470-DF4	Field House 470 - Northeast Right Drinking Fountain	12/17/2025	0731	<1.00
THS-01-FH-IN-470-BF	Field House 470 - Northeast Bottle Filler	12/17/2025	0732	<1.00
THS-01-RM-IN-TR-IM	Training Room Ice Machine	12/17/2025	0734	<1.00
THS-01-CONC-IN-470B-T	Tap In Concessions Stand	12/17/2025	0741	<1.00



APPENDIX B:
LABORATORY ANALYTICAL
REPORTS



December 08, 2025

Service Request No:R2515005

Cory Stamp
Labella Associates, PC
300 State Street, 2nd Floor
Suite 201
Rochester, NY 14614

Laboratory Results for: Webster CSD - Thomas

Dear Cory,

Enclosed are the results of the sample(s) submitted to our laboratory November 07, 2025
For your reference, these analyses have been assigned our service request number R2515005.

All testing was performed according to our laboratory's quality assurance program and met the requirements of the TNI standards except as noted in the case narrative report. Any testing not included in the lab's accreditation is identified on a Non-Certified Analytes report. All results are intended to be considered in their entirety. ALS Environmental is not responsible for use of less than the complete report. Results apply only to the individual samples submitted to the lab for analysis, as listed in the report. The measurement uncertainty of the results included in this report is within that expected when using the prescribed method(s), and represented by Laboratory Control Sample control limits. Any events, such as QC failures or Holding Time exceedances, which may add to the uncertainty are explained in the report narrative or are flagged with qualifiers. The flags are explained in the Report Qualifiers and Definitions page of this report.

Please contact me if you have any questions. My extension is 7475. You may also contact me via email at Meghan.Pedro@alsglobal.com.

Respectfully submitted,

ALS Group USA, Corp. dba ALS Environmental

Meghan Pedro
Project Manager

ADDRESS 1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
PHONE +1 585 288 5380 | FAX +1 585 288 8475
ALS Group USA, Corp.
dba ALS Environmental



Narrative Documents

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



Client: Labella Associates, PC
Project: Webster CSD - Thomas
Sample Matrix: Drinking Water

Service Request: R2515005
Date Received: 11/07/2025

CASE NARRATIVE

All analyses were performed consistent with the quality assurance program of ALS Environmental. This report contains analytical results for samples for the Tier II level requested by the client.

Sample Receipt:

Eight drinking water samples were received for analysis at ALS Environmental on 11/07/2025. Any discrepancies upon initial sample inspection are annotated on the sample receipt and preservation form included within this report. The samples were stored at minimum in accordance with the analytical method requirements.

Metals:

No significant anomalies were noted with this analysis.

A handwritten signature in black ink that reads "Meghan Pedro".

Approved by _____

Date 12/08/2025



SAMPLE DETECTION SUMMARY

This form includes only detections above the reporting levels. For a full listing of sample results, continue to the Sample Results section of this Report.

CLIENT ID: TTF-01-RM-IN-CONC-T			Lab ID: R2515005-003			
--------------------------------	--	--	----------------------	--	--	--

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	3.1			1.0	ug/L	200.8

CLIENT ID: TTF-01-OD-BY-TURF-T1			Lab ID: R2515005-005			
---------------------------------	--	--	----------------------	--	--	--

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.1			1.0	ug/L	200.8

CLIENT ID: TTF-01-OD-BY-TURF-T2			Lab ID: R2515005-006			
---------------------------------	--	--	----------------------	--	--	--

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.3			1.0	ug/L	200.8

CLIENT ID: TTF-01-OD-BY-TURF-T3			Lab ID: R2515005-007			
---------------------------------	--	--	----------------------	--	--	--

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.3			1.0	ug/L	200.8

CLIENT ID: TTF-01-OD-BY-TURF-T4			Lab ID: R2515005-008			
---------------------------------	--	--	----------------------	--	--	--

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	2.7			1.0	ug/L	200.8



Sample Receipt Information

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

Client: Labella Associates, PC
Project: Webster CSD - Thomas/2251107

Service Request:R2515005

SAMPLE CROSS-REFERENCE

<u>SAMPLE #</u>	<u>CLIENT SAMPLE ID</u>	<u>DATE</u>	<u>TIME</u>
R2515005-001	TTF-01-OD-IN-FNCE-B2	11/7/2025	0713
R2515005-002	TTF-01-OD-IN-FNCE-B1	11/7/2025	0714
R2515005-003	TTF-01-RM-IN-CONC-T	11/7/2025	0715
R2515005-004	TTF-01-RM-IN-CONC-CT	11/7/2025	0716
R2515005-005	TTF-01-OD-BY-TURF-T1	11/7/2025	0718
R2515005-006	TTF-01-OD-BY-TURF-T2	11/7/2025	0719
R2515005-007	TTF-01-OD-BY-TURF-T3	11/7/2025	0720
R2515005-008	TTF-01-OD-BY-TURF-T4	11/7/2025	0721



ALS Environmental

Laboratory location:
Rochester, NY

Chain of Custody Form

Page 1 of 1

R2515005

LaBella Associates, PC
Webster CSD - Thomas

5



Customer Information			Project Information				Parameter/Method Request for Analysis											
Purchase Order		Project Name	Webster CSD - Thomas		A	EPA 200.8 Lead in Drinking Water												
Work Order		Project Number	2251107		B													
Company Name	LaBella Associates	Bill To Company	LaBella Associates		C													
Send Report To	Cory Stamp	Invoice Attn	Cory Stamp		D													
Address	300 State Street, Suite 200	Address	300 State Street, Suite 200		E													
					F													
City/State/Zip	Rochester, NY 14614	City/State/Zip	Rochester, NY 14614		G													
Phone	(607) 591-7516	Phone	(607) 591-7516		H													
Fax		Fax			I													
e-Mail Address	cstamp@labellapc.com	e-Mail Address	cstamp@labellapc.com		J													
No	Sample Description	Date	Time	Matrix	Pres.	# Bottles	A	B	C	D	E	F	G	H	I	J	Hold	
1	TTF-01-OD-IN-FNCE-B2	11/07/25	7:13 AM		N/A		X											
2	TTF-01-OD-IN-FNCE-B1	11/07/25	7:14 AM		N/A		X											
3	TTF-01-RM-IN-CONC-T	11/07/25	7:15 AM		N/A		X											
4	TTF-01-RM-IN-CONC-CT	11/07/25	7:16 AM		N/A		X											
5	TTF-01-OD-BY-TURF-T1	11/07/25	7:18 AM		N/A		X											
6	TTF-01-OD-BY-TURF-T2	11/07/25	7:19 AM		N/A		X											
7	TTF-01-OD-BY-TURF-T3	11/07/25	7:20 AM		N/A		X											
8	TTF-01-OD-BY-TURF-T4	11/07/25	7:21 AM		N/A		X											
9																		
10																		
Sampler(s): Please Print & Sign <i>Cory Stamp</i>			Shipment Method: Delivered		Required Turnaround Time: <input checked="" type="checkbox"/> STD 10 Wk Days <input type="checkbox"/> 5 Wk Days <input type="checkbox"/> 2 Wk Days <input type="checkbox"/> 24 Hour				Results Due Date:									
Relinquished by: <i>[Signature]</i>		Date: 11/7/25	Time: 1530	Received by: <i>[Signature]</i>		Notes:												
Relinquished by:		Date:	Time:	Received by (Laboratory):		Cooler Temp.	QC Package: (Check Box Below)											
Logged by (Laboratory):		Date:	Time:	Checked by (Laboratory):			<input type="checkbox"/> Level II: Standard QC				TRRP-Checklist							
							<input type="checkbox"/> Level III: Std QC + Raw Data				TRRP Level IV							
							<input type="checkbox"/> Level IV: SW846 CLP-Like											
Preservative Key: 1-HCL 2-HNO3 3-H2SO4 4-NaOH 5-Na2S2O3 6-NaHSO4 7-Other 8-4 degrees C 9-5035						Other:												

Note: Any changes must be made in writing once samples and COC Form have been submitted to ALS Laboratory Group.

Signature denotes acceptance of ALS Group USA, Corp. Terms and Conditions - Please click the link below for detailed Terms & Conditions:

<https://www.alsglobal.com/ALSGroupUSACorpTC>

ALS copyright © 2024. All rights reserved.



R2515005

5

Labella Associates, PC
Webster CSD - Thomas



Cooler Receipt and Preservation Check Form

Project/Client _____ Folder Number _____

Cooler received on 11/7/25 by: _____

COURIER: ALS UPS FEDEX VELOCITY CLIENT

1	Were Custody seals on outside of cooler?	Y <u>N</u>
2	Custody papers properly completed (ink, signed)?	<u>Y</u> N
3	Did all bottles arrive in good condition (unbroken)?	<u>Y</u> N
4	Circle: Wet Ice Dry Ice Gel packs present?	Y <u>N</u>

5a	Did VOA vials have sig* bubbles?	Y N <u>NA</u>
5b	Sig* bubbles: Alk? Y N <u>NA</u>	Sulfide? Y N <u>NA</u>
6	Where did the bottles originate?	<u>ALS/ROC</u> CLIENT
7	Soil VOA received as: Bulk Encore 5035set	<u>NA</u>

8. Temperature Readings Date: 11/10/25 Time: 11:10 ID: IR#12 IR#11 From: Temp Blank Sample Bottle

Temp (°C)	<u>17.2</u>						
Within 0-6°C?	Y <u>N</u>	Y N	Y N	Y N	Y N	Y N	Y N
If <0°C, were samples frozen?	Y N	Y N	Y N	Y N	Y N	Y N	Y N

If out of Temperature, note packing/ice condition: No ice Ice melted Poorly Packed (described below) Same Day Rule
& Client Approval to Run Samples: _____ Standing Approval Client aware at drop-off Client notified by: _____

All samples held in storage location: SMO by Rm on 11/10 at 11:12
5035 samples placed in storage location: _____ by _____ on _____ at _____ within 48 hours of sampling? Y N

Cooler Breakdown/Preservation Check**: Date: 11/14/25 Time: 1045 by: NM

- 9. Were all bottle labels complete (i.e. analysis, preservation, etc.)? YES NO
- 10. Did all bottle labels and tags agree with custody papers? YES NO
- 11. Were correct containers used for the tests indicated? YES NO
- 12. Were 5035 vials acceptable (no extra labels; not leaking)? YES NO N/A
- 13. Were dissolved metals filtered in the field? YES NO N/A
- 14. Air Samples: Cassettes / Tubes Intact Y/N with MS Y/N Canisters Pressurized Tedlar® Bags Inflated N/A

pH	Lot of test paper	Reagent	Preserved?		Lot Received	Exp	Sample ID Adjusted	Vol. Added	Lot Added	Final pH
			Yes	No						
≥12		NaOH								
≤2		HNO ₃		✓			<u>All</u>	<u>4.0ml</u>	<u>245078</u>	<u>22.0</u>
≤2		H ₂ SO ₄								
<4		NaHSO ₄								
5-9		For 608pest			No=Notify for 3day					
Residual Chlorine (-)		For CN, Phenol, 625, 608pest, 522			If +, contact PM to add Na ₂ S ₂ O ₃ (625, 608, CN), ascorbic (phenol).					
		Na ₂ S ₂ O ₃								
		ZnAcetate	-	-						
		HCl	**	**						

**VOAs and 1664 Not to be tested before analysis. Otherwise, all bottles of all samples with chemical preservatives are checked (not just representatives).

Bottle lot numbers: _____
Explain all Discrepancies/ Other Comments: _____

HPROD	BULK
HTR	FLDT
SUB	HGFB
ALS	LL3541

Labels secondary reviewed by: TOP *significant air bubbles: VOA > 5-6 mm : WC > 1 in. diameter



Miscellaneous Forms

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



REPORT QUALIFIERS AND DEFINITIONS

- U Analyte was analyzed for but not detected. The sample quantitation limit has been corrected for dilution and for percent moisture, unless otherwise noted in the case narrative.
- J Estimated value due to either being a Tentatively Identified Compound (TIC) or that the concentration is between the MRL and the MDL. Concentrations are not verified within the linear range of the calibration. For DoD: concentration >40% difference between two GC columns (pesticides/Aroclors).
- B Analyte was also detected in the associated method blank at a concentration that may have contributed to the sample result.
- E Inorganics- Concentration is estimated due to the serial dilution was outside control limits.
- E Organics- Concentration has exceeded the calibration range for that specific analysis.
- D Concentration is a result of a dilution, typically a secondary analysis of the sample due to exceeding the calibration range or that a surrogate has been diluted out of the sample and cannot be assessed.
- * Indicates that a quality control parameter has exceeded laboratory limits. Under the "Notes" column of the Form I, this qualifier denotes analysis was performed out of Holding Time.
- H Analysis was performed out of hold time for tests that have an "immediate" hold time criteria.
- # Spike was diluted out.
- + Correlation coefficient for MSA is <0.995.
- N Inorganics- Matrix spike recovery was outside laboratory limits.
- N Organics- Presumptive evidence of a compound (reported as a TIC) based on the MS library search.
- S Concentration has been determined using Method of Standard Additions (MSA).
- W Post-Digestion Spike recovery is outside control limits and the sample absorbance is <50% of the spike absorbance.
- P Concentration >40% difference between the two GC columns.
- C Confirmed by GC/MS
- Q DoD reports: indicates a pesticide/Aroclor is not confirmed ($\geq 100\%$ Difference between two GC columns).
- X See Case Narrative for discussion.
- MRL Method Reporting Limit. Also known as:
- LOQ Limit of Quantitation (LOQ)
The lowest concentration at which the method analyte may be reliably quantified under the method conditions.
- MDL Method Detection Limit. A statistical value derived from a study designed to provide the lowest concentration that will be detected 99% of the time. Values between the MDL and MRL are estimated (see J qualifier).
- LOD Limit of Detection. A value at or above the MDL which has been verified to be detectable.
- ND Non-Detect. Analyte was not detected at the concentration listed. Same as U qualifier.

Rochester Lab ID # for State Accreditations¹



NELAP States
Florida ID # E87674
New Hampshire ID # 2941
New York ID # 10145
Pennsylvania ID# 68-786
Texas ID#T104704581
Virginia #460167

Non-NELAP States
Connecticut ID #PH0556
Delaware Approved
Maine ID #NY01587
North Carolina #36701
North Carolina #676
Rhode Island LAO00333

¹ Analyses were performed according to our laboratory's NELAP-approved quality assurance program and any applicable state or agency requirements. The test results meet requirements of the current NELAP/TNI standards or state or agency requirements, where applicable, except as noted in the case narrative. Since not all analyte/method/matrix combinations are offered for state/NELAC accreditation, this report may contain results which are not accredited. For a specific list of accredited analytes, contact the laboratory. To verify NH accredited analytes, go to <https://www4.des.state.nh.us/CertifiedLabs/Certified-Method.aspx>.

ALS Laboratory Group

Acronyms

ASTM	American Society for Testing and Materials
A2LA	American Association for Laboratory Accreditation
CARB	California Air Resources Board
CAS Number	Chemical Abstract Service registry Number
CFC	Chlorofluorocarbon
CFU	Colony-Forming Unit
DEC	Department of Environmental Conservation
DEQ	Department of Environmental Quality
DHS	Department of Health Services
DOE	Department of Ecology
DOH	Department of Health
EPA	U. S. Environmental Protection Agency
ELAP	Environmental Laboratory Accreditation Program
GC	Gas Chromatography
GC/MS	Gas Chromatography/Mass Spectrometry
LUFT	Leaking Underground Fuel Tank
M	Modified
MCL	Maximum Contaminant Level is the highest permissible concentration of a substance allowed in drinking water as established by the USEPA.
MDL	Method Detection Limit
MPN	Most Probable Number
MRL	Method Reporting Limit
NA	Not Applicable
NC	Not Calculated
NCASI	National Council of the Paper Industry for Air and Stream Improvement
ND	Not Detected
NIOSH	National Institute for Occupational Safety and Health
PQL	Practical Quantitation Limit
RCRA	Resource Conservation and Recovery Act
SIM	Selected Ion Monitoring
TPH	Total Petroleum Hydrocarbons
tr	Trace level is the concentration of an analyte that is less than the PQL but greater than or equal to the MDL.

ALS Group USA, Corp.
dba ALS Environmental
Analyst Summary report

Client: Labella Associates, PC
Project: Webster CSD - Thomas/2251107

Service Request: R2515005

Sample Name: TTF-01-OD-IN-FNCE-B2
Lab Code: R2515005-001
Sample Matrix: Drinking Water

Date Collected: 11/7/25
Date Received: 11/7/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: TTF-01-OD-IN-FNCE-B1
Lab Code: R2515005-002
Sample Matrix: Drinking Water

Date Collected: 11/7/25
Date Received: 11/7/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: TTF-01-RM-IN-CONC-T
Lab Code: R2515005-003
Sample Matrix: Drinking Water

Date Collected: 11/7/25
Date Received: 11/7/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: TTF-01-RM-IN-CONC-CT
Lab Code: R2515005-004
Sample Matrix: Drinking Water

Date Collected: 11/7/25
Date Received: 11/7/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: TTF-01-OD-BY-TURF-T1
Lab Code: R2515005-005
Sample Matrix: Drinking Water

Date Collected: 11/7/25
Date Received: 11/7/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

ALS Group USA, Corp.
dba ALS Environmental
Analyst Summary report

Client: Labella Associates, PC
Project: Webster CSD - Thomas/2251107

Service Request: R2515005

Sample Name: TTF-01-OD-BY -TURF-T2
Lab Code: R2515005-006
Sample Matrix: Drinking Water

Date Collected: 11/7/25
Date Received: 11/7/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: TTF-01-OD-BY -TURF-T3
Lab Code: R2515005-007
Sample Matrix: Drinking Water

Date Collected: 11/7/25
Date Received: 11/7/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: TTF-01-OD-BY -TURF-T4
Lab Code: R2515005-008
Sample Matrix: Drinking Water

Date Collected: 11/7/25
Date Received: 11/7/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN



PREPARATION METHODS

The preparation methods associated with this report are found in these tables unless discussed in the case narrative.

INORGANIC

Water/Liquid Matrix

Analytical Method	Preparation Method
200.7 / 200.8	200.2
6010D	3005A/3010A
6020B	ILM05.3
9034 Sulfide Acid Soluble	9030B
SM 4500-CN-N-2016 Amenable and Residual Cyanide	SM 4500-CN-G and SM 4500-CN-B,C-2016
SM 4500-CN-E WAD Cyanide	SM 4500-CN-I

Solid/Soil/Non-Aqueous Matrix

Analytical Method	Preparation Method
6010D	3050B
6010D TCLP (1311) extract	3005A/3010A
6010D SPLP (1312) extract	3005A/3010A
7199	3060A
300.0 Anions/ 350.1/ 353.2/ SM 2320B/ SM 5210B/ 9056A Anions	DI extraction
For analytical methods not listed, the preparation method is the same as the analytical method reference.	

ORGANIC

Preparation Methods for Organic methods are listed in the header of the Results pages.

Regarding "Bulk/5035A":

For soil/solid samples submitted in soil jars for Volatiles analysis, the prep method is listed as "Bulk/5035A". The lab follows the closed-system EPA 5035A protocols once the sample is transferred to a sealed vial, but collection in bulk in soil jars does not follow the collection protocols listed in EPA 5035A. In accordance with the NYSDOH technical notice of October 2012, all results or reporting limits <200 ug/kg are to be considered estimated due to potential low bias.



Sample Results

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



Metals

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Thomas/2251107
Sample Matrix: Drinking Water
Sample Name: TTF-01-OD-IN-FNCE-B2
Lab Code: R2515005-001

Service Request: R2515005
Date Collected: 11/07/25 07:13
Date Received: 11/07/25 15:30
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	12/03/25 14:59	

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Thomas/2251107
Sample Matrix: Drinking Water
Sample Name: TTF-01-OD-IN-FNCE-B1
Lab Code: R2515005-002

Service Request: R2515005
Date Collected: 11/07/25 07:14
Date Received: 11/07/25 15:30
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	12/03/25 15:03	

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Thomas/2251107
Sample Matrix: Drinking Water
Sample Name: TTF-01-RM-IN-CONC-T
Lab Code: R2515005-003

Service Request: R2515005
Date Collected: 11/07/25 07:15
Date Received: 11/07/25 15:30
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	3.1	ug/L	1.0	1	12/03/25 15:05	

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Thomas/2251107
Sample Matrix: Drinking Water
Sample Name: TTF-01-RM-IN-CONC-CT
Lab Code: R2515005-004

Service Request: R2515005
Date Collected: 11/07/25 07:16
Date Received: 11/07/25 15:30
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	12/03/25 15:06	

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Thomas/2251107
Sample Matrix: Drinking Water
Sample Name: TTF-01-OD-BY -TURF-T1
Lab Code: R2515005-005

Service Request: R2515005
Date Collected: 11/07/25 07:18
Date Received: 11/07/25 15:30

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.1	ug/L	1.0	1	12/03/25 15:07	

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Thomas/2251107
Sample Matrix: Drinking Water
Sample Name: TTF-01-OD-BY -TURF-T2
Lab Code: R2515005-006

Service Request: R2515005
Date Collected: 11/07/25 07:19
Date Received: 11/07/25 15:30
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.3	ug/L	1.0	1	12/03/25 15:16	

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Thomas/2251107
Sample Matrix: Drinking Water
Sample Name: TTF-01-OD-BY -TURF-T3
Lab Code: R2515005-007

Service Request: R2515005
Date Collected: 11/07/25 07:20
Date Received: 11/07/25 15:30
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.3	ug/L	1.0	1	12/03/25 15:20	

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Thomas/2251107
Sample Matrix: Drinking Water
Sample Name: TTF-01-OD-BY -TURF-T4
Lab Code: R2515005-008

Service Request: R2515005
Date Collected: 11/07/25 07:21
Date Received: 11/07/25 15:30
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	2.7	ug/L	1.0	1	12/03/25 15:21	



QC Summary Forms

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



Metals

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Thomas/2251107
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2515005-MB1

Service Request: R2515005
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	12/03/25 15:14	

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Thomas/2251107
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2515005-MB2

Service Request: R2515005
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	12/03/25 14:32	

QA/QC Report

Client: Labella Associates, PC
Project: Webster CSD - Thomas/2251107
Sample Matrix: Drinking Water

Service Request: R2515005
Date Collected: 11/07/25
Date Received: 11/07/25
Date Analyzed: 12/3/25

Duplicate Matrix Spike Summary
Inorganic Parameters

Sample Name: TTF-01-OD-BY -TURF-T1
Lab Code: R2515005-005
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike R2515005-005MS		Result	Duplicate Matrix Spike R2515005-005DMS		% Rec Limits	RPD	RPD Limit
			Spike Amount	% Rec		Spike Amount	% Rec			
Lead, Total	1.1	21.9	20.0	104	20.8	20.0	99	70-130	5	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

QA/QC Report

Client: Labella Associates, PC
Project: Webster CSD - Thomas/2251107
Sample Matrix: Drinking Water

Service Request: R2515005
Date Collected: 11/07/25
Date Received: 11/07/25
Date Analyzed: 12/3/25

Duplicate Matrix Spike Summary
Inorganic Parameters

Sample Name: TTF-01-OD-BY -TURF-T2
Lab Code: R2515005-006
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike R2515005-006MS		Result	Duplicate Matrix Spike R2515005-006DMS		% Rec Limits	RPD	RPD Limit
			Spike Amount	% Rec		Spike Amount	% Rec			
Lead, Total	1.3	22.0	20.0	104	21.6	20.0	102	70-130	2	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

Client: Labella Associates, PC
Project: Webster CSD - Thomas/2251107
Sample Matrix: Drinking Water

Service Request: R2515005
Date Analyzed: 12/03/25

Lab Control Sample Summary
Inorganic Parameters

Units: ug/L
Basis: NA

Lab Control Sample
R2515005-LCS1

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	20.7	20.0	104	85-115

Client: Labella Associates, PC
Project: Webster CSD - Thomas/2251107
Sample Matrix: Drinking Water

Service Request: R2515005

Date Analyzed: 12/03/25

Lab Control Sample Summary
Inorganic Parameters

Units: ug/L

Basis: NA

Lab Control Sample
R2515005-LCS2

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	20.8	20.0	104	85-115



January 12, 2026

Service Request No:R2516953

Cory Stamp
Labella Associates, PC
300 State Street, 2nd Floor
Suite 201
Rochester, NY 14614

Laboratory Results for: Webster CSD - Thomas High

Dear Cory,

Enclosed are the results of the sample(s) submitted to our laboratory December 17, 2025
For your reference, these analyses have been assigned our service request number **R2516953**.

All testing was performed according to our laboratory's quality assurance program and met the requirements of the TNI standards except as noted in the case narrative report. Any testing not included in the lab's accreditation is identified on a Non-Certified Analytes report. All results are intended to be considered in their entirety. ALS Environmental is not responsible for use of less than the complete report. Results apply only to the individual samples submitted to the lab for analysis, as listed in the report. The measurement uncertainty of the results included in this report is within that expected when using the prescribed method(s), and represented by Laboratory Control Sample control limits. Any events, such as QC failures or Holding Time exceedances, which may add to the uncertainty are explained in the report narrative or are flagged with qualifiers. The flags are explained in the Report Qualifiers and Definitions page of this report.

Please contact me if you have any questions. My extension is 7475. You may also contact me via email at Meghan.Pedro@alsglobal.com.

Respectfully submitted,

ALS Group USA, Corp. dba ALS Environmental

Meghan Pedro
Project Manager

ADDRESS 1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
PHONE +1 585 288 5380 | **FAX** +1 585 288 8475
ALS Group USA, Corp.
dba ALS Environmental



Narrative Documents

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



Client: Labella Associates, PC
Project: Webster CSD - Thomas High
Sample Matrix: Drinking Water

Service Request: R2516953
Date Received: 12/17/2025

CASE NARRATIVE

All analyses were performed consistent with the quality assurance program of ALS Environmental. This report contains analytical results for samples for the Tier II level requested by the client.

Sample Receipt:

Forty nine drinking water samples were received for analysis at ALS Environmental on 12/17/2025. Any discrepancies upon initial sample inspection are annotated on the sample receipt and preservation form included within this report. The samples were stored at minimum in accordance with the analytical method requirements.

Metals:

No significant anomalies were noted with this analysis.

A handwritten signature in black ink that reads "Meghan Pedro".

Approved by _____

Date 01/12/2026



SAMPLE DETECTION SUMMARY

This form includes only detections above the reporting levels. For a full listing of sample results, continue to the Sample Results section of this Report.

CLIENT ID: THS-01-RM-IN-240-T	Lab ID: R2516953-001
--------------------------------------	-----------------------------

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.1			1.0	ug/L	200.8

CLIENT ID: THS-01-RM-IN-422-T1	Lab ID: R2516953-007
---------------------------------------	-----------------------------

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.5			1.0	ug/L	200.8

CLIENT ID: THS-01-FR-IN-A134-T	Lab ID: R2516953-025
---------------------------------------	-----------------------------

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	3.3			1.0	ug/L	200.8

CLIENT ID: THS-01-HA-BY-216-DFR	Lab ID: R2516953-028
--	-----------------------------

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.2			1.0	ug/L	200.8

CLIENT ID: THS-01-KIT-IN-445-CTR	Lab ID: R2516953-045
---	-----------------------------

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	2.8			1.0	ug/L	200.8



Sample Receipt Information

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

Client: Labella Associates, PC
Project: Webster CSD - Thomas High

Service Request:R2516953

SAMPLE CROSS-REFERENCE

<u>SAMPLE #</u>	<u>CLIENT SAMPLE ID</u>	<u>DATE</u>	<u>TIME</u>
R2516953-001	THS-01-RM-IN-240-T	12/17/2025	
R2516953-002	THS-01-RM-IN-251-T	12/17/2025	
R2516953-004	THS-01-RM-IN-332-T	12/17/2025	
R2516953-005	THS-01-TM-IN-TR-T	12/17/2025	
R2516953-006	THS-01-RM-IN-TR-IM	12/17/2025	
R2516953-007	THS-01-RM-IN-422-T1	12/17/2025	
R2516953-009	THS-01-RM-IN-422-IM	12/17/2025	
R2516953-010	THS-01-KIT-IN-445-CTL	12/17/2025	
R2516953-011	THS-01-KIT-IN-445-T1	12/17/2025	
R2516953-012	THS-01-KIT-IN-445-T2	12/17/2025	
R2516953-013	THS-01-KIT-IN-445-T3	12/17/2025	
R2516953-014	THS-01-KIT-IN-445-T5	12/17/2025	
R2516953-015	THS-01-KIT-IN-445-PFL	12/17/2025	
R2516953-016	THS-01-KIT-IN-445-PFR	12/17/2025	
R2516953-017	THS-01-RM-IN-POOL-DF	12/17/2025	
R2516953-018	THS-01-RM-IN-POOL-BF	12/17/2025	
R2516953-019	THS-01-FH-IN-470-DF1	12/17/2025	
R2516953-020	THS-01-FH-IN-470-DF2	12/17/2025	
R2516953-021	THS-01-FH-IN-470-DF3	12/17/2025	
R2516953-022	THS-01-FH-IN-470-DF4	12/17/2025	
R2516953-023	THS-01-FH-IN-470-BF	12/17/2025	
R2516953-024	THS-01-CONC-IN-470B-T	12/17/2025	
R2516953-025	THS-01-FR-IN-A134-T	12/17/2025	
R2516953-026	THS-01-RM-IN-C243-T	12/17/2025	
R2516953-027	THS-01-HA-BY-216-DFL	12/17/2025	
R2516953-028	THS-01-HA-BY-216-DFR	12/17/2025	
R2516953-029	THS-01-HA-BY-402-DFL	12/17/2025	
R2516953-030	THS-01-HA-BY-402-BFL	12/17/2025	
R2516953-031	THS-01-HA-BY-402-DFR	12/17/2025	
R2516953-032	THS-01-HA-BY-402-BFR	12/17/2025	
R2516953-033	THS-01-HA-BY-CAFE-DFL	12/17/2025	
R2516953-034	THS-01-HA-BY-CAFE-BFL	12/17/2025	
R2516953-035	THS-01-HA-BY-CAFE-DFR	12/17/2025	
R2516953-036	THS-01-HA-BY-CAFE-BFR	12/17/2025	
R2516953-037	THS-01-HA-GYM-DFL	12/17/2025	
R2516953-038	THS-01-HA-GYM-BFL	12/17/2025	
R2516953-039	THS-01-HA-GYM-DFR	12/17/2025	
R2516953-040	THS-01-HA-GYM-BFR	12/17/2025	
R2516953-041	THS-01-HA-BY-GCONC-DF	12/17/2025	
R2516953-042	THS-01-HA-BY-GCONC-BF	12/17/2025	
R2516953-043	THS-01-328-T	12/17/2025	
R2516953-044	THS-01-CR-IN-145-T	12/17/2025	

Client: Labella Associates, PC
Project: Webster CSD - Thomas High

Service Request:R2516953

SAMPLE CROSS-REFERENCE

<u>SAMPLE #</u>	<u>CLIENT SAMPLE ID</u>	<u>DATE</u>	<u>TIME</u>
R2516953-045	THS-01-KIT-IN-445-CTR	12/17/2025	
R2516953-046	THS-01-HA-BY-236DF	12/17/2025	
R2516953-047	THS-01-HA-BY-236BF	12/17/2025	
R2516953-048	THS-01-HA-BY-212-BF	12/17/2025	
R2516953-049	THS-01-HA-BY-212-DF	12/17/2025	



ALS Environmental

Laboratory location:
Rochester NY

Chain of Custody Form

Page 1 of

Customer Information		Project Information					Parameter/Method Request for Analysis										
Purchase Order		Project Name	Webster CSD - Thomas High			A	EPA 200.8 Lead in Drinking Water										
Work Order		Project Number	2251107			B											
Company Name	LaBella Associates	Bill To Company	LaBella Associates			C											
Send Report To	Cory Stamp	Invoice Attn	Cory Stamp			D											
Address	300 State Street, Suite 200	Address	300 State Street, Suite 200			E											
City/State/Zip	Rochester, NY 14614	City/State/Zip	Rochester, NY 14614			F											
Phone	(607) 591-7516	Phone	(607) 591-7516			G											
Fax		Fax				H											
e-Mail Address	cstamp@labellapc.com	e-Mail Address	cstamp@labellapc.com			I											
J																	
No.	Sample Description	Date	Time	Matrix	Pres	# Bottles	A	B	C	D	E	F	G	H	I	J	Hold
1	See attached spreadsheets for sample				N/A		X										
2	descriptions. All samples are 250 mL																
3	plastic bottles, drinking water, with																
4	no preservative																
5																	
6																	
7																	
8																	
9																	
10																	
Sampler(s): Please Print & Sign		Shipment Method:		Required Turnaround Time:				Results Due Date:									
		Delivered		<input checked="" type="checkbox"/> STD 10 Wk Days <input type="checkbox"/> 5 Wk Days <input type="checkbox"/> 2 Wk Days <input type="checkbox"/> 24 Hour <input type="checkbox"/> Other _____													
Relinquished by:	Date:	Time:	Received by:		Notes:												
			12/17/25 9:52														
Relinquished by:	Date:	Time:	Received by (Laboratory):		Cooler Temp.		QC Package: (Check Box Below)										
	12/17/25	9:52					<input type="checkbox"/> Level II: Standard QC TRRP-Checklist <input type="checkbox"/> Level III: Std QC + Raw Data TRRP Level IV <input type="checkbox"/> Level IV: SW846 CLP-Like Other: _____										
Logged by (Laboratory):	Date:	Time:	Checked by (Laboratory):														
Preservative Key: 1-HCL 2-HNO3 3-H2SO4 4-NaOH 5-Na2S2O3 6-NaHSO4 7-Other 8-4 degrees C 9-5035																	

Note: Any changes must be made in writing once samples and COC Form have been submitted to ALS Laboratory Group.
Signature denotes acceptance of ALS Group USA, Corp. Terms and Conditions - Please click the link below for detailed Terms & Conditions:

<https://www.alsglobal.com/ALSGroupUSACorpTC>

ALS copyright © 2024. All rights reserved.


R2516953

Labella Associates, PC
 Webster CSD - Thomas High


5

Thomas High School			
Identification Code	Description	Date Sampled	Time Sampled
THS-01-CR-IN-145-T	Tap In Classroom 145		
THS-01-RM-IN-240-T	Tap In Room 240	12/17/25	6:55
THS-01-RM-IN-251-T	Tap In Room 251	12/17/25	6:48
THS-01-CR-IN-303-IM	Classroom 303 Ice Machine	12/17/25	
THS-01-RM-IN-332-T	Tap In Room 332	12/17/25	7:29
THS-01-RM-IN-TR-T	Training Room Tap	12/17/25	6:50
THS-01-RM-IN-TR-IM	Training Room Ice Machine	12/17/25	7:34
THS-01-RM-IN-422-T1	Tap In Room 422 Closest to Hallway (Left Tap)	12/17/25	6:24
THS-01-RM-IN-422-T2	Tap In Room 422 Furthest From Hallway (Right Tap)	12/17/25	6:24
THS-01-RM-IN-422-IM	Ice Machine In Room 422	12/17/25	6:25
THS-01-KIT-IN-445-CTR	Kitchen 445 Right Coffee Tap		
THS-01-KIT-IN-445-CTL	Kitchen 445 Left Coffee Tap	12/17/25	5:58
THS-01-KIT-IN-445-T1	Kitchen Prep Area Right Tap	12/17/25	5:59
THS-01-KIT-IN-445-T2	Tap Near Northern Serving Area in Kitchen 445	12/17/25	5:59
THS-01-KIT-IN-445-T3	Kitchen 445 Southeast Corner Left Sink	12/17/25	6:00
THS-01-KIT-IN-445-T4	Kitchen Prep Area Left Tap		
THS-01-KIT-IN-445-T5	Kitchen 445 East Standalone Tap	12/17/25	5:55
THS-01-KIT-IN-445-PFL	Kitchen 445 Left Hand Pot Filler	12/17/25	5:56
THS-01-KIT-IN-445-PFR	Kitchen 445 Right Hand Pot Filler	12/17/25	5:58
THS-01-RM-IN-POOL-DF	Pool Drinking Fountain	12/17/25	7:10
THS-01-RM-IN-POOL-BF	Pool Bottle Filler	12/17/25	7:11
THS-01-FH-IN-470-DF1	Field House 470 - Northwest Left Drinking Fountain	12/17/25	7:28
THS-01-FH-IN-470-DF2	Field House 470 - Northwest Right Drinking Fountain	12/17/25	7:29
THS-01-FH-IN-470-DF3	Field House 470 - Northeast Left Drinking Fountain	12/17/25	7:30
THS-01-FH-IN-470-DF4	Field House 470 - Northeast Right Drinking Fountain	12/17/25	7:31
THS-01-FH-IN-470-BF	Field House 470 - Northeast Bottle Filler	12/17/25	7:32
THS-01-CONC-IN-470B-T	Tap In Concessions Stand	12/17/25	7:41
THS-01-FR-IN-A134-T	Tap in Faculty Break Room A134	12/17/25	7:25
THS-01-RM-IN-C243-T	Tap in Receiving Room C243	12/17/25	7:24
THS-01-HA-BY-212-DF	Hallway by Room 212 Drinking Fountain		
THS-01-HA-BY-212-BF	Hallway by Room 212 Bottle Filler		
THS-01-HA-BY-236-DF	Hallway by Room 236 Drinking Fountain		

(Water Dripping)

 = NO SAMPLE

THS-01-HA-BY-236-BF	Hallway by Room 236 Bottle Filler		
THS-01-HA-BY-216-DFL	Hallway by West Library Left Drinking Fountain	12/17/25	721
THS-01-HA-BY-216-DFR	Hallway by West Library Right Drinking Fountain	12/17/25	722
THS-01-HA-BY-328-DF	Hallway by Room 328 Drinking Fountain		
THS-01-HA-BY-328-BF	Hallway by Room 328 Bottle Filler		
THS-01-HA-BY-402-DFL	Hallway by Room 402 Left Drinking Fountain	12/17/25	635
THS-01-HA-BY-402-BFL	Hallway by Room 402 Left Bottle Filler	12/17/25	636
THS-01-HA-BY-402-DFR	Hallway by Room 402 Right Drinking Fountain	12/17/25	637
THS-01-HA-BY-402-BFR	Hallway by Room 402 Bottle Filler	12/17/25	638
THS-01-HA-BY-CAFE-DFL	Hallway by South Cafeteria Left Drinking Fountain	12/17/25	705
THS-01-HA-BY-CAFE-BFL	Hallway by South Cafeteria Left Bottle Filler	12/17/25	706
THS-01-HA-BY-CAFE-DFR	Hallway by South Cafeteria Right Drinking Fountain	12/17/25	707
THS-01-HA-BY-CAFE-BFR	Hallway by South Cafeteria Bottle Filler	12/17/25	708
THS-01-HA-BY-GYM-DFL	Hallway by Gym Left Drinking Fountain	12/17/25	715
THS-01-HA-BY-GYM-BFL	Hallway by Gym Left Bottle Filler	12/17/25	716
THS-01-HA-BY-GYM-DFR	Hallway by Gym Right Drinking Fountain	12/17/25	717
THS-01-HA-BY-GYM-BFR	Hallway by Gym Bottle Filler	12/17/25	718
THS-01-HA-BY-GCONC-DF	Hallway by Gym Concession Stand Drinking Fountain	12/17/25	719
THS-01-HA-BY-GCONC-BF	Hallway by Gym Concession Stand Bottle Filler	12/17/25	720



= NO SAMPLE



R2516953

5

Labels Associates, PC
Webster CSD - Thomas High

Cooler Receipt and Preservation

Project/Client Labelka

Folder Number _____

Cooler received on 12/17/25 by: RM

COURIER: ALS UPS FEDEX VELOCITY CLIENT

1	Were Custody seals on outside of cooler?	Y <u>N</u>	5a	Did VOA vials have sig* bubbles?	Y N <u>NA</u>
2	Custody papers properly completed (ink, signed)?	<u>Y</u> N	5b	Sig* bubbles: Alk? Y N <u>NA</u> Sulfide? Y N <u>NA</u>	
3	Did all bottles arrive in good condition (unbroken)?	<u>Y</u> N	6	Where did the bottles originate?	ALS/ROC <u>CLIENT</u>
4	Circle: Wet Ice Dry Ice Gel packs present?	Y <u>N</u>	7	Soil VOA received as: Bulk Encore 5035set	<u>NA</u>

8. Temperature Readings Date: 12/17/25 Time: 9:55 ID: IR#11 IR#12 IR#13 From: Temp Blank Sample Bottle

Temp (°C)	<u>18.9</u>						
Within 0-6°C?	Y <u>N</u>	Y N	Y N	Y N	Y N	Y N	Y N
If <0°C, were samples frozen?	Y N	Y N	Y N	Y N	Y N	Y N	Y N

If out of Temperature, note packing/ice condition: _____ Ice melted Poorly Packed (described below) Same Day Rule
& Client Approval to Run Samples: _____ Standing Approval Client aware at drop-off Client notified by: _____

All samples held in storage location: 5M0 by RM on 12/17 at 9:56
5035 samples placed in storage location: _____ by _____ on _____ at _____ within 48 hours of sampling? Y N

Cooler Breakdown/Preservation Check**: Date: 12/17/25 Time: 12:0 by: RM

- 9. Were all bottle labels complete (i.e. analysis, preservation, etc.)? YES NO
- 10. Did all bottle labels and tags agree with custody papers? YES NO
- 11. Were correct containers used for the tests indicated? YES NO
- 12. Were 5035 vials acceptable (no extra labels, not leaking)? YES NO N/A
- 13. Were dissolved metals filtered in the field? YES NO N/A

pH	Lot of test paper	Reagent	Preserved?		Lot Received	Exp	Sample ID Adjusted	Vol. Added	Lot Added	Final pH
			Yes	No						
≥12		NaOH								
≤2	<u>202325</u>	HNO ₃		✓			<u>All</u>	<u>4mL</u>	<u>245078</u>	<u>≤2</u>
≤2		H ₂ SO ₄								
<4		NaHSO ₄								
5-9		For 608pest			No=Notify for 3day					
Residual Chlorine (-)		For CN, Phenol, 625, 608pest, 522			If +, contact PM to add Na ₂ S ₂ O ₃ (625, 608, CN), ascorbic (phenol).					
		Na ₂ S ₂ O ₃								
		ZnAcetate	-	-			**VOAs and 1664 Not to be tested before analysis. Otherwise, all bottles of all samples with chemical preservatives are checked (not just representatives).			
		HCl	**	**						

Bottle lot numbers: Client bottles

Explain all Discrepancies/ Other Comments:

10) Only sample ID on

Bottle says ~~CAFEBEF~~ labeled as CAFE-BFE
RM

HPROD	BULK
HTR	FLDT
SUB	HGFB
ALS	LL3541

Labels secondary reviewed by: RM

*significant air bubbles: VOA > 5-6 mm : WC > 1 in. diameter



Miscellaneous Forms

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



REPORT QUALIFIERS AND DEFINITIONS

- U Analyte was analyzed for but not detected. The sample quantitation limit has been corrected for dilution and for percent moisture, unless otherwise noted in the case narrative.
- J Estimated value due to either being a Tentatively Identified Compound (TIC) or that the concentration is between the MRL and the MDL. Concentrations are not verified within the linear range of the calibration. For DoD: concentration >40% difference between two GC columns (pesticides/Aroclors).
- B Analyte was also detected in the associated method blank at a concentration that may have contributed to the sample result.
- E Inorganics- Concentration is estimated due to the serial dilution was outside control limits.
- E Organics- Concentration has exceeded the calibration range for that specific analysis.
- D Concentration is a result of a dilution, typically a secondary analysis of the sample due to exceeding the calibration range or that a surrogate has been diluted out of the sample and cannot be assessed.
- * Indicates that a quality control parameter has exceeded laboratory limits. Under the “Notes” column of the Form I, this qualifier denotes analysis was performed out of Holding Time.
- H Analysis was performed out of hold time for tests that have an “immediate” hold time criteria.
- # Spike was diluted out.
- + Correlation coefficient for MSA is <0.995.
- N Inorganics- Matrix spike recovery was outside laboratory limits.
- N Organics- Presumptive evidence of a compound (reported as a TIC) based on the MS library search.
- S Concentration has been determined using Method of Standard Additions (MSA).
- W Post-Digestion Spike recovery is outside control limits and the sample absorbance is <50% of the spike absorbance.
- P Concentration >40% difference between the two GC columns.
- C Confirmed by GC/MS
- Q DoD reports: indicates a pesticide/Aroclor is not confirmed ($\geq 100\%$ Difference between two GC columns).
- X See Case Narrative for discussion.
- MRL Method Reporting Limit. Also known as:
- LOQ Limit of Quantitation (LOQ)
The lowest concentration at which the method analyte may be reliably quantified under the method conditions.
- MDL Method Detection Limit. A statistical value derived from a study designed to provide the lowest concentration that will be detected 99% of the time. Values between the MDL and MRL are estimated (see J qualifier).
- LOD Limit of Detection. A value at or above the MDL which has been verified to be detectable.
- ND Non-Detect. Analyte was not detected at the concentration listed. Same as U qualifier.

Rochester Lab ID # for State Accreditations¹



NELAP States
Florida ID # E87674
New Hampshire ID # 2941
New York ID # 10145
Pennsylvania ID# 68-786
Texas ID#T104704581
Virginia #460167

Non-NELAP States
Connecticut ID #PH0556
Delaware Approved
Maine ID #NY01587
North Carolina #36701
North Carolina #676
Rhode Island LAO00333

¹ Analyses were performed according to our laboratory’s NELAP-approved quality assurance program and any applicable state or agency requirements. The test results meet requirements of the current NELAP/TNI standards or state or agency requirements, where applicable, except as noted in the case narrative. Since not all analyte/method/matrix combinations are offered for state/NELAC accreditation, this report may contain results which are not accredited. For a specific list of accredited analytes, contact the laboratory. To verify NH accredited analytes, go to <https://www4.des.state.nh.us/CertifiedLabs/Certified-Method.aspx>.

ALS Laboratory Group

Acronyms

ASTM	American Society for Testing and Materials
A2LA	American Association for Laboratory Accreditation
CARB	California Air Resources Board
CAS Number	Chemical Abstract Service registry Number
CFC	Chlorofluorocarbon
CFU	Colony-Forming Unit
DEC	Department of Environmental Conservation
DEQ	Department of Environmental Quality
DHS	Department of Health Services
DOE	Department of Ecology
DOH	Department of Health
EPA	U. S. Environmental Protection Agency
ELAP	Environmental Laboratory Accreditation Program
GC	Gas Chromatography
GC/MS	Gas Chromatography/Mass Spectrometry
LUFT	Leaking Underground Fuel Tank
M	Modified
MCL	Maximum Contaminant Level is the highest permissible concentration of a substance allowed in drinking water as established by the USEPA.
MDL	Method Detection Limit
MPN	Most Probable Number
MRL	Method Reporting Limit
NA	Not Applicable
NC	Not Calculated
NCASI	National Council of the Paper Industry for Air and Stream Improvement
ND	Not Detected
NIOSH	National Institute for Occupational Safety and Health
PQL	Practical Quantitation Limit
RCRA	Resource Conservation and Recovery Act
SIM	Selected Ion Monitoring
TPH	Total Petroleum Hydrocarbons
tr	Trace level is the concentration of an analyte that is less than the PQL but greater than or equal to the MDL.

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Labella Associates, PC
Project: Webster CSD - Thomas High/

Service Request: R2516953

Sample Name: THS-01-RM-IN-240-T
Lab Code: R2516953-001
Sample Matrix: Drinking Water

Date Collected: 12/17/25
Date Received: 12/17/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: THS-01-RM-IN-251-T
Lab Code: R2516953-002
Sample Matrix: Drinking Water

Date Collected: 12/17/25
Date Received: 12/17/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: THS-01-RM-IN-332-T
Lab Code: R2516953-004
Sample Matrix: Drinking Water

Date Collected: 12/17/25
Date Received: 12/17/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: THS-01-TM-IN-TR-T
Lab Code: R2516953-005
Sample Matrix: Drinking Water

Date Collected: 12/17/25
Date Received: 12/17/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: THS-01-RM-IN-TR-IM
Lab Code: R2516953-006
Sample Matrix: Drinking Water

Date Collected: 12/17/25
Date Received: 12/17/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Labella Associates, PC
Project: Webster CSD - Thomas High/

Service Request: R2516953

Sample Name: THS-01-RM-IN-422-T1
Lab Code: R2516953-007
Sample Matrix: Drinking Water

Date Collected: 12/17/25
Date Received: 12/17/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: THS-01-RM-IN-422-IM
Lab Code: R2516953-009
Sample Matrix: Drinking Water

Date Collected: 12/17/25
Date Received: 12/17/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: THS-01-KIT-IN-445-CTL
Lab Code: R2516953-010
Sample Matrix: Drinking Water

Date Collected: 12/17/25
Date Received: 12/17/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: THS-01-KIT-IN-445-T1
Lab Code: R2516953-011
Sample Matrix: Drinking Water

Date Collected: 12/17/25
Date Received: 12/17/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: THS-01-KIT-IN-445-T2
Lab Code: R2516953-012
Sample Matrix: Drinking Water

Date Collected: 12/17/25
Date Received: 12/17/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Labella Associates, PC
Project: Webster CSD - Thomas High/

Service Request: R2516953

Sample Name: THS-01-KIT-IN-445-T3
Lab Code: R2516953-013
Sample Matrix: Drinking Water

Date Collected: 12/17/25
Date Received: 12/17/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: THS-01-KIT-IN-445-T5
Lab Code: R2516953-014
Sample Matrix: Drinking Water

Date Collected: 12/17/25
Date Received: 12/17/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: THS-01-KIT-IN-445-PFL
Lab Code: R2516953-015
Sample Matrix: Drinking Water

Date Collected: 12/17/25
Date Received: 12/17/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: THS-01-KIT-IN-445-PFR
Lab Code: R2516953-016
Sample Matrix: Drinking Water

Date Collected: 12/17/25
Date Received: 12/17/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: THS-01-RM-IN-POOL-DF
Lab Code: R2516953-017
Sample Matrix: Drinking Water

Date Collected: 12/17/25
Date Received: 12/17/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Labella Associates, PC
Project: Webster CSD - Thomas High/

Service Request: R2516953

Sample Name: THS-01-RM-IN-POOL-BF
Lab Code: R2516953-018
Sample Matrix: Drinking Water

Date Collected: 12/17/25
Date Received: 12/17/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: THS-01-FH-IN-470-DF1
Lab Code: R2516953-019
Sample Matrix: Drinking Water

Date Collected: 12/17/25
Date Received: 12/17/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: THS-01-FH-IN-470-DF2
Lab Code: R2516953-020
Sample Matrix: Drinking Water

Date Collected: 12/17/25
Date Received: 12/17/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: THS-01-FH-IN-470-DF3
Lab Code: R2516953-021
Sample Matrix: Drinking Water

Date Collected: 12/17/25
Date Received: 12/17/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: THS-01-FH-IN-470-DF4
Lab Code: R2516953-022
Sample Matrix: Drinking Water

Date Collected: 12/17/25
Date Received: 12/17/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Labella Associates, PC
Project: Webster CSD - Thomas High/

Service Request: R2516953

Sample Name: THS-01-FH-IN-470-BF
Lab Code: R2516953-023
Sample Matrix: Drinking Water

Date Collected: 12/17/25
Date Received: 12/17/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: THS-01-CONC-IN-470B-T
Lab Code: R2516953-024
Sample Matrix: Drinking Water

Date Collected: 12/17/25
Date Received: 12/17/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: THS-01-FR-IN-A134-T
Lab Code: R2516953-025
Sample Matrix: Drinking Water

Date Collected: 12/17/25
Date Received: 12/17/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: THS-01-RM-IN-C243-T
Lab Code: R2516953-026
Sample Matrix: Drinking Water

Date Collected: 12/17/25
Date Received: 12/17/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: THS-01-HA-BY-216-DFL
Lab Code: R2516953-027
Sample Matrix: Drinking Water

Date Collected: 12/17/25
Date Received: 12/17/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Labella Associates, PC
Project: Webster CSD - Thomas High/

Service Request: R2516953

Sample Name: THS-01-HA-BY-216-DFR
Lab Code: R2516953-028
Sample Matrix: Drinking Water

Date Collected: 12/17/25
Date Received: 12/17/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: THS-01-HA-BY-402-DFL
Lab Code: R2516953-029
Sample Matrix: Drinking Water

Date Collected: 12/17/25
Date Received: 12/17/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: THS-01-HA-BY-402-BFL
Lab Code: R2516953-030
Sample Matrix: Drinking Water

Date Collected: 12/17/25
Date Received: 12/17/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: THS-01-HA-BY-402-DFR
Lab Code: R2516953-031
Sample Matrix: Drinking Water

Date Collected: 12/17/25
Date Received: 12/17/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: THS-01-HA-BY-402-BFR
Lab Code: R2516953-032
Sample Matrix: Drinking Water

Date Collected: 12/17/25
Date Received: 12/17/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Labella Associates, PC
Project: Webster CSD - Thomas High/

Service Request: R2516953

Sample Name: THS-01-HA-BY-CAFE-DFL
Lab Code: R2516953-033
Sample Matrix: Drinking Water

Date Collected: 12/17/25
Date Received: 12/17/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: THS-01-HA-BY-CAFE-BFL
Lab Code: R2516953-034
Sample Matrix: Drinking Water

Date Collected: 12/17/25
Date Received: 12/17/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: THS-01-HA-BY-CAFE-DFR
Lab Code: R2516953-035
Sample Matrix: Drinking Water

Date Collected: 12/17/25
Date Received: 12/17/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: THS-01-HA-BY-CAFE-BFR
Lab Code: R2516953-036
Sample Matrix: Drinking Water

Date Collected: 12/17/25
Date Received: 12/17/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: THS-01-HA-GYM-DFL
Lab Code: R2516953-037
Sample Matrix: Drinking Water

Date Collected: 12/17/25
Date Received: 12/17/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Labella Associates, PC
Project: Webster CSD - Thomas High/

Service Request: R2516953

Sample Name: THS-01-HA-GYM-BFL
Lab Code: R2516953-038
Sample Matrix: Drinking Water

Date Collected: 12/17/25
Date Received: 12/17/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: THS-01-HA-GYM-DFR
Lab Code: R2516953-039
Sample Matrix: Drinking Water

Date Collected: 12/17/25
Date Received: 12/17/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: THS-01-HA-GYM-BFR
Lab Code: R2516953-040
Sample Matrix: Drinking Water

Date Collected: 12/17/25
Date Received: 12/17/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: THS-01-HA-BY-GCONC-DF
Lab Code: R2516953-041
Sample Matrix: Drinking Water

Date Collected: 12/17/25
Date Received: 12/17/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: THS-01-HA-BY-GCONC-BF
Lab Code: R2516953-042
Sample Matrix: Drinking Water

Date Collected: 12/17/25
Date Received: 12/17/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Labella Associates, PC
Project: Webster CSD - Thomas High/

Service Request: R2516953

Sample Name: THS-01-328-T
Lab Code: R2516953-043
Sample Matrix: Drinking Water

Date Collected: 12/17/25
Date Received: 12/17/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: THS-01-CR-IN-145-T
Lab Code: R2516953-044
Sample Matrix: Drinking Water

Date Collected: 12/17/25
Date Received: 12/17/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: THS-01-KIT-IN-445-CTR
Lab Code: R2516953-045
Sample Matrix: Drinking Water

Date Collected: 12/17/25
Date Received: 12/17/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: THS-01-HA-BY-236DF
Lab Code: R2516953-046
Sample Matrix: Drinking Water

Date Collected: 12/17/25
Date Received: 12/17/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: THS-01-HA-BY-236BF
Lab Code: R2516953-047
Sample Matrix: Drinking Water

Date Collected: 12/17/25
Date Received: 12/17/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Labella Associates, PC
Project: Webster CSD - Thomas High/

Service Request: R2516953

Sample Name: THS-01-HA-BY-212-BF
Lab Code: R2516953-048
Sample Matrix: Drinking Water

Date Collected: 12/17/25
Date Received: 12/17/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: THS-01-HA-BY-212-DF
Lab Code: R2516953-049
Sample Matrix: Drinking Water

Date Collected: 12/17/25
Date Received: 12/17/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER



PREPARATION METHODS

The preparation methods associated with this report are found in these tables unless discussed in the case narrative.

INORGANIC

Water/Liquid Matrix

Analytical Method	Preparation Method
200.7 / 200.8	200.2
6010D	3005A/3010A
6020B	ILM05.3
9034 Sulfide Acid Soluble	9030B
SM 4500-CN-N-2016 Amenable and Residual Cyanide	SM 4500-CN-G and SM 4500-CN-B,C-2016
SM 4500-CN-E WAD Cyanide	SM 4500-CN-I

Solid/Soil/Non-Aqueous Matrix

Analytical Method	Preparation Method
6010D	3050B
6010D TCLP (1311) extract	3005A/3010A
6010D SPLP (1312) extract	3005A/3010A
7199	3060A
300.0 Anions/ 350.1/ 353.2/ SM 2320B/ SM 5210B/ 9056A Anions	DI extraction
For analytical methods not listed, the preparation method is the same as the analytical method reference.	

ORGANIC

Preparation Methods for Organic methods are listed in the header of the Results pages.

Regarding "Bulk/5035A":

For soil/solid samples submitted in soil jars for Volatiles analysis, the prep method is listed as "Bulk/5035A". The lab follows the closed-system EPA 5035A protocols once the sample is transferred to a sealed vial, but collection in bulk in soil jars does not follow the collection protocols listed in EPA 5035A. In accordance with the NYSDOH technical notice of October 2012, all results or reporting limits <200 ug/kg are to be considered estimated due to potential low bias.



Sample Results

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



Metals

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Thomas High
Sample Matrix: Drinking Water
Sample Name: THS-01-RM-IN-240-T
Lab Code: R2516953-001

Service Request: R2516953
Date Collected: 12/17/25
Date Received: 12/17/25 09:52
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.1	ug/L	1.0	1	01/07/26 21:38	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Thomas High
Sample Matrix: Drinking Water
Sample Name: THS-01-RM-IN-251-T
Lab Code: R2516953-002

Service Request: R2516953
Date Collected: 12/17/25
Date Received: 12/17/25 09:52
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	01/07/26 21:51	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Thomas High
Sample Matrix: Drinking Water
Sample Name: THS-01-RM-IN-332-T
Lab Code: R2516953-004

Service Request: R2516953
Date Collected: 12/17/25
Date Received: 12/17/25 09:52
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	01/07/26 21:55	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Thomas High
Sample Matrix: Drinking Water
Sample Name: THS-01-TM-IN-TR-T
Lab Code: R2516953-005

Service Request: R2516953
Date Collected: 12/17/25
Date Received: 12/17/25 09:52
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	01/07/26 21:56	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Thomas High
Sample Matrix: Drinking Water
Sample Name: THS-01-RM-IN-TR-IM
Lab Code: R2516953-006

Service Request: R2516953
Date Collected: 12/17/25
Date Received: 12/17/25 09:52
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	01/07/26 21:58	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Thomas High
Sample Matrix: Drinking Water
Sample Name: THS-01-RM-IN-422-T1
Lab Code: R2516953-007

Service Request: R2516953
Date Collected: 12/17/25
Date Received: 12/17/25 09:52
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.5	ug/L	1.0	1	01/07/26 21:59	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Thomas High
Sample Matrix: Drinking Water
Sample Name: THS-01-RM-IN-422-IM
Lab Code: R2516953-009

Service Request: R2516953
Date Collected: 12/17/25
Date Received: 12/17/25 09:52
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	01/07/26 22:01	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Thomas High
Sample Matrix: Drinking Water
Sample Name: THS-01-KIT-IN-445-CTL
Lab Code: R2516953-010

Service Request: R2516953
Date Collected: 12/17/25
Date Received: 12/17/25 09:52
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	01/07/26 22:05	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Thomas High
Sample Matrix: Drinking Water
Sample Name: THS-01-KIT-IN-445-T1
Lab Code: R2516953-011

Service Request: R2516953
Date Collected: 12/17/25
Date Received: 12/17/25 09:52
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	01/07/26 22:06	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Thomas High
Sample Matrix: Drinking Water
Sample Name: THS-01-KIT-IN-445-T2
Lab Code: R2516953-012

Service Request: R2516953
Date Collected: 12/17/25
Date Received: 12/17/25 09:52
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	01/07/26 22:08	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Thomas High
Sample Matrix: Drinking Water
Sample Name: THS-01-KIT-IN-445-T3
Lab Code: R2516953-013

Service Request: R2516953
Date Collected: 12/17/25
Date Received: 12/17/25 09:52
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	01/07/26 22:09	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Thomas High
Sample Matrix: Drinking Water
Sample Name: THS-01-KIT-IN-445-T5
Lab Code: R2516953-014

Service Request: R2516953
Date Collected: 12/17/25
Date Received: 12/17/25 09:52
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	01/07/26 22:10	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Thomas High
Sample Matrix: Drinking Water
Sample Name: THS-01-KIT-IN-445-PFL
Lab Code: R2516953-015

Service Request: R2516953
Date Collected: 12/17/25
Date Received: 12/17/25 09:52
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	01/07/26 22:12	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Thomas High
Sample Matrix: Drinking Water
Sample Name: THS-01-KIT-IN-445-PFR
Lab Code: R2516953-016

Service Request: R2516953
Date Collected: 12/17/25
Date Received: 12/17/25 09:52
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	01/07/26 22:13	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Thomas High
Sample Matrix: Drinking Water
Sample Name: THS-01-RM-IN-POOL-DF
Lab Code: R2516953-017

Service Request: R2516953
Date Collected: 12/17/25
Date Received: 12/17/25 09:52
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	01/07/26 22:15	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Thomas High
Sample Matrix: Drinking Water
Sample Name: THS-01-RM-IN-POOL-BF
Lab Code: R2516953-018

Service Request: R2516953
Date Collected: 12/17/25
Date Received: 12/17/25 09:52
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	01/07/26 22:16	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Thomas High
Sample Matrix: Drinking Water
Sample Name: THS-01-FH-IN-470-DF1
Lab Code: R2516953-019

Service Request: R2516953
Date Collected: 12/17/25
Date Received: 12/17/25 09:52
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	01/07/26 22:17	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Thomas High
Sample Matrix: Drinking Water
Sample Name: THS-01-FH-IN-470-DF2
Lab Code: R2516953-020

Service Request: R2516953
Date Collected: 12/17/25
Date Received: 12/17/25 09:52
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	01/07/26 22:21	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Thomas High
Sample Matrix: Drinking Water
Sample Name: THS-01-FH-IN-470-DF3
Lab Code: R2516953-021

Service Request: R2516953
Date Collected: 12/17/25
Date Received: 12/17/25 09:52
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	01/07/26 22:23	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Thomas High
Sample Matrix: Drinking Water
Sample Name: THS-01-FH-IN-470-DF4
Lab Code: R2516953-022

Service Request: R2516953
Date Collected: 12/17/25
Date Received: 12/17/25 09:52
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	01/07/26 22:24	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Thomas High
Sample Matrix: Drinking Water
Sample Name: THS-01-FH-IN-470-BF
Lab Code: R2516953-023

Service Request: R2516953
Date Collected: 12/17/25
Date Received: 12/17/25 09:52
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	01/07/26 22:26	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Thomas High
Sample Matrix: Drinking Water
Sample Name: THS-01-CONC-IN-470B-T
Lab Code: R2516953-024

Service Request: R2516953
Date Collected: 12/17/25
Date Received: 12/17/25 09:52
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	01/07/26 22:33	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Thomas High
Sample Matrix: Drinking Water
Sample Name: THS-01-FR-IN-A134-T
Lab Code: R2516953-025

Service Request: R2516953
Date Collected: 12/17/25
Date Received: 12/17/25 09:52
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	3.3	ug/L	1.0	1	01/07/26 22:40	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Thomas High
Sample Matrix: Drinking Water
Sample Name: THS-01-RM-IN-C243-T
Lab Code: R2516953-026

Service Request: R2516953
Date Collected: 12/17/25
Date Received: 12/17/25 09:52
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	01/07/26 22:41	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Thomas High
Sample Matrix: Drinking Water
Sample Name: THS-01-HA-BY-216-DFL
Lab Code: R2516953-027

Service Request: R2516953
Date Collected: 12/17/25
Date Received: 12/17/25 09:52
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	01/07/26 22:42	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Thomas High
Sample Matrix: Drinking Water
Sample Name: THS-01-HA-BY-216-DFR
Lab Code: R2516953-028

Service Request: R2516953
Date Collected: 12/17/25
Date Received: 12/17/25 09:52
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.2	ug/L	1.0	1	01/07/26 22:44	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Thomas High
Sample Matrix: Drinking Water
Sample Name: THS-01-HA-BY-402-DFL
Lab Code: R2516953-029

Service Request: R2516953
Date Collected: 12/17/25
Date Received: 12/17/25 09:52
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	01/07/26 22:45	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Thomas High
Sample Matrix: Drinking Water
Sample Name: THS-01-HA-BY-402-BFL
Lab Code: R2516953-030

Service Request: R2516953
Date Collected: 12/17/25
Date Received: 12/17/25 09:52
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	01/07/26 22:46	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Thomas High
Sample Matrix: Drinking Water
Sample Name: THS-01-HA-BY-402-DFR
Lab Code: R2516953-031

Service Request: R2516953
Date Collected: 12/17/25
Date Received: 12/17/25 09:52
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	01/07/26 22:48	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Thomas High
Sample Matrix: Drinking Water
Sample Name: THS-01-HA-BY-402-BFR
Lab Code: R2516953-032

Service Request: R2516953
Date Collected: 12/17/25
Date Received: 12/17/25 09:52
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	01/07/26 22:49	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Thomas High
Sample Matrix: Drinking Water
Sample Name: THS-01-HA-BY-CAFE-DFL
Lab Code: R2516953-033

Service Request: R2516953
Date Collected: 12/17/25
Date Received: 12/17/25 09:52
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	01/07/26 22:51	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Thomas High
Sample Matrix: Drinking Water
Sample Name: THS-01-HA-BY-CAFE-BFL
Lab Code: R2516953-034

Service Request: R2516953
Date Collected: 12/17/25
Date Received: 12/17/25 09:52
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	01/07/26 22:55	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Thomas High
Sample Matrix: Drinking Water
Sample Name: THS-01-HA-BY-CAFE-DFR
Lab Code: R2516953-035

Service Request: R2516953
Date Collected: 12/17/25
Date Received: 12/17/25 09:52
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	01/07/26 22:56	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Thomas High
Sample Matrix: Drinking Water
Sample Name: THS-01-HA-BY-CAFE-BFR
Lab Code: R2516953-036

Service Request: R2516953
Date Collected: 12/17/25
Date Received: 12/17/25 09:52
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	01/07/26 22:58	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Thomas High
Sample Matrix: Drinking Water
Sample Name: THS-01-HA-GYM-DFL
Lab Code: R2516953-037

Service Request: R2516953
Date Collected: 12/17/25
Date Received: 12/17/25 09:52
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	01/07/26 22:59	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Thomas High
Sample Matrix: Drinking Water
Sample Name: THS-01-HA-GYM-BFL
Lab Code: R2516953-038

Service Request: R2516953
Date Collected: 12/17/25
Date Received: 12/17/25 09:52
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	01/07/26 23:00	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Thomas High
Sample Matrix: Drinking Water
Sample Name: THS-01-HA-GYM-DFR
Lab Code: R2516953-039

Service Request: R2516953
Date Collected: 12/17/25
Date Received: 12/17/25 09:52
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	01/09/26 14:19	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Thomas High
Sample Matrix: Drinking Water
Sample Name: THS-01-HA-GYM-BFR
Lab Code: R2516953-040

Service Request: R2516953
Date Collected: 12/17/25
Date Received: 12/17/25 09:52
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	01/09/26 14:23	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Thomas High
Sample Matrix: Drinking Water
Sample Name: THS-01-HA-BY-GCONC-DF
Lab Code: R2516953-041

Service Request: R2516953
Date Collected: 12/17/25
Date Received: 12/17/25 09:52
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	01/09/26 14:24	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Thomas High
Sample Matrix: Drinking Water
Sample Name: THS-01-HA-BY-GCONC-BF
Lab Code: R2516953-042

Service Request: R2516953
Date Collected: 12/17/25
Date Received: 12/17/25 09:52
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	01/09/26 14:25	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Thomas High
Sample Matrix: Drinking Water
Sample Name: THS-01-328-T
Lab Code: R2516953-043

Service Request: R2516953
Date Collected: 12/17/25
Date Received: 12/17/25 09:52
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	01/09/26 14:27	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Thomas High
Sample Matrix: Drinking Water
Sample Name: THS-01-CR-IN-145-T
Lab Code: R2516953-044

Service Request: R2516953
Date Collected: 12/17/25
Date Received: 12/17/25 09:52
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	01/09/26 14:28	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Thomas High
Sample Matrix: Drinking Water
Sample Name: THS-01-KIT-IN-445-CTR
Lab Code: R2516953-045

Service Request: R2516953
Date Collected: 12/17/25
Date Received: 12/17/25 09:52
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	2.8	ug/L	1.0	1	01/09/26 14:32	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Thomas High
Sample Matrix: Drinking Water
Sample Name: THS-01-HA-BY-236DF
Lab Code: R2516953-046

Service Request: R2516953
Date Collected: 12/17/25
Date Received: 12/17/25 09:52
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	01/09/26 14:34	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Thomas High
Sample Matrix: Drinking Water
Sample Name: THS-01-HA-BY-236BF
Lab Code: R2516953-047

Service Request: R2516953
Date Collected: 12/17/25
Date Received: 12/17/25 09:52
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	01/09/26 14:35	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Thomas High
Sample Matrix: Drinking Water
Sample Name: THS-01-HA-BY-212-BF
Lab Code: R2516953-048

Service Request: R2516953
Date Collected: 12/17/25
Date Received: 12/17/25 09:52
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	01/09/26 14:37	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Thomas High
Sample Matrix: Drinking Water
Sample Name: THS-01-HA-BY-212-DF
Lab Code: R2516953-049

Service Request: R2516953
Date Collected: 12/17/25
Date Received: 12/17/25 09:52
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	01/09/26 14:38	



QC Summary Forms

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



Metals

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Thomas High
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2516953-MB1

Service Request: R2516953
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	01/07/26 22:30	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Thomas High
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2516953-MB2

Service Request: R2516953
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	01/07/26 21:48	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Thomas High
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2516953-MB3

Service Request: R2516953
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	01/07/26 21:01	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Labella Associates, PC
Project: Webster CSD - Thomas High
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2516953-MB4

Service Request: R2516953
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	01/09/26 14:16	

Client: Labella Associates, PC
Project: Webster CSD - Thomas High
Sample Matrix: Drinking Water

Service Request: R2516953
Date Collected: 12/17/25
Date Received: 12/17/25
Date Analyzed: 01/7/26

**Duplicate Matrix Spike Summary
Inorganic Parameters**

Sample Name: THS-01-RM-IN-240-T
Lab Code: R2516953-001
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike R2516953-001MS		Result	Duplicate Matrix Spike R2516953-001DMS		% Rec Limits	RPD	RPD Limit
			Spike Amount	% Rec		Spike Amount	% Rec			
Lead, Total	1.1	20.3	20.0	96	20.6	20.0	97	70-130	2	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Labella Associates, PC
Project: Webster CSD - Thomas High
Sample Matrix: Drinking Water

Service Request: R2516953
Date Collected: 12/17/25
Date Received: 12/17/25
Date Analyzed: 01/7/26

**Duplicate Matrix Spike Summary
Inorganic Parameters**

Sample Name: THS-01-RM-IN-251-T
Lab Code: R2516953-002
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike R2516953-002MS		Duplicate Matrix Spike R2516953-002DMS		% Rec Limits	RPD	RPD Limit	
			Spike Amount	% Rec	Result	Spike Amount				% Rec
Lead, Total	1.0 U	21.4	20.0	107	21.1	20.0	105	70-130	2	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Labella Associates, PC
Project: Webster CSD - Thomas High
Sample Matrix: Drinking Water

Service Request: R2516953
Date Collected: 12/17/25
Date Received: 12/17/25
Date Analyzed: 01/7/26

**Duplicate Matrix Spike Summary
Inorganic Parameters**

Sample Name: THS-01-FH-IN-470-BF
Lab Code: R2516953-023
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike R2516953-023MS		Result	Duplicate Matrix Spike R2516953-023DMS		% Rec Limits	RPD	RPD Limit
			Spike Amount	% Rec		Spike Amount	% Rec			
Lead, Total	1.0 U	19.8	20.0	99	19.7	20.0	99	70-130	<1	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Labella Associates, PC
Project: Webster CSD - Thomas High
Sample Matrix: Drinking Water

Service Request: R2516953
Date Collected: 12/17/25
Date Received: 12/17/25
Date Analyzed: 01/7/26

**Duplicate Matrix Spike Summary
Inorganic Parameters**

Sample Name: THS-01-CONC-IN-470B-T
Lab Code: R2516953-024
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike R2516953-024MS		Result	Duplicate Matrix Spike R2516953-024DMS		% Rec Limits	RPD	RPD Limit
			Spike Amount	% Rec		Spike Amount	% Rec			
Lead, Total	1.0 U	21.3	20.0	106	20.7	20.0	103	70-130	3	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Labella Associates, PC
Project: Webster CSD - Thomas High
Sample Matrix: Drinking Water

Service Request: R2516953
Date Collected: 12/17/25
Date Received: 12/17/25
Date Analyzed: 01/7/26

**Duplicate Matrix Spike Summary
Inorganic Parameters**

Sample Name: THS-01-HA-GYM-BFL
Lab Code: R2516953-038
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike R2516953-038MS		Duplicate Matrix Spike R2516953-038DMS		% Rec Limits	RPD	RPD Limit	
			Spike Amount	% Rec	Result	Spike Amount				% Rec
Lead, Total	1.0 U	20.1	20.0	101	20.1	20.0	100	70-130	<1	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

Client: Labella Associates, PC
Project: Webster CSD - Thomas High
Sample Matrix: Drinking Water

Service Request: R2516953
Date Collected: 12/17/25
Date Received: 12/17/25
Date Analyzed: 01/9/26

**Duplicate Matrix Spike Summary
Inorganic Parameters**

Sample Name: THS-01-HA-GYM-DFR
Lab Code: R2516953-039
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike R2516953-039MS		Duplicate Matrix Spike R2516953-039DMS		% Rec Limits	RPD	RPD Limit	
			Spike Amount	% Rec	Result	Spike Amount				% Rec
Lead, Total	1.0 U	22.2	20.0	111	21.8	20.0	109	70-130	2	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Labella Associates, PC
Project: Webster CSD - Thomas High
Sample Matrix: Drinking Water

Service Request: R2516953
Date Analyzed: 01/07/26

Lab Control Sample Summary
Inorganic Parameters

Units:ug/L
Basis:NA

Lab Control Sample
R2516953-LCS1

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	20.7	20.0	103	85-115

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Labella Associates, PC
Project: Webster CSD - Thomas High
Sample Matrix: Drinking Water

Service Request: R2516953
Date Analyzed: 01/07/26

Lab Control Sample Summary
Inorganic Parameters

Units:ug/L
Basis:NA

Lab Control Sample
R2516953-LCS2

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	20.9	20.0	104	85-115

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Labella Associates, PC
Project: Webster CSD - Thomas High
Sample Matrix: Drinking Water

Service Request: R2516953
Date Analyzed: 01/07/26

Lab Control Sample Summary
Inorganic Parameters

Units:ug/L
Basis:NA

Lab Control Sample
R2516953-LCS3

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	20.5	20.0	102	85-115

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Labella Associates, PC
Project: Webster CSD - Thomas High
Sample Matrix: Drinking Water

Service Request: R2516953
Date Analyzed: 01/09/26

Lab Control Sample Summary
Inorganic Parameters

Units:ug/L
Basis:NA

Lab Control Sample
R2516953-LCS4

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	22.8	20.0	114	85-115



**APPENDIX C:
LICENSES AND CERTIFICATIONS**

United States Environmental Protection Agency

This is to certify that

LaBella Associates, D.P.C.

has fulfilled the requirements of the Toxic Substances Control Act (TSCA) Section 402, and has received certification to conduct lead-based paint activities pursuant to 40 CFR Part 745.226

In the Jurisdiction of:

All EPA Administered Lead-based Paint Activities Program States, Tribes and Territories

This certification is valid from the date of issuance and expires September 26, 2027

LBP-2226-3

Certification #

August 01, 2024

Issued On



A handwritten signature in black ink, appearing to read "Marc Edmonds".

Marc Edmonds, Chief

Risk Assessment Management Branch 2.

United States Environmental Protection Agency

This is to certify that



Cory J Stamp

has fulfilled the requirements of the Toxic Substances Control Act (TSCA) Section 402, and has received certification to conduct lead-based paint activities pursuant to 40 CFR Part 745.226 as:

Risk Assessor

In the Jurisdiction of:

All EPA Administered Lead-based Paint Activities Program States, Tribes and Territories

This certification is valid from the date of issuance and expires October 24, 2028

LBP-R-I206349-3

Certification #

October 15, 2025

Issued On



A handwritten signature in black ink that reads "Ben Conetta".

Ben Conetta, Manager

Chemicals and Multimedia Programs Branch

NEW YORK STATE DEPARTMENT OF HEALTH
WADSWORTH CENTER



Expires 12:01 AM April 01, 2026
Issued April 01, 2025

CERTIFICATE OF APPROVAL FOR LABORATORY SERVICE

Issued in accordance with and pursuant to section 502 Public Health Law of New York State

MS. CHRISTINE KUTZER
ALS ENVIRONMENTAL - ROCHESTER
1565 JEFFERSON ROAD BUILDING 300, SUITE 360
ROCHESTER, NY 14623

NY Lab Id No: 10145

*is hereby APPROVED as an Environmental Laboratory in conformance with the
National Environmental Laboratory Accreditation Conference Standards (2016) for the category
ENVIRONMENTAL ANALYSES POTABLE WATER
All approved analytes are listed below:*

Bacteriology

Coliform, Total / E. coli (Qualitative) SM 20, 21-23 9223B (-04) (Colilert)

Dissolved Gases

Acetylene RSK-175
Ethane RSK-175
Ethene (Ethylene) RSK-175
Methane RSK-175
Propane RSK-175

Fuel Additives

Methyl tert-butyl ether EPA 524.2
Naphthalene EPA 524.2

Metals I

Arsenic, Total EPA 200.8 Rev. 5.4
Barium, Total EPA 200.8 Rev. 5.4
Cadmium, Total EPA 200.8 Rev. 5.4
Chromium, Total EPA 200.7 Rev. 4.4
Copper, Total EPA 200.8 Rev. 5.4
Iron, Total EPA 200.7 Rev. 4.4
Lead, Total EPA 200.8 Rev. 5.4
Manganese, Total EPA 200.7 Rev. 4.4
Mercury, Total EPA 245.1 Rev. 3.0
Selenium, Total EPA 200.8 Rev. 5.4
Silver, Total EPA 200.7 Rev. 4.4
Zinc, Total EPA 200.7 Rev. 4.4



Serial No.: 70111

Property of the New York State Department of Health. Certificates are valid only at the address shown and must be conspicuously posted by the laboratory. Continued accreditation depends on the laboratory's successful ongoing participation in the Program. Consumers may verify a laboratory's accreditation status online at <https://apps.health.ny.gov/pubdoh/applinks/wc/elappublicweb/>, by phone (518) 485-5570 or by email to elap@health.ny.gov.

