

Klem Road North Elementary School Resamples				
New Identification Code	Description	Date Sampled	Time Sampled	Result (µg/L)
KN-01-RM-IN-LIB-T	Library Tap - RESAMPLE	1/15/26	710	<1.0
KN-01-OFF-IN-MO-T	Main Office Tap - RESAMPLE	1/15/26	712	<1.0
Klem South Resample				
New Identification Code	Description	Date Sampled	Time Sampled	Result (µg/L)
KS-01-CR-IN-807A-T	Band Room Sink - RESAMPLE	12/18/25	700	1.08
Plank Road North Elementary School Resample				
Identification Code	Description	Date Sampled	Time Sampled	Result (µg/L)
PN-01-CR-IN-121-T	Classroom 121 Tap - RESAMPLE	1/15/26	635	<1.0
Webster Schroeder High School Resamples				
Identification Code	Description	Date Sampled	Time Sampled	Result (µg/L)
SHS-01-KIT-IN-58-T1	Western Kitchen 58 Tap 1 - RESAMPLE	1/15/26	633	<1.0
SHS-02-RM-IN-W228-T	Room W228 Tap - RESAMPLE	1/15/26	635	<1.0
Spry Middle School Resample				
Identification Code	Description	Date Sampled	Time Sampled	Result (µg/L)
SMS-02-CR-IN-208-T	Classroom 208 Tap - RESAMPLE	10/28/25	716	2.1
Willink Middle School Resample				
Identification Code	Description	Date Sampled	Time Sampled	Result (µg/L)
WMS-01-CR-IN-D106-T	Classroom D103 Tap - RESAMPLE	10/28/25	703	<1.0